OMRON

Programmable Terminal

NA-series

Hardware (-V1)

User's Manual

NA5-15□101□-V1(-P)

NA5-12□101□-V1(-P)

NA5-9□001□-V1(-P)

NA5-7□001□-V1(-P)





NOTE

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form, or by any means, mechanical, electronic, photocopying, recording, or otherwise, without the prior written permission of OMRON.

No patent liability is assumed with respect to the use of the information contained herein. Moreover, because OMRON is constantly striving to improve its high-quality products, the information contained in this manual is subject to change without notice. Every precaution has been taken in the preparation of this manual. Nevertheless, OMRON assumes no responsibility for errors or omissions. Neither is any liability assumed for damages resulting from the use of the information contained in this publication.

Trademarks

- Sysmac and SYSMAC are trademarks or registered trademarks of OMRON Corporation in Japan and other countries for OMRON factory automation products.
- · Microsoft, Windows, Microsoft Edge, Excel, and Visual Basic are either registered trademarks or trademarks of Microsoft Corporation in the United States and other countries.
- EtherCAT® is registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.
- ODVA, CIP, CompoNet, DeviceNet, and EtherNet/IP are trademarks of ODVA.
- The SD and SDHC logos are trademarks of SD-3C, LLC.



- Portions of this software are copyright 2014 The FreeType Project (freetype.org). All rights reserved.
- Celeron, Intel, Intel Core and Intel Atom are trademarks of Intel Corporation in the U.S. and / or other countries.

Other company names and product names in this document are the trademarks or registered trademarks of their respective companies.

Copyrights

Microsoft product screen shots used with permission from Microsoft.

Introduction

Thank you for purchasing an NA-series Programmable Terminal.

This manual contains information that is necessary to use the NA-series Programmable Terminal. Please read this manual and make sure you understand the functionality and performance of the NA-series Programmable Terminal before you attempt to use it in a control system.

Keep this manual in a safe place where it will be available for reference during operation.

Intended Audience

This manual is intended for the following personnel, who must also have knowledge of electrical systems (an electrical engineer or the equivalent).

- · Personnel in charge of introducing FA systems.
- · Personnel in charge of designing FA systems.
- · Personnel in charge of installing and maintaining FA systems.
- · Personnel in charge of managing FA systems and facilities.

Applicable Products

This manual covers the following products.

NA-series Programmable Terminals NA5-□□W□□□□-V1(-P)

Relevant Manuals

The basic information required to use an NA-series PT is provided in the following manuals.

- NA-series Programmable Terminal Hardware User's Manual (Cat. No. V117)
- NA-series Programmable Terminal Hardware(-V1) User's Manual (Cat. No. V125)
- NA-series Programmable Terminal Software User's Manual (Cat. No. V118)
- NA-series Programmable Terminal Device Connection User's Manual (Cat. No. V119)
- NA-series Programmable Terminal Soft-NA User's Manual (Cat. No. V126)

Operations are performed from the Sysmac Studio Automation Software.

Refer to the Sysmac Studio Version 1 Operation Manual (Cat. No. W504) for information on the Sysmac Studio.

Other manuals are necessary for specific system configurations and applications.

The following manual is also available to walk you through installations and operations up to starting actual operation using simple examples.


Refer to it as required.

• NA-series Programmable Terminal Startup Guide Manual (Cat. No. V120)

Manual Structure

Page Structure and Markings

The following page structure is used in this manual.



Note This illustration is provided only as a sample. It may not literally appear in this manual.

Special Information

Special information in this manual is classified as follows:



Precautions for Safe Use

Precautions on what to do and what not to do to ensure safe usage of the product.



Precautions for Correct Use

Indicates precautions on what to do and what not to do to ensure proper operation and performance.



Additional Information

Additional information to read as required.

This information is provided to increase understanding or make operation easier.



Version Information

Information on differences in specifications and functionality with different versions is given.

Sections in this Manual

			1
1	Introduction to the NA-series Programmable Terminals		2
2			3
2	Configuration Units	_/ /	4
3	Installation and Wiring	///	5
4	System Program		6
5	Troubleshooting		A
6	Maintenance	_///	ı
Α	Appendices		
1	Index		

Sections in this Manual

CONTENTS

	Intro	oduction	1
	Rele	vant Manuals	2
	Man	ual Structure	3
	Sect	tions in this Manual	5
	Term	ns and Conditions Agreement	11
	Safe	ety Precautions	13
	Prec	cautions for Safe Use	17
	Prec	autions for Correct Use	20
	Regu	ulations and Standards	21
	Conf	formance to Shipbuilding Standards	23
		ted Manuals	
	Term	ninology	35
	Revi	ision History	36
Section		Introduction to the NA-series Programmable Ter	
	n 1	Introduction to the NA-series Programmable Ter	minals
	n 1	Introduction to the NA-series Programmable Ter NA-series Programmable Terminals 1-1-1 Features.	minals1-21-41-4
	n 1 1-1 1-2	Introduction to the NA-series Programmable Ter NA-series Programmable Terminals	minals1-21-41-41-61-6
	n 1 1-1 1-2 1-3	Introduction to the NA-series Programmable Ter NA-series Programmable Terminals 1-1-1 Features System Configurations 1-2-1 Connecting to the Support Software 1-2-2 Network Configuration with Other Devices Available Products 1-3-1 NA Units 1-3-2 Support Software 1-3-3 Other Optional Products	minals
	n 1 1-1 1-2 1-3	Introduction to the NA-series Programmable Ter NA-series Programmable Terminals 1-1-1 Features System Configurations 1-2-1 Connecting to the Support Software 1-2-2 Network Configuration with Other Devices Available Products 1-3-1 NA Units 1-3-2 Support Software 1-3-3 Other Optional Products Specifications 1-4-1 General Specifications	minals
Section	n 1 1-1 1-2 1-3	Introduction to the NA-series Programmable Terminals 1-1-1 Features	minals
Section	n 1 1-1 1-2 1-3 1-4 n 2 2-1	Introduction to the NA-series Programmable Ter NA-series Programmable Terminals	minals

	2-3	USB Memory Devices	2-12
		2-3-1 Models and Specifications	
		2-3-2 Applications	
		2-3-3 Installing and Removing	2-12
	2-4	Support Software	2-14
	2-4	2-4-1 Connection Methods	
		24-1 Golfficetor Mctriogs	ـــــــــــــــــــــــــــــــــــــ
Sect	tion 3	Installation and Wiring	
	3-1	Processing at Power ON and Power OFF	3-2
		3-1-1 Power ON Operation	
		3-1-2 Power OFF Operation	3-2
	3-2	Fail-safe Measures	3-3
		3-2-1 Power ON Sequence	3-3
	3-3	Installing NA Units	3_4
	5-5	3-3-1 Installation in a Control Panel	
	3-4		
		3-4-1 Power Supply Wiring	
		3-4-2 Wiring the Ethernet Port	
		3	
	3-5		
		3-5-1 Temperature	
		3-5-2 Humidity	
		3-5-3 Vibration and Shock	
		3-5-5 Electrical Environment	
		3-5-6 Grounding	
Sect	tion 4	System Program	
	4-1	System Program and NA Unit Startup Status	
	4-2	System Recovery	4-3
	4-3	System Menu Overview	4-6
		4-3-1 System Menu Configuration	
		4-3-2 Using the System Menu	4-9
	4-4	System Menu Details	4-11
		4-4-1 Display Settings (Project System Menu)	
		4-4-2 Language Settings (Project System Menu)	
		4-4-3 External Device Settings (Project System Menu)	
		4-4-4 User Accounts (Project System Menu)	4-13
		4-4-5 NJ/NX/NY Troubleshooter (Project System Menu)	
		4-4-6 Alarm Viewer (Project System Menu)	
		4-4-7 Project System Menu Settings (Project System Menu)	
		4-4-8 Print Settings (Project System Menu)	
		4-4-9 Buzzer Settings (Project System Menu)	
		4-4-10 Operation Log Viewer4-4-11 Safety Monitor	
		4-4-12 Date & Time Settings (Device System Menu)	
		4-4-13 Language Settings (Device System Menu)	
		4-4-14 Interface Settings (Device System Menu)	
		4-4-15 Brightness Settings (Device System Menu)	4-54
		4-4-16 Transfer Operations (Device System Menu)	
		4-4-17 Hardware Diagnostics (Device System Menu)	
		4-4-18 Production Information (Device System Menu)	4-64

Section 5		Iroubleshooting					
	5-1	Operation after an Error					
		5-1-1 Checking NA Unit Status					
		5-1-2 Fatal Errors in the NA Unit					
	5-2	Troubleshooting					
		5-2-1 Confirming NA Unit Operation					
		5-2-2 Correcting Fatal Errors in the NA Unit					
		5-2-3 Troubleshooting Non-fatal Errors					
		5-2-5 Troubleshooting NA Unit Errors					
Sectio	n 6	Maintenance					
	6-1	Periodic Maintenance and Inspection	6-2				
		6-1-1 Preparations for Problems	6-2				
		6-1-2 Periodic Inspection					
		6-1-3 Precautions When Replacing the NA Unit					
		6-1-4 Cleaning	6-4				
	6-2	Replacing the Battery	6-5				
		6-2-1 Battery Replacement					
		6-2-2 Operation without a Battery	6-6				
Appen	dic	es					
	A-1	Dimensions					
		A-1-1 NA Units	A-2				
	A-2	Available Products					
		A-2-1 Optional Products	A-10				
Index							

Terms and Conditions Agreement

Warranty, Limitations of Liability

Warranties

Exclusive Warranty

Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.

Limitations

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right.

Buyer Remedy

Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See https://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Application Considerations

Suitability of Use

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

Disclaimers

Performance Data

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions

Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

Safety Precautions

Definition of Precautionary Information

The following notation is used in this manual to provide precautions required to ensure safe usage of the NA-series Programmable Terminal. The safety precautions that are provided are extremely important to safety. Always read and heed the information provided in all safety precautions.

The following notation is used.



Indicates a potentially hazardous situation which, if not avoided, could result in mild or moderate injury or at the worst, serious injury or death. Additionally, there may be severe property damage.



Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury, or property damage.



Indicates precautions on what to do and what not to do to ensure safe usage of the product.



Indicates precautions on what to do and what not to do to ensure proper operation and performance.

Symbols



The circle and slash symbol indicates operations that you must not do.

The specific operation is shown in the circle and explained in text.

This example indicates prohibiting disassembly.



The triangle symbol indicates precautions (including warnings).

The specific operation is shown in the triangle and explained in text.

This example indicates a general precaution.



The filled circle symbol indicates operations that you must do.

The specific operation is shown in the circle and explained in text.

This example shows a general precaution for something that you must do.

Warnings

∕N WARNING

Do not attempt to take the NA Unit apart and do not touch the product inside while the power is being supplied. Otherwise it may result in electric shock.



Always ensure that the personnel in charge confirm that installation, inspection, and maintenance were properly performed for the NA Unit. "Personnel in charge" refers to individuals qualified and responsible for ensuring safety during machine design, installation, operation, maintenance, and disposal.



Ensure that installation and post-installation checks are performed by personnel in charge who possess a thorough understanding of the machinery to be installed.



Do not use the input functions such as the touch panel or function keys of the NA Unit, in applications that involve human life, in applications that may result in serious injury, or for emergency stop switches.



Do not attempt to disassemble, repair, or modify the NA Unit. It may cause NA Unit to lose its safety function.



Never press two points or more on the touch panel of the NA Unit at a time. Touching two points or more interrupts normal touch panel operations.



To conform to UL Type 4X standards, always use the NA5-\(\subseteq \text{UV}\)\(\subseteq \text{U-V1-P/NA5-9W}\)\(\subseteq \subseteq \text{V1-P with a High-pressure Waterproof Attachment (PWA). If you do not use a PWA, there is a risk of water entry, which may cause severe equipment damage.



Always pay attention to the inside dimensions when you mount a PWA on the NA Unit. If you do not mount the PWA correctly, there is a risk of water entry, which may cause severe equipment damage.



Security Measures

Anti-virus protection

Install the latest commercial-quality antivirus software on the computer connected to the control system and maintain to keep the software up-to-date.



Security measures to prevent unauthorized access

Take the following measures to prevent unauthorized access to our products.

- · Install physical controls so that only authorized personnel can access control systems and equipment.
- Reduce connections to control systems and equipment via networks to prevent access from untrusted devices.
- · Install firewalls to shut down unused communications ports and limit communications hosts and isolate control systems and equipment from the IT network.
- Use a virtual private network (VPN) for remote access to control systems and equipment.
- · Adopt multifactor authentication to devices with remote access to control systems and equipment.
- Set strong passwords and change them frequently.
- · Scan virus to ensure safety of USB drives or other external storages before connecting them to control systems and equipment.

Data input and output protection

Validate backups and ranges to cope with unintentional modification of input/output data to control systems and equipment.

- · Checking the scope of data
- · Checking validity of backups and preparing data for restore in case of falsification and abnormal-
- Safety design, such as emergency shutdown and fail-soft operation in case of data tampering and abnormalities



Data recovery

Backup data and keep the data up-to-date periodically to prepare for data loss.



When using an intranet environment through a global address, connecting to an unauthorized terminal such as a SCADA, HMI or to an unauthorized server may result in network security issues such as spoofing and tampering. You must take sufficient measures such as restricting access to the terminal, using a terminal equipped with a secure function, and locking the installation area by yourself.



When constructing an intranet, communication failure may occur due to cable disconnection or the influence of unauthorized network equipment. Take adequate measures, such as restricting physical access to network devices, by means such as locking the installation area.



When using a device equipped with the SD Memory Card function, there is a security risk that a third party may acquire, alter, or replace the files and data in the removable media by removing the removable media or unmounting the removable media.



Please take sufficient measures, such as restricting physical access to the Controller or taking appropriate management measures for removable media, by means of locking the installation area, entrance management, etc., by yourself.



Precaution


∕<u>N</u> WARNING

Wiring

Observe the following precautions when wiring the NA5-\(\subseteq\) W\(\subseteq\) \(\subseteq\).


The internal power supply in the NA5-\(\subseteq\) W\(\subseteq\) \(\subseteq\) V1(-P) is a non-isolated DC power supply. Never ground the 24 V side. If the 24 V power supply to the NA is grounded positively, a short circuit will occur as shown below and may result in damage to the device.

24 V Grounding Power Supply





Grounding diagram



*1. Protective grounding is not required for the NA5-\(\subseteq\) W\(\subseteq\) \(\subseteq\)-V1-P, and thus no wiring is necessary.




Additional Information

The internal power supply of the NA5- $\square\square$ W $\square\square\square$ Product uses an isolated DC power supply, and therefore is not susceptible to the effects of grounding of the 24 V side.

Precautions for Safe Use

- When unpacking the NA Unit, check carefully for any external scratches or other damages. Also, shake the NA Unit gently and check for any abnormal sound.
- The NA Unit must be installed on a flat surface of a control panel.
- Do not let metal particles enter the NA Unit when preparing the panel.
- Turn OFF the power supply before connecting or disconnecting cables.
- Periodically check the installation conditions in applications where the NA Unit is subject to contact with oil or water.
- Be certain to use the cables with lock mechanism such as serial cable or the Ethernet cable after confirming if it is securely locked.
- Do not touch the packaging part of the circuit board with your bare hands. Discharge any static electricity from your body before handling the board.
- Do not use volatile solvents such as benzene and thinners or chemical cloths.
- Water and oil resistance will be lost if the front sheet is torn or is peeling off. Do not use the NA Unit, if the front sheet is torn or is peeling off.
- As the rubber packing will deteriorate, shrink, or harden depending on the operating environment, periodical inspection is necessary.
- Confirm the safety of the system before turning ON or OFF the power supply, or pressing the reset switch.
- The whole system may stop depending on how the power supply is turned ON or OFF. Turn ON/OFF
 the power supply according to the specified procedure.
- · Operate DIP switch according to the following way.



The DIP switch may break if it is levered with a tool against the case as shown in the figure.

- Once the DIP switch settings are changed, reset by pressing the reset switch, or restart the power supply.
- Initialize the project, after confirming that existing project is backed up at the Sysmac Studio.
- When changing the password, do not reset or turn OFF the power supply until the writing is completed. A failure to store the password may cause the project to fail to function.
- While uploading or downloading a project or a system program, do not perform the operations as follows. Such operations may corrupt the project or the system program:
 - · Turning OFF the power supply of the NA Unit.
 - · Resetting the NA Unit.
 - · Removing the USB devices or SD card.
 - Disconnecting the cable between a support tool and the NA Unit.
- Do not connect an AC power supply to the DC power terminals.
- Do not perform a dielectric strength test.
- Use a DC power with a slight voltage fluctuation and that will provide a stable output even if the input is momentarily interrupted for 10 ms. Also use the one with reinforced insulation or double insulation.
 Rated Power Supply Voltage: 24 VDC (Allowable range 19.2 to 28.8 VDC)

- Use a power cable with AWG#12 to #22 thick (0.35 mm² to 3.31 mm²). Peel the coating 7 mm length and tighten the terminal screw with the torque in the range of 0.5 to 0.6 N·m. Also confirm if the terminal screw is tighten appropriately.
- · Ground the NA Unit correctly.
- When using the NA5-□□W□□□□-V1, to help prevent electrical shock, ground to 100 Ω or less by using dedicated ground wires (with cross-section area of 2 mm² or larger) and tighten the terminal screw on the protective ground terminal to a torque of 1.0 to 1.2 N·m.
- Do not use any battery if strong impact is applied to it (e.g. by dropping on the floor) because such a battery may cause a leakage.
- Confirm the type of the battery to install the battery properly.
- Apply power for at least five minutes before changing the battery. Mount a new battery within five minutes after turning OFF the power supply. If power is not supplied for at least five minutes, the clock data may be lost. Check the clock data after changing the battery.
- · Do not dismantle a battery nor let it short-circuit.
- Do not apply an impact with the lithium battery, charge it, dispose it into a fire, or heat it. Doing either of them may cause an ignition or a bursting.
- · Dispose of the NA Units and batteries according to local ordinances as they apply.



廢電池請回收

The following precaution must be displayed on all products containing lithium primary batteries with a
perchlorate content of 6 ppb or higher when exporting them to or shipping them through California,
USA.

Perchlorate Material - special handling may apply.

See www.dtsc.ca.gov/hazardouswaste/perchlorate

The NA-Series contains a lithium primary battery with a perchlorate content of 6 ppb or higher. When exporting a product containing the NA-Series to or shipping such a product through California, USA, label all packing and shipping containers appropriately.

- Do not connect the USB devices in the environment subject to the strong vibration.
- Use a USB memory device for temporary purposes such as data transfer.
- · Do not connect USB devices which are not allowed to connect to NA Unit.
- Start actual system application only after checking normal operation of the system including storage devices such as USB memory and SD card.
- When connecting peripheral devices which do not meet the performance level of the NA Unit for noise and static electricity, ensure sufficient countermeasures against noise and static electricity during installation of the peripheral devices to the NA Unit.
- Do not carry out the following operations when accessing USB devices or SD card:
 - Turning OFF the power supply of the NA Unit
 - · Press the Reset switch of the NA Unit
 - · Pull out the USB devices or SD card
- When using the No. 6 pin of the serial port connector for a voltage of DC+5 V, make sure the supply equipment's current capacity is below 250 mA before using it. The DC+5 V voltage output of the NA Unit is +5 V±5%, and the maximum current is 250 mA.
- To ensure the system's safety, make sure to incorporate a program that call periodically signals during the operation at connected device side and can confirm the normal functionality of the NA Unit before running the system.
- Do not press the touch panel with a force greater than 30 N.
- Do not use hard or pointed objects to operate or scrub the screen, otherwise the surface of the screen may be damaged.
- The deterioration over time may cause the touch points to move on the touch panel. Calibrate the touch panel periodically.

- A touch position detection error of approximately 20 pixels may occur due to the precision of the touch panel. Always take this into account when positioning objects on the panel so adjoining objects will not be activated by mistake.
- Confirm the safety of the system before pressing the touch panel.
- Do not accidentally press the touch panel when the backlight is not lit or when the display does not appear or is too dark to identify visually.
- You can change the brightness by changing the setting such as in the system menu or by downloading project.
 - If the brightness is set to very dark, it causes flickering or unreadable screen. Additionally, the brightness can be restored by transferring the project again after setting the property of the brightness appropriately.
 - In a case of the applications where end users can control the brightness, create the applications so as keeping on operations by such as assigning the function which restores the brightness to one of function keys, if necessary.
- Signals from the touch panel may not be entered if the touch panel is pressed consecutively at high speed. Make sure to go on the next operation after confirming that the NA Unit has detected the input of the touch panel.
- Displaying a pattern for a long time, 24 hours as an indication, may cause an afterimage on the display. Use Screen Saver function or switch displaying screens to prevent the afterimage.
- The function keys have the restrictions as follows:
 - When you use gloves or others, the function keys may not work correctly depending on the material and thickness of the gloves. Take actual conditions of the gloves usage into considerations prior to the system startup to perform the confirmation.
 - The function keys do not work when covered with water. Remove the water completely before
 use.

Precautions for Correct Use

• Do not install or store the NA Unit in any of the following locations:

- · Locations subject to severe changes in temperature
- · Locations subject to temperatures or humidity outside the range specified in the specifications
- · Locations subject to condensation as the result of high humidity
- · Locations subject to corrosive or flammable gases
- · Locations subject to strong shock or vibration
- · Locations outdoors subject to direct wind and rain
- Locations subject to strong ultraviolet light
- · Locations subject to dust
- · Locations subject to direct sunlight
- · Locations subject to splashing oil or chemicals

Take appropriate and sufficient countermeasures when installing systems in the following locations:

- Locations subject to static electricity or other forms of noise
- · Locations subject to strong electric field or magnetic field
- · Locations close to power supply lines
- · Locations subject to possible exposure to radioactivity

Mounting Panel

• The following table shows the mounting panel thickness and the necessity of using a High-pressure Waterproof Attachment (PWA) to conform to standards.

Model	UL Type	1, IP65	UL Type 4X ^{*1}		
Model	Panel thickness	PWA	Panel thickness	PWA	
NA5-15W□□□□-V1	1.6 to 6.0 mm	Not necessary	1.6 to 4.5 mm	Necessary*2	
NA5-12W□□□□-V1				·	
NA5-9W□□□□-V1					
NA5-7W□□□□-V1					
NA5-15W□□□□-V1-P			1.6 to 6.0 mm	Not necessary*3	
NA5-12W□□□□-V1-P				,	
NA5-9W□□□□-V1-P			1.6 to 4.5 mm	Necessary*2	
NA5-7W□□□□-V1-P				,	

^{*1.} Do not use the NA Unit outdoors.

• Tighten the Mounting Brackets evenly to a torque of between 0.5 and 0.6 N·m to maintain water and dust resistance. If the tightening torque exceeds the specified range or the tightening is not even, deformation of the front panel may occur. Make sure the panel is not dirty or warped, that the front surface is smooth, and that the panel is strong enough to hold the NA Unit.

^{*2.} Be sure to use a PWA. If you do not use a PWA, there is a risk of water entry, which may cause severe equipment damage.

^{*3.} Do not use a PWA. If you use a PWA, there is a risk of water entry, which may cause severe equipment damage.

Regulations and Standards

Conformance to EMC Regulations

Concepts

NA-series PTs are industrial electrical devices that are incorporated into various types of machines and manufacturing equipment. The products conform to the relevant standards so that the machines and equipment incorporating the Omron products can comply with EMC Regulations more easily.

Refer to the OMRON website (www.ia.omron.com) or ask your OMRON representative for the most recent standards to which our products conform.

To ensure that your machine or equipment complies with EMC regulations, please observe the following precautions.

- The NA Unit is defined as an in-panel device and must be installed within a control panel.
- NA-series PTs complies with the emission standards. For the radiated emission requirements, in
 particular, please note that the actual emission varies depending on the configuration of the control panel to be used, the connected devices, and wiring methods. Therefore, customers themselves must confirm that the entire machine or equipment conforms to EMC regulations, even you
 are using a device that conforms to EMC regulations.
- You must use reinforced insulation or double insulation for the DC power supplies connected to the NA Unit.

Caution:

This equipment is not intended for use in residential environments and may not provide adequate protection to radio reception in such environments.

Conformance to KC Standards

When you use this product in South Korea, observe the following precautions.

사용자안내문이 기기는 업무용 환경에서 사용할 목적으로 적합성평가를 받은기기로서 가정용 환경에서 사용하는 경우 전파간섭의 우려가 있습니다.

This product meets the electromagnetic compatibility requirements for business use. There is a risk of radio interference when this product is used in home.

Model	URL
NA5-15W□□□□-V1-P	https://www.rra.go.kr/selform/OMR-NA5-00013
NA5-12W□□□□-V1-P	https://www.rra.go.kr/selform/OMR-NA5-00012
NA5-9W□□□□-V1-P	https://www.rra.go.kr/selform/OMR-NA5-00011
NA5-7W□□□□-V1-P	https://www.rra.go.kr/selform/OMR-NA5-00010

Conformance to Shipbuilding Standards

The NA-series Programmable Terminals comply with shipping standards. Application conditions are set for compliance for individual shipping standards, and it may not be possible to use the product in some installation locations. Contact an OMRON sales representative before using the product.

International Shipping Standards

Shipping Standards of Various Countries

Abbreviation	Country	Name
NK	Japan	ClassNK
LR	Great Britain Lloyd's Register of Shipping	
DNV	Norway and Germany	Det Norske Veritas Germanischer Lloyd
RINA	Italy	Registro Italiano Navale
BV	BV France Bureau Veritas	
ABS	USA	American Bureau of Shipping
KR	South Korea	Korean Register of Shipping
CR Taiwan China Corporation Register of Sh		China Corporation Register of Shipping

Certification Status for NA Units

The following table shows the certification status with shipping standards for NA Units. For the latest applicable standards for each model, refer to our website (www.fa.omron.co.jp or www.ia.omron.com) or check with your OMRON representative.


NA5-00W0000-V1

Abbreviation	NA5W-15□□□□-V1	NA5W-12□□□□-V1	NA5W-9□□□□-V1	NA5W-7□□□□-V1
NK	Certified	Certified	Certified	Certified
LR	Certified	Certified	Certified	Certified
DNV	Certified	Certified	Certified	Certified
RINA	Uncertified	Uncertified	Uncertified	Uncertified
BV	Certified	Certified	Certified	Certified
ABS	Certified	Certified	Certified	Certified
KR	Uncertified	Uncertified	Uncertified	Uncertified
CR	Uncertified	Uncertified	Uncertified	Uncertified

NA5-DDWDDDD-V1-P

Abbreviation	NA5-15W□□□□-V1 -P	NA5-12W□□□□-V1 -P	NA5-9W□□□□-V1 -P	NA5-7W□□□□-V1 -P
NK	Uncertified	Uncertified	Uncertified	Uncertified
LR	Uncertified	Uncertified	Uncertified	Uncertified
DNV	Uncertified	Uncertified	Uncertified	Uncertified
RINA	Uncertified	Uncertified	Uncertified	Uncertified
BV	Uncertified	Uncertified	Uncertified	Uncertified
ABS	Uncertified	Uncertified	Uncertified	Uncertified
KR	Uncertified	Uncertified	Uncertified	Uncertified
CR	Uncertified	Uncertified	Uncertified	Uncertified

Certification Zones for Shipping Standards



- a. Deck zone
- b. Zones with and without air conditioning on the bridge (e.g., helm room)
- c. Depends on the ship type. Emergency power supply devices on bulk carrier ships carrying lique-fied gas or hazardous chemicals.
- d. Engine room zone (devices mounted on machinery that has strict vibration conditions, such as diesel engines or air compressors)
- e. Zones with and without air conditioning not on the bridge or deck (e.g., boiler room)

NA Unit Certification Zones for Shipping Standards

		b. Bridge		c. Ship		e. Not on deck or bridge	
Stan- dards	a. Deck	No air con- ditioning	With air condition- ing	type (e.g., bulk ship with lique- fied gas)	d. Engine (e.g.)	No air con- ditioning	With air condition- ing
NK	Uncertified	Certified	Certified	Uncertified	Uncertified	Certified	Certified
LR	Uncertified	Certified	Certified	Uncertified	Uncertified	Certified	Certified
DNV	Uncertified	Certified	Certified	Uncertified	Uncertified	Certified	Certified
RINA	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified
BV	Uncertified	Certified	Certified	Uncertified	Uncertified	Certified	Certified
ABS	Uncertified	Certified	Certified	Uncertified	Uncertified	Certified	Certified
KR	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified
CR	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified	Uncertified

Precautions for Compliance with Shipping Standards

Always install the NA Unit in a control panel.

Related Manuals

The following manuals are related to the NA-series PTs. Use these manuals for reference.

Manual name	Cat. No.	Models	Applications	Description
NA-series Program-	V117	NA5-□□W□□□□	Learning the speci-	Information is provided on NA-series
mable Terminal Hard-			fications and set-	PT specifications, part names, instal-
ware User's Manual			tings required to	lation procedures, and procedures to
			install an NA-series	connect an NA Unit to peripheral
			PT and connect	devices.
			peripheral devices.	Information is also provided on main-
				tenance after operation and trouble-
				shooting.
NA-series Program-	V125	NA5-□□W□□□□-V1(-P)	Learning the speci-	Information is provided on NA-series
mable Terminal Hard-			fications and set-	PT specifications, part names, instal-
ware(-V1) User's			tings required to	lation procedures, and procedures to
Manual			install an NA-series	connect an NA Unit to peripheral
			PT and connect peripheral devices.	devices.
			periprieral devices.	Information is also provided on main-
				tenance after operation and trouble-
	11110	NA = ====(NE)		shooting.
NA-series Program-	V118	NA5-□□W□□□□(-V□)	Learning about	NA-series PT pages and object func-
mable Terminal Soft-			NA-series PT pages	tions are described.
ware User's Manual			and object func-	
NA series Dregrem	V119	NA5-□□W□□□□(-V□)	tions.	Information is provided an approprian
NA-series Program- mable Terminal	V119	NAS-LLVVLLLL(-VL)	Learning the speci- fications required	Information is provided on connection procedures and setting procedures to
Device Connection			to connect devices	connect an NA-series PT to a Control-
User's Manual			to an NA-series PT.	ler or other device.
NA-series Program-	V126	NA-RTLD□□	Learning about the	Information is provided on the specifi-
mable Terminal	0		procedure to install	cations of the Soft-NA and differences
Soft-NA User's Man-			the Soft-NA and	from the NA5 series.
ual			differences from	Information is also provided on mainte-
			the NA5 series.	nance after operation and trouble-
				shooting.
NA-series Program-	V120	NA5-□□W□□□□	Learning in con-	The part names and installation proce-
mable Terminal			crete terms infor-	dures are described followed by page
Startup Guide			mation required to	creation and transfer procedures with
			install and start the	the Sysmac Studio. Also operation,
			operation of an	maintenance, and inspection proce-
			NA-series PT.	dures after the project is transferred
				are described. Sample screen cap-
				tures are provided as examples.

Manual name	Cat. No.	Models	Applications	Description
NX-series CPU Unit	W535	NX701-□□□□	Learning the basic	An introduction to the entire NX-series
Hardware User's Manual			specifications of the NX-series CPU	system is provided along with the following information on the CPU Unit.
Manuai			Units, including	-
			introductory infor-	Features and system configurationIntroduction
			mation, designing,	Part names and functions
			installation, and	General specifications
			maintenance. Mainly hardware	Installation and wiring
			information is pro-	Maintenance and inspection
			vided.	Use this manual together with the
				NJ/NX-series CPU Unit Software User's Manual (Cat. No.W501).
NJ-series CPU Unit	W500	NJ501-□□□□	Learning the basic	An introduction to the entire NJ-series
Hardware User's		NJ301-□□□□	specifications of	system is provided along with the fol-
Manual		NJ101-□□□□	the NJ-series CPU	lowing information on a Controller
			Units, including introductory infor-	built with a CPU Unit.
			mation, designing,	Features and system configuration Introduction
			installation, and	Introduction Part names and functions
			maintenance.	General specifications
			Mainly hardware	Installation and wiring
			information is pro- vided.	Inspection and maintenance
			vided.	Use this manual together with the
				NJ-series CPU Unit Software User's
				Manual (Cat. No. W501).
NJ/NX-series CPU	W506	NX701-□□□□	Using the built-in	Information on the built-in EtherNet/IP
Unit Built-in Ether- Net/IP™ Port User's		NX502-□□□□	EtherNet/IP port on an NJ/NX-series	port is provided.
Manual		NX102-□□□□	CPU Unit.	Information is provided on the basic setup, tag data links, and other fea-
		NX1P2-□□□□		tures.
		NJ501-□□□□		
		NJ301-□□□□		
		NJ101-□□□□		
NJ/NX-series CPU	W501	NX701-□□□□	Learning how to	Provides the following information on
Unit Software User's Manual		NX502-□□□□	program and set up an	a Controller built with an NJ/NX-series CPU Unit.
Wallaal		NX102-□□□□	NJ/NX-series CPU	CPU Unit operation
		NX1P2-□□□□	Unit.	CPU Unit features
		NJ501-□□□□	Mainly software	Initial settings
		NJ301-□□□□	information is pro-	Programming based on IEC
		NJ101-□□□□	vided.	61131-3 language specifications
NJ/NX-series Instruc-	W502	NX701-□□□□	Learning detailed	The instructions in the instruction set
tions Reference Man-		NX502-□□□□	specifications on	(IEC 61131-3 specifications) are
ual		NX102-□□□□	the basic instruc- tions of an	described.
		NX1P2-□□□□	NJ/NX-series CPU	
		NJ501-□□□□	Unit.	
		NJ301-□□□□		
		NJ101-□□□□		

Manual name	Cat. No.	Models	Applications	Description
NJ/NX-series Troubleshooting Manual	W503	NX701-□□□□ NX502-□□□□ NX102-□□□□ NX1P2-□□□□ NJ501-□□□□ NJ301-□□□□ NJ101-□□□□	Learning about the errors that may be detected in an NJ/NX-series Con- troller.	Concepts on managing errors that may be detected in an NJ/NX-series Controller and information on individual errors are described.
CJ Series Program- mable Controllers Operation Manual	W393	CJ1H-CPU□□H-R CJ1G/H-CPU□□H CJ1G-CPU□□P CJ1M-CPU□□ CJ1G-CPU□□	Learning the basic specifications of the CJ-series PLCs, including introductory information, designing, installation, and maintenance.	The following information is provided on a CJ-series PLC. Introduction and features System configuration design Installation and wiring I/O memory allocation Troubleshooting Use this manual together with the Programming Manual (Cat. No. W394).
CS/CJ/NSJ Series Programmable Controllers Operation Manual	W394	CS1G/H-CPU H CS1G/H-CPU H CS1G/H-CPU H CS1D-CPU H CS1D-CPU S CJ1H-CPU H-R CJ1G/H-CPU H CJ1G-CPU P CJ1M-CPU C UNSJ C UN	Learning about the functions of the CS/CJ-series and NSJ-series PLCs.	The following information is provided on a CS/CJ-series or NSJ-series PLC. • Programming • Master function • File memory • Other functions Use this manual together with the Operation Manual (CS-series PLCs: W339, CJ-series PLCs: W393).
CS/CJ/NSJ Series Instructions Refer- ence Manual	W340	CS1a-CPU-DD-DD-DD-CJ1a-CPU-DD-DD-DD-DD-DD-DD-DD-DD-DD-DD-DD-DD-DD	Learning detailed information on programming instructions.	Instructions are described in detail. When programming, use this manual together with the <i>Operation Manual</i> (CS-series PLCs: W339, CJ-series PLCs: W393) and the <i>Programming Manual</i> (W394).
CS/CJ Series Programming Consoles Operation Manual	W341	CQM1H-PRO01 CQM1-PRO01 C200H-PRO27 +CS1W-KS001	Learning the operating procedures of the Programming Consoles.	The operating procedures of the Programming Consoles are described. When programming, use this manual together with the <i>Operation Manual</i> (CS-series PLCs: W339, CJ-series PLCs: W393), the <i>Programming Manual</i> (W394), and the <i>Instructions Reference Manual</i> (W340).

Manual name	Cat. No.	Models	Applications	Description
CS/CJ/NSJ Series	W342	CS1G/H-CPU□□H	Learning detailed	1) C-mode commands and 2) FINS
Communications		CS1G/H-CPU□□-V1	specifications on	commands are described in detail.
Commands Refer-		CS1D-CPU□□H	the communica-	Refer to this manual for information
ence Manual		CS1D-CPU□□S	tions instructions addressed to	on communications commands
		CS1W-SCU□□-V1	CS/CJ-series CPU	(C-mode commands and FINS com-
		CS1W-SCB□□-V1	Units and	mands) addressed to CPU Units.
		CJ1G/H-CPU□□H	NSJ-series PLCs.	Note This manual describes com-
				munications commands that
		CJ1G-CPU□□P		are addressed to a CPU Unit.
		CJ1M-CPU□□		The communications path is not relevant. (The communi-
		CJ1G-CPU□□		cations commands can be
		CJ1W-SCU□□-V1		sent through the serial com-
				munications port of the CPU
				Unit, the communications port
				of a Serial Communications
				Board/Unit, or a communica- tions port on another Commu-
				nications Unit.)
CJ-series CJ2 CPU	W472	CJ2H-CPU6□-EIP	Learning the hard-	The following information is provided
Unit Hardware User's		CJ2H-CPU6□	ware specifica-	on a CJ2 CPU Unit.
Manual		CJ2M-CPU□□	tions of CJ2 CPU	Introduction and features
		002 0. 02.2	Units.	Basic system configuration
				Part names and functions
				Installation and setting procedures
				Troubleshooting
				Use this manual together with the Soft-
				ware User's Manual (Cat. No. W473).
CJ-series CJ2 CPU	W473	CJ2H-CPU6□-EIP	Learning the soft-	The following information is provided
Unit Software User's Manual		CJ2H-CPU6□	ware specifica- tions of CJ2 CPU	on a CJ2 CPU Unit.
iviariuai		CJ2M-CPU□□	Units.	CPU Unit operation
				Internal memory
				• Programming
				• Settings
				Functions built into the CPU Unit
				Use this manual together with the
				Hardware User's Manual (Cat. No.
Ethernet Units Oper-	W420	CS1W-ETN21	Learning how to	W472). Information is provided on the Ether-
ation Manual Con-	11120	CJ1W-ETN21	use an Ethernet	net Units.
struction of Networks		00177-211721	Unit.	Information is provided on the basic
				setup and FINS communications.
				Refer to the Communications Com-
				mands Reference Manual (Cat. No.
				W342) for details on FINS commands
				that can be sent to CS/CJ-series CPU
				Units when using the FINS communications service.
Ethernet Units Oper-	W421	CS1W-ETN21	Learning how to	Information is provided on construct-
ation Manual Con-	1 - 1 - 1	CJ1W-ETN21	use an Ethernet	ing host applications, including func-
struction of		33 22.	Unit.	tions for sending/receiving mail,
Applications				socket service, automatic clock
				adjustment, FTP server functions,
				and FINS communications.

Manual name	Cat. No.	Models	Applications	Description
CS/CJ-series Ether-	W465	CJ2H-CPU6□-EIP	Learning how to	Information is provided on the built-in
Net/IP™ Units Oper-		CJ2M-CPU3□	use the built-in Eth-	EtherNet/IP port and EtherNet/IP
ation Manual		CS1W-EIP21	erNet/IP port of the	Units.
		CJ1W-EIP21	CJ2 CPU Units.	Basic settings, tag data links, FINS
				communications, and other functions are described.
Sysmac Studio Ver-	W504	SYSMAC-SE2□□□	Learning about the	The operating procedures of the Sys-
sion 1 Operation	VV30 4	OTOWAC-SEZEEE	operating proce-	mac Studio are described.
Manual			dures and func-	
			tions of the	
			Sysmac Studio.	
CX-Programmer	W446	CXONE-AL□□C-V4	Learning about the	The operating procedures of the
Operation Manual		CXONE-AL□□D-V4	CX-Programmer	CX-Programmer are described.
			except for informa- tion on function	
			blocks, ST pro-	
			gramming, and	
			SFC programming.	
NY-Series Industrial	W553	NYB 1 1	Learning the basic	An introduction to the entire NY-series
Box PC User's Man-			specifications of	system is provided along with the fol-
ual			the NY-series Industrial Box PCs,	lowing information on the Industrial Box PC.
			including introduc-	Features and system configuration
			tory information,	Introduction
			designing, installa-	Part names and functions
			tion, and mainte-	General specifications
			nance.	· ·
				Installation and wiring
NY-Series Industrial	W555	NYP 1 W	Learning the basic	Maintenance and inspection An introduction to the entire NY-series
Panel PC User's	VV333	C100	specifications of	system is provided along with the fol-
Manual		0.002	the NY-series	lowing information on the Industrial
			Industrial Panel	Panel PC.
			PCs, including	Features and system configuration
			introductory infor-	Introduction
			mation, designing, installation, and	Part names and functions
			maintenance.	General specifications
				Installation and wiring
				Maintenance and inspection
NY-Series IPC	W556	NY512-□□□□	Learning the basic	An introduction to the entire NY-series
Machine Controller			specifications of	system is provided along with the fol-
Industrial Box PC			the NY-series	lowing information on the Industrial
Hardware User's Manual			Industrial Box PCs, including introduc-	Box PC.
Manag			tory information,	Features and system configuration
			designing, installa-	• Introduction
			tion, and mainte-	Part names and functions Caparal applifications
			nance.	General specifications
			Mainly hardware	Installation and wiring
			information is pro-	Maintenance and inspection
			vided.	

Manual name	Cat. No.	Models	Applications	Description
NY-Series IPC Machine Controller Industrial Panel PC Hardware User's Manual	W557	NY532-□□□	Learning the basic specifications of the NY-series Industrial Panel PCs, including introductory information, designing, installation, and maintenance. Mainly hardware information is provided.	An introduction to the entire NY-series system is provided along with the following information on the Industrial Panel PC. • Features and system configuration • Introduction • Part names and functions • General specifications • Installation and wiring • Maintenance and inspection
NY-Series IPC Machine Controller Industrial Panel PC / Industrial Box PC Software User's Manual	W558	NY532-□□□□ NY512-□□□□	Learning how to program and set up the Controller functions of an NY-series Industrial PC.	The following information is provided on the NY-series Controller functions. Controller operation Controller features Controller settings Programming based on IEC 61131-3 language specifications
NY-Series Instruc- tions Reference Man- ual	W560	NY532-□□□□ NY512-□□□□	Learning detailed specifications on the basic instruc- tions of an NY-series Indus- trial PC.	The instructions in the instruction set (IEC 61131-3 specifications) are described.
NY-Series Trouble- shooting Manual	W564	NY532-□□□□ NY512-□□□□	Learning about the errors that may be detected in an NY-series Industrial PC.	Concepts on managing errors that may be detected in an NY-series Controller and information on individual errors are described.
NX-series NX1P2 CPU Unit Hardware User's Manual	W578	NX1P2-□□□	Learning the basic specifications of the NX-series NX1P2 CPU Units, including introductory information, designing, installation, and maintenance. Mainly hardware information is provided.	An introduction to the entire NX1P system is provided along with the following information on the NX1P2 CPU Unit. • Features and system configuration • Introduction • Part names and functions • General specifications • Installation and wiring • Maintenance and inspection

Manual name	Cat. No.	Models	Applications	Description
NX-series NX1P2 CPU Unit Built-in I/O and Option Board User's Manual	W579	NX1P2-□□□	Learning about the details of functions only for an NX-series NX1P2 CPU Unit and an introduction of functions for an NJ/NX-series CPU Unit.	Of the functions for an NX1P2 CPU Unit, the following information is provided. Built-in I/O Serial Option Boards Analog Option Boards An introduction of following functions for an NJ/NX-series CPU Unit is also provided. Motion control functions EtherNet/IP communications functions EtherCAT communications functions
NX-series NX102 CPU Unit Hardware User's Manual	W593	NX102- □□□□	Learning the basic specifications of NX102 CPU Units, including introductory information, design, installation, and maintenance. Mainly hardware information is provided.	An introduction to the entire NX102 system is provided along with the following information on the CPU Unit. • Features and system configuration • Introduction • Part names and functions • General specifications • Installation and wiring • Maintenance and inspection
NX-series Safety Control Unit / Com- munication Control Unit User's Manual	Z395	NX-SL5 □□□ NX-SI□□□□ NX-SO□□□□ NX-CSG□□□	Learning how to use the NX-series Safety Control Units and Commu- nications Control Units.	Describes the hardware, setup methods, and functions of the NX-series Safety Control Units and Communications Control Units.
NX-series Communication Control Unit Built-in Function User's Manual	Z396	NX-CSG□□□	Learning about the built-in functions of an NX-series Com- munications Con- trol Unit.	Describes the software setup methods and communicantions functions of an NX-series Communications Control Unit.
NJ-series Robot Inte- grated CPU Unit User's Manual	O037	NJ501-R□□□	Using the NJ-series Robot Integrated CPU Unit.	Describes the settings and operation of the CPU Unit and programming concepts for OMRON robot control.
CS Series Programmable Controllers Operation Manual	W339	CS1G-CPU□□H CS1H-CPU□□H	Learning the basic specifications of the CS-series PLCs, including introductory information, designing, installation, and maintenance.	The following information is provided on a CS-series PLC. Introduction and features System configuration design Installation and wiring I/O memory allocation Troubleshooting Use this manual together with the Programming Manual (Cat. No. W394).

Manual name	Cat. No.	Models	Applications	Description
CS Series Duplex	W405	CS1D-CPU□□H(A)	Learning the basic	The following information is provided
System Operation		CS1D-CPU□□S(A)	specifications of	on a CS-series Duplex System.
Manual			the CS-series	Introduction and features
			Duplex System,	System configuration design
			including introduc-	Installation and wiring
			tory information,	I/O memory allocation
			designing, installa- tion, and mainte-	Troubleshooting
			nance.	Use this manual together with the
			Tidilioo.	Programming Manual (Cat. No.
				W394).
CP Series CP1H	W450		Learning the basic	Provide the following information on
CPU Unit Operation			specifications of	the CP Series:
Manual			the CP1H CPU	Overview, design, installation,
			Unit, including	maintenance, and other basic spec-
			introductory infor-	ifications
			mation, designing,	Features
			installation, and	System configuration
OD 0 OD41	14/400		maintenance.	Mounting and wiring
CP Series CP1L CPU Unit Operation	W462	CP1L-L□□□□-□	Learning the basic specifications of	I/O memory allocation
Manual		CP1L-M□□□□-□	the CP1L CPU	Troubleshooting
Mariaai			Unit, including	
			introductory infor-	Use this manual together with the CP1H Programmable Controllers Pro-
			mation, designing,	gramming Manual (W451).
			installation, and	gramming Mandar (VV 101).
			maintenance.	
CP Series	W516	CP1L-E□□□□-□	Learning the basic	Provides the following information on
CP1L-EL/EM CPU			specifications of	the CP Series:
Unit Operation Man- ual			theCP1L-EL/EM CPU Unit, includ-	Overview, design, installation,
uai			ing introductory	maintenance, and other basic spec-
			information,	ifications
			designing, installa-	• Features
			tion, and mainte-	System configuration
			nance.	Mounting and wiring
				I/O memory allocation
				Troubleshooting
				Use this manual together with the
				CP1L Programmable Controllers Pro-
				gramming Manual (W451).
CP Series CP1H and	W451	CP1H-□□□□□-□	Learning about the	Provides the following information on
CP1L CPU Unit Pro-		CP1L-□□□□□-□	functions of the CP Series CP1H CPU	the CP Series:
gramming Manual			Units.	Programming instructions
			Office.	Programming methods
				Tasks
				File memory
				Functions
				Use this manual together with the CP
				Series CP1H CPU Units Operation
				Manual (W450) and CP Series CP1L
-				CPU Units Operation Manual (W462).

Manual name	Cat. No.	Models	Applications	Description
CP Series CP2E CPU Unit Hardware User's Manual	W613	CP2E-□□□□□-□	To learn the hard- ware specifica- tions of the CP Series CP2E CPU Unit.	Describes the following information for CP2E PLCs. Overview and features Basic system configuration Part names and functions Installation and settings Troubleshooting Use this manual together with the CP2E CPU Unit Software User's Manual (Cat. No. W614) and Instructions Reference Manual (Cat. No.W483).
CP Series CP2E CPU Unit Software User's Manual	W614	CP2E-□□□□□-□	To learn the soft- ware specifica- tions of the CP Series CP2E CPU Unit.	Describes the following information for CP2E PLCs. CPU Unit operation Internal memory Programming Settings CPU Unit built-in functions Interrupts High-speed counter inputs Pulse outputs Serial communications Ethernet Other functions Use this manual together with the CP2E CPU Unit Hardware User's Manual (Cat. No. W613) and Instructions Reference Manual (Cat. No.W483).
CP Series CP1E/CP2E CPU Unit Instructions Ref- erence Manual	W483	CP2E-□□□□□-□	To learn programming instructions in detail.	Describes each programming instruction indetail. When programming, use this manual together with the CP2E CPU Unit Software User's Manual (Cat. No. W614).
CS/CJ Series Serial Communications Boards/Units Opera- tion Manual	W336	CS1W-SCB□1-V1 CS1W-SCU□1-V1 CJ1W-SCU□1-V1 CJ1W-SCU□2	To learn the specifications of the hardware and serial communication mode of a serial communication board/unit.	Describes the use of Serial Communications Unit and Boards to perform serial communications with external devices, including the use of standard system protocols for OMRON products. Note Refer to the CS/CJ Series Communications Commands Reference Manual (W342) for details on sending commands in host link mode from a Serial Communications Board or Unit's port.


Manual name	Cat. No.	Models	Applications	Description
NX-series NX502 CPU Unit Hardware User's Manual	W629	NX502- □□□□	Learning the basic specifications of NX502 CPU Units, including introductory information, design, installation, and maintenance. Mainly hardware information is provided.	An introduction to the entire NX502 system is provided along with the following information on the CPU Unit. • Features and system configuration • Introduction • Part names and functions • General specifications • Installation and wiring • Maintenance and inspection

Terminology

Term	Description				
HMI	A general term for interface devices that indicates both hardware and software elements. In				
	this manual, "HMI" refers to an OMRON Sysmac-brand product unless otherwise specified.				
PT	The hardware elements of the HMI.				
NA Series	The NA Series of Programmable Terminals and peripheral devices.				
NA5 Series	NA5-□□W□□□□ (-V□).				
HMI Project	A Sysmac Studio project for an HMI.				
NA Unit	An NA-series Programmable Terminal.				
Download	Transferring data from the Sysmac Studio to an HMI.				
Upload	Transferring the project from an HMI to the Sysmac Studio.				
IAG collection	When you provide IAGs, you provide them as IAG collections. IAGs are also imported as				
	IAG collections. An IAG collection contains one or more IAGs.				

Revision History

A manual revision code appears as a suffix to the catalog number on the front and back covers of the manual.



Revision code	Date	Revised content
01	April 2020	Original production
02	April 2021	Made revisions accompanying version upgrade.
03	July 2022	Made revisions accompanying support for secure communication with
		the NJ/NX series.
04	October 2022	Revisions for adding safety precautions regarding security.
05	April 2023	Made revisions accompanying support of serial connection with the
		CS/CJ/CP series, and support of connection with the NX502 series.
06	July 2025	Revisions accompanying changes in the Controller function
07	January 2026	Made revisions accompanying model additions.



Introduction to the NA-series Programmable Terminals

This section describes the features, basic system configuration, specifications, and overall operating procedure of the NA-series Programmable Terminals.

1-1		ries Programmable Terminals	
	1-1-1	Features	. 1-2
1-2	Syste	m Configurations	1-4
	1-2-1	Connecting to the Support Software	. 1-4
	1-2-2	Network Configuration with Other Devices	. 1-4
1-3	Availa	ble Products	1-6
	1-3-1	NA Units	. 1-6
	1-3-2	Support Software	. 1-7
	1-3-3	Other Optional Products	. 1-7
1-4	Specif	fications	1-9
	1-4-1	General Specifications	. 1-9
	1-4-2	Performance Specifications	1-12


NA-series Programmable Terminals

The NA-series Programmable Terminals represent the next generation of HMIs for industrial applications. They display information on FA manufacturing sites and function as control interfaces while providing safety, reliability, and maintainability. They provide all of the functions of traditional programmable terminals with a clearer, easy-to-use interface.

OMRON offers the new Sysmac Series of control devices designed with unified communications specifications and user interface specifications.

The NA-series Programmable Terminals are Sysmac devices that you can use together with the NJ/NX/NY-series Machine Automation Controllers and the Sysmac Studio Automation Software to achieve optimum functionality and ease of operation.

If you connect an NA-series Programmable Terminal to an NJ/NX/NY-series Controller, all you have to do to specify memory in the Controller is to specify the Controller variables for the objects on the Programmable Terminal screens. This allows you to create screens without being concerned with the memory map of the Controller.



1-1-1 **Features**

Hardware Features

High-resolution Display Panels

High-resolution display panels are used to more clearly display large amounts of information than was possible with previous OMRON products.

Two Ethernet Ports (Standard Feature)

You can use both Ethernet ports to separate the segment attached to control devices from the segment attached to maintenance devices. Access is possible from both segments at the same time.

You can connect the following devices.

- NJ/NX/NY-series Controllers
- PLCs
- Computers
- · Sysmac Studio

Standard-feature SD Memory Card Slot

You can use an SD Memory Card inserted in the NA Unit to transfer the project you created on the Sysmac Studio to the NA Unit, to update the system program in the NA Unit, or to save the log data from the NA Unit.

Software Features

Specifications with Variables for Superior Reusability

If you connect to an NJ/NX/NY-series Controller, all you have to do to specify memory in the Controller is to specify the Controller variables. This allows you to create objects that are not dependent on specific devices or memory maps. This in turn makes the objects much more reusable than they were with previous PTs.

Program with Visual Basic

You can use Microsoft's Visual Basic to program advanced functions that you cannot achieve with standard objects.

A Wealth of Security Features

The many security features of the NA-series PTs include operation authority settings, execution restrictions with IDs and secure communication with the controller.

Use the Integrated Development Environment of Sysmac Studio Automation Software

You use the Sysmac Studio to create applications for the NA-series Programmable Terminals.

The Sysmac Studio provides an integrated development environment that covers not only the NA-series Programmable Terminal, but also the Controller and devices on EtherCAT as well.

You can use consistent procedures for all devices regardless of differences in the devices. The Sysmac Studio supports all phases of Controller application, from page creation and sequence design through debugging, simulations, commissioning, and changes during operation.

• A Wealth of Simulation Features


You can perform simulations using a virtual HMI on the Sysmac Studio. And you can also perform online debugging with a virtual NJ/NX/NY-series Controller.


1-2 **System Configurations**

The section describes the system configurations of an NA-series PT.

1-2-1 **Connecting to the Support Software**

You can connect the Sysmac Studio to a USB port on the NA Unit with a commercially available USB cable. You can also connect it through an Ethernet cable that is connected to Ethernet port 2 on the NA Unit. Refer to the NA-series Programmable Terminal Software User's Manual (V118) for details on the connection configuration with the Sysmac Studio.







1-2-2 **Network Configuration with Other Devices**

With an NA-series PT, you use Ethernet or serial to connect to connected devices.

When connecting using Ethernet, you can connect an NJ/NX/NY-series Controller, PLC, or other device to Ethernet port 1 on the NA Unit with an Ethernet cable.



When connecting using serial, you can connect a CS/CJ/CP-series PLC to the serial port on the NA Unit with an RS-232C/422A cable.



Available Products

This section provides tables of the NA Units and optional products. Refer to 1-4 Specifications on page 1-9 for detailed specifications.

1-3-1 **NA Units**

Model			Display	Data	Power con-	Weight
	Appearance	Color	panel	capacity	sumption	Weight
NA5-15W□□□□-V1		Silver	15.4 inches			3.2 kg max.
		Black			29 W max.	o.z kg max.
NA5-15W□□□□-V1-P		Silver				2.8 kg max.
	000	Black				2.0 kg max.
NA5-12W□□□□-V1		Silver	12.1 inches			2.4 kg max.
		Black			25 W max.	2.4 kg max.
NA5-12W□□□□-V1-P		Silver		256 MB	25 W Max.	4.01
		Black				1.9 kg max.
NA5-9W□□□-V1		Silver	9.0 inches			1.8 kg max.
NA5-9W□□□□-V1-P		Black Silver	-		23 W max.	
NA5-9WUUUU-VI-P		Black				1.4 kg max.
NA5-7W□□□□-V1		Silver	7.0 inches			
1VAV-/ VV		Black	7.0 11101165		40.14	1.4 kg max.
NA5-7W□□□-V1-P		Silver			19 W max.	1.1 kg max.
		Black				i.i ky iliax.

1-3-2 Support Software

You use the Sysmac Studio to create applications for NA-series PTs and to debug them.

Name	Model	Specifications
Sysmac Studio	SYSMAC-SE□□□	This software is used to create and debug applications for NA-series
Standard Edition		PTs.
		You can also use the Sysmac Studio to perform programming and simulations for NJ/NX/NY-series Controllers because it provides an integrated development environment for all Sysmac devices.

1-3-3 Other Optional Products

SD Memory Cards

Model	Appearance	Capacity
HMC-SD292	omron A f HNC-S0291	2 GB
HMC-SD492		4 GB
HMC-SD1A2	2 GB	16 GB

USB Memory Devices

Model	Appearance	Capacity
FZ-MEM2G		2 GB
FZ-MEM16G		16 GB

Other Products

Name	Model	Appearance	Specifications
Battery Set	CJ1W-BAT01		This is the battery for backup. This Battery is provided as an accessory. It is used to back up the clock information in the NA Unit.
Cable for USB port (to connect the Sysmac Studio)	Commercially available USB cable		USB 2.0 (or 1.1) cable (A connector - B connector), 5.0 m max.
Anti-reflection Sheets	NA-15WKBA04 NA-12WKBA04 NA-9WKBA04 NA-7WKBA04		Attach a Sheet to the screen to suppress the diffused reflections and protect against damage and dirt. (For NA5-\(\subseteq \subseteq \subseteq \subseteq (-V1))
	NA-15WKBA04-V2 NA-12WKBA04-V2 NA-9WKBA04-V2 NA-7WKBA04-V2		Attach a Sheet to the screen to suppress the diffused reflections and protect against damage and dirt. (For NA5-□□W□□□□-V1-P)
High-pressure Waterproof Attachment (PWA)	NA-15WATW01 NA-12WATW01 NA-9WATW01 NA-7WATW01		This metal frame is for high-pressure waterproofing. Install it to conform to UL Type 4X standards.

1-4 Specifications


This section gives the hardware specifications of the NA-series PTs.

1-4-1 General Specifications


		Specification						
	NA5-15W	NA5-15W	NA5-12W	NA5-12W	NA5-9W	NA5-9W	NA5-7W	NA5-7W
Item								
	V1	V1-P	V1	V1-P	V1	V1-P	V1	V1-P
Rated supply	24 VDC							
voltage								
Allowable power	19.2 to 28.	8 VDC (24 \	VDC ±20%)					
supply voltage								
range		Operation for momentary power interruption is not specified.						
Allowable	Operation	for momenta	ary power in	terruption is	not specifie	ed.		
momentary								
power interrup-								
tion time	20 14/		05 W ====		22 14/		10 10/ 100	
Power con- sumption	29 W max.		25 W max.		23 W max.		19 W max	•
Ambient operat-	aa.a*	1*2						
ing temperature	0 to 50°C*´	1 2						
Ambient stor-	20 to 600	00 / 0000*3						
age temperature	-20 to 60°	-20 to 60°C ^{*3}						
Ambient operat-	10 to 90%	10 to 90% ^{*2}						
ing humidity								
		Must be no condensation. Must be free from corrosive gases.						
Atmosphere Pollution degree		EC61010-2-		•				
Noise immunity		wer supply		me to IEC 6	1000-4-4)			
11013C IIIIIIIIIIIII		to IEC 6006	•	1113 to 120 0	1000 4 4.)			
Vibration resis-							2	
tance (during			•				² for 100 mir	
operation)			s (Time coet	ticient of 10	minutes × 0	coemicient ta	ector of 10 =	total time
Shock resis-		of 100 min.) Conforms to IEC 60028-2-27.						
tance (during								
operation)	147 m/s ² 3	times each	in X, Y, and	I Z direction	S			
эрэхэнэг	420×291	414×287	340×244	333×240	290×190	283×185	236×165	220×160
D	× 69 mm	× 69 mm	× 69 mm	× 69 mm	× 69 mm	× 69 mm	× 69 mm	× 69 mm
Dimensions	$(W \times H \times$	$(W \times H \times$	$(W \times H \times$	$(W \times H \times$	$(W \times H \times$	$(W \times H \times$	$(W \times H \times$	$(W \times H \times$
	D)	D)	D)	D)	D)	D)	D)	D)
	$392_{0}^{+1} \times 268_{0}^{+1} \text{ mm}$ $310_{0}^{+1} \times 221_{0}^{+1} \text{ mm}$ $261_{0}^{+1} \times 166_{0}^{+1} \text{ mm}$ $197_{0}^{+0.5} \times 141_{0}^{+0.5} \text{ mm}$					141 ^{+0.5} mm		
Panel cutout								
dimensions	l `	,		,	(horizontal × vertical)		`	,
	Panel thick		Panel thick		Panel thick		Panel thick	
	1.6 to 6.0 r		1.6 to 6.0 r		1.6 to 6.0 i		1.6 to 6.0 i	
Weight	3.2 kg	2.8 kg	2.4 kg	1.9 kg	1.8 kg	1.4 kg	1.4 kg	1.1 kg
	max.	max.	max.	max.	max.	max.	max.	max.
Degree of pro-	· ·	oof type, UL	• •		,			
tection			t in a panel,	contact you	r OMRON r	epresentativ	ve for replac	ement of
	the rubber packing.							

		Specification							
Item	NA5-15W	NA5-15W	NA5-12W	NA5-12W		NA5-9W	NA5-7W	NA5-7W	
			0000-	0000-	0000-	0000-	0000-	0000-	
	V1	V1-P	V1	V1-P	V1	V1-P	V1	V1-P	
	Battery life	: 5 years at	25°C						
Battery life			•	ays after the	•		RTC will be	backed up	
	by a super capacitor for 5 minutes after removing the old battery. (This assumes that the power is first turned ON for at least 5 minutes and then turned OFF.)								
RTC	Ambient te	Ambient temperature 25°C: Maximum error of ±90 seconds per month							
	EU								
	UKCA	UKCA							
International	Shipbuilding standards ^{*7} NK, LR, DNV, BV and ABS IP65 oil-proof, UL Type4X ^{*4} (Front-panel controls)								
standards*5 *6									
cULus			:ULus						
	KC								
RCM									


- *1. The ambient operating temperature is subject to the following restrictions, depending on the mounting angle.
 - The ambient operating temperature is 0 to 40°C when the mounting angle is 0° or more and less than 45° to the horizontal.
 - The ambient operating temperature is 0 to 50°C when the mounting angle is 45° or more and 90° or less to the horizontal.
 - The ambient operating temperature is 0 to 50°C when the mounting angle is 90° or more and 135° or less to the horizontal.



*2. Use the PT within the following temperature and humidity ranges.



*3. Store the PT within the following temperature and humidity ranges.



- *4. To conform to UL Type 4X standards, you may have to use the NA-□WATW01 High-pressure Waterproof Attachment (sold separately). When the NA-□WATW01 High-pressure Waterproof Attachment is used, the panel thickness is between 1.6 to 4.5 mm. Refer to 3-3 Installing NA Units on page 3-4 for details.
- *5. Check with your OMRON representative or refer to the following OMRON website for the latest information on the applicable standards for each model: **www.ia.omron.com**.
- *6. Use power supply Class 2 to conform to UL Standards.
- *7. NA5-\Bullet W \Bullet \Bullet -V1-P is not supported.

Performance Specifications 1-4-2

Display

		Specification	pecification						
Item		NA5-15W□□□□	NA5-12W□□□□	NA5-9W□□□□	NA5-7W□□□□				
		-V1(-P)	-V1(-P)	-V1(-P)	-V1(-P)				
Display	Display	TFT LCD			_				
panel ^{*1}	device								
•	Screen size	15.4 inches	12.1 inches	9.0 inches	7.0 inches				
	Resolution	1,280 × 800 dots (ho	rizontal × vertical)	800 × 480 dots (hori	80 dots (horizontal × vertical)				
	Colors	16,770,000 colors							
	Effective	331×207 mm (hor-	261×163 mm (hor-	197 × 118 mm (hor-	152 × 91 mm (hori-				
	display area	$izontal \times vertical)$	$izontal \times vertical)$	izontal × vertical)	zontal × vertical)				
	View angles	Left: 60°, Right: 60°,	Top: 60°, Bottom: 60°	0					
Backlight	Life	50,000 hours min.*3							
*2	Brightness	200 levels							
	adjustment								
Front panel	RUN	Lit green: Normal operation							
indicators*4		Lit red: Error							

^{*1.} There may be some defective pixels in the display. This is not a fault as long as the numbers of defective light and dark pixels fall within the following standard ranges.

Model	Standard range
NA5-15W□□□□-V1(-P)	Number of light and dark pixels: 10 or less. (There
NA5-12W□□□□-V1(-P)	must not be 3 consecutive light/dark pixels.)
NA5-9W□□□□-V1(-P)	
NA5-7W□□□□-V1(-P)	

^{*2.} The backlight can be replaced at an OMRON maintenance base. The backlight is LED type.

Operation

	Specification			
Item	NA5-15W□□□□	NA5-12W□□□□	NA5-9W□□□□	NA5-7W□□□□
	-V1(-P)	-V1(-P)	-V1(-P)	-V1(-P)
Touch panel	Method: Analog resistance membrane (pressure sensitive)			
	Resolution: 16,384 × 16,384			
	Life: 1,000,000 operations			
Function keys*1	3 inputs (capacitance inputs)			

^{*1.} Each function key has blue indicator. The brightness of the function key indicators is also adjustable when you adjust the brightness of the backlight.

^{*3.} This is the estimated time before brightness is reduced by half at room temperature and humidity. The life expectancy is drastically shortened if PT is used at high temperatures.

^{*4.} The brightness of the front panel indicators is also adjustable when you adjust the brightness of the backlight.

Data Capacity

	Specification			
Item	NA5-15W□□□□	NA5-12W□□□□	NA5-9W□□□□	NA5-7W□□□□
	-V1(-P)	-V1(-P)	-V1(-P)	-V1(-P)
User data capacity	256 MB			

External Interfaces

Item		Specifications (Same for all models.)	
Ethernet ports	Applications	Port 1: Connecting to anything other than the Sysmac Studio,	
		e.g., device connections and VNC clients	
		Port 2: Connecting to the Sysmac Studio in addition to the	
		applications of port 1.	
	Number of ports	2 ports	
	Compliant standards	IEEE 802.3i (10BASE-T), IEEE 802.3u (100BASE-TX), and IEEE 802.3ab (1000Base-T)	
	Transmission media	Shielded twisted-pair (STP) cable: Category 5, 5e, or higher	
	Transmission dis-	100 m	
	tance		
	Connector	RJ-45 8P8C modular connector	
USB host ports *1 *2	Applications	USB Memory Device, keyboard, or mouse	
	Number of ports	2 ports	
	Compliant standards	USB 2.0	
	Transmission dis-	5 m max.	
	tance		
	Connector	Type-A connector	
USB slave port *2	Applications	Sysmac Studio connection	
·	Number of ports	1 port	
	Compliant standards	USB 2.0	
	Transmission dis-	5 m max.	
	tance		
	Connector	Type-B connector	
Serial port	Applications	Device Connection	
	Number of ports	1 port	
	Compliant standards	RS-232C	
	Transmission dis-	15 m max.	
	tance		
	Connector	D-SUB 9-pin female connector	
SD Memory Card slot	Applications	To transfer or store the project or to store log data.	
	Number of slots	1 slot	
	Compliant standards	SD/SDHC	

^{*1.} Use a USB memory for temporary applications such as transferring data.

^{*2.} The connection to all USB 2.0-compliant devices is not guaranteed.

- 1	introduction to the NA-series Programmable Terminals	
	<u></u>	



Configuration Units

This section describes the basic system configuration and devices used for NA-series Programmable Terminals.


2-1	NA Un	its 2-2
	2-1-1	Components and Functions
2-2	SD Me	mory Cards 2-10
	2-2-1	Models and Specifications 2-10
	2-2-2	Applications
	2-2-3	Installing and Removing
2-3	USB N	lemory Devices 2-12
	2-3-1	Models and Specifications 2-12
	2-3-2	Applications
	2-3-3	Installing and Removing
2-4	Suppo	rt Software
	2-4-1	Connection Methods

NA Units 2-1

This section describes the names and functions of NA Unit parts and installation methods and provides other information.

2-1-1 **Components and Functions**


Front Panel



No.	Name	Description	
①	Display	The entire display is a touch panel that also functions as an input device.	
2	RUN indicator	The status of the indicator changes according to the status of the NA Unit.	
3	Function keys	There are three function keys: F1, F2, and F3.	
		: F1 Key, : F2 Key, : F3 Key	
		You can use the function keys as execution conditions for the actions for global or page events.	
		You can also use the function keys for interlocks.	

Display

You can perform input operations with the touch panel on the front surface of the NA Unit. You can tap buttons on the touch panel to change the display or to send data to connected devices.





Precautions for Safe Use

- · Do not press the touch panel with a force greater than 30 N.
- The deterioration over time may cause the touch points to move on the touch panel. Calibrate the touch panel periodically.
- A touch position detection error of approximately 20 pixels may occur due to the precision of the touch panel. Always take this into account when positioning objects on the panel so adjoining objects will not be activated by mistake.
- Confirm the safety of the system before pressing the touch panel.
- Do not accidentally press the touch panel when the backlight is not lit or when the display does not appear or is too dark to identify visually.
- Signals from the touch panel may not be entered if the touch panel is pressed consecutively at high speed. Make sure to go on the next operation after confirming that the NA Unit has detected the input of the touch panel.



Precautions for Correct Use

- If you touch the touch panel where there is no object and then slide your finger over to an object, the object will not be activated. To activate an object, remove your finger from the touch panel and then touch the object securely.
- To ensure accurate input operations, use the size of a finger as the basis for the minimum size of objects.

RUN Indicator Status

You can use the status of the RUN indicator to check the status of the NA Unit. Refer to *5-1-1 Checking NA Unit Status* on page 5-2 for details.

Function Keys

You can specify the action to execute when a function key is tapped.


You can specify the following actions: calling a user-defined subroutine, prohibiting touch panel inputs, changing the backlight brightness, displaying a PDF file, etc.

To execute these functions, you assign the function key operations to global events or object events and then specify the corresponding actions.


Refer to the NA-series Programmable Terminal Software User's Manual (Cat. No. V118) for details.


Back Panel

Back Panel



Bottom Panel





No.	Name	Description
(a)	Battery cover	Open this cover to replace the Battery.
(b)	ID information label	You can check the ID information of the NA Unit.
(c)	SD Memory Card connector	Insert an SD Memory Card here.
(d)	Protective ground terminal*1	Use for protective grounding.
(e)	Ethernet port 1	Connect a device other than the Sysmac Studio.
	Ethernet port 2	Connect mainly the Sysmac Studio.
(f)	Serial port	Connect the connected device.
(g)	USB host port	Connect this port to a USB Memory Device, keyboard, mouse, etc.
(h)	USB slave port	Connect the Sysmac Studio or other devices.
(i)	Reset switch	Use this switch to reset the NA Unit.
(j)	DC input terminals	These are the power supply terminals. Connect the accessory power
		supply connector and supply power.
(k)	Battery connector	Connect the connector on the backup Battery here.
(1)	DIP switch	Used for system recovery. (The DIP switch is on a PCB that is accessed
		by opening the Battery cover.) In other cases, do not change any of the
		factory settings of the pins on the DIP switch.
(m)	Battery	This is the battery to backup the clock information in the NA Unit.

^{*1.} The NA5-\(\subseteq\) \(\subseteq\) \(\subseteq\) \(\subseteq\) \(\subseteq\) also has a terminal in the same location, but it does not have a protective grounding function.



Precautions for Safe Use


Confirm the safety of the system before turning ON or OFF the power supply, or pressing the reset switch.

Battery

The following Battery is provided as a standard feature.

Model	Appearance	Specifications
CJ1W-BAT01		Effective life (i.e., maximum life expectancy): 5 years The following data is retained during power interruptions. • Time data


Power Supply Connector Pin Arrangement



Pin No.	Signal name	Name
1	+24 V	+24-V input
2	0 V	0 V
3	FG	Functional ground

Protective Ground Terminal


A terminal for protective grounding to prevent electrical shock. The NA5-\(\subseteq \subseteq \subseteq \subseteq \subseteq \) has a terminal but does not require protective grounding, and it does not have a protective grounding func-



Pin No.	Signal name	Name
1	PE	Protective ground


Reset Switch

Use a precision screwdriver or similar device with a diameter of less than 2.4 mm. The reset switch performs the same function as cycling the power supply.



Ethernet Ports

• Port Pin Arrangement and Indicator Locations




• Connecting Devices That Support IEEE 802.3i (10BASE-T) or IEEE 802.3u (100BASE-TX)

Pin No.	Signal name	Name
1	TD+	Twisted-pair output (differential output)
2	TD-	Twisted-pair output (differential output)
3	RD+	Twisted-pair input (differential input)
4	BI D+	Protection circuit
5	BI D-	Protection circuit
6	RD-	Twisted-pair input (differential input)
7	BI D+	Protection circuit
8	BI D-	Protection circuit

• Connecting Devices That Support IEEE 802.3ab (1000Base-T)

Pin No.	Signal name	Name
1	TRD0+	Send/receive data 0+
2	TRD0-	Send/receive data 0-
3	TRD1+	Send/receive data 1+
4	TRD2+	Send/receive data 2+
5	TRD2-	Send/receive data 2-
6	TRD1-	Send/receive data 1-
7	TRD3+	Send/receive data 3+
8	TRD3-	Send/receive data 3-


If you use a cable with a hood or boot, make sure that the mating length is at least 15 mm, as shown in the following figure.



· Ethernet Port Indicators

Indicator	Color	Status	Description		
LINK		Not lit.	A link was not established.		
			The cable is not connected.		
			The power supply is OFF or the NA Unit was reset.		
	Green	Lit.	The link was established.		
ACT		Not lit.	The link is on standby.		
	Orange	Flashing.	Data is being sent or received.		

• Serial Port Pin Arrangement




Pin No.	Signal abbreviation	Signal name	
1	NC	Unused	
2 SD Send Da		Send Data	
3	RD	Receive Data	
4	RS	Request to Send	
5 CS Clear to S		ar to Send	
6	+5 V	Power Supply (+5 V ±5%, maximum current 250 mA)	
7	NC	Unused	
8	NC	Unused	
9	SG	Signal Ground	
Connector Hood	FG	Protective Ground	

• ID Information Label

You can check the ID information of the NA Unit with the ID information label on the back of the NA Unit.

An example is shown below. The label varies with the model and applicable standards.



No.	Name	Description	
(a)	Model	Gives the model of the NA Unit.	
(b)	Standards	Gives the standards for which the NA Unit is certified.	
(c)	MAC addresses	Give the MAC addresses of the Ethernet ports.	
(d)	Lot number	Gives the lot number of the NA Unit.	
		DDMYY□: Lot number, □: For use by OMRON	
		M is 1 to 9 for January to September, X for October, Y for November, and Z for December.	

SD Memory Cards 2-2

This section describes how to use an SD Memory Card to transfer the project or save log data.

2-2-1 **Models and Specifications**

SD and SDHC memory cards are supported, but use the OMRON-specified SD Memory Cards. (Refer to 1-3-3 Other Optional Products on page 1-7.) OMRON is not responsible for the operation, performance, or write life of any other memory card.



Additional Information

Write Protection Key

You will not be able to write to the SD Memory Card if the key is set to the LOCK position. (Use this setting to prevent overwriting.)



2-2-2 **Applications**

You can use the SD Memory Card for the following applications.

- Transferring the project data created on the Sysmac Studio to an HMI
- · Updating the HMI system program
- Recording log data (data log, user alarms, etc.)

2-2-3 Installing and Removing

This section describes the methods to install and remove an SD Memory Card.

Refer to the NA-series Programmable Terminal Software User's Manual (Cat. No. V118) for information on executing actions and information on system-defined variables.

Before Using an SD Memory Card


Observe the following precautions while an SD Memory Card is inserted.

- Before you remove the SD Memory Card, execute the EjectSDMemory action and check the _HMI_CanEjectSDCard system-defined variable to make sure that the power supply to the SD Memory Card is stopped.
- Before you turn OFF the HMI power supply, execute the EjectSDMemory action and check the HMI CanEjectSDCard system-defined variable to make sure that the power supply to the SD Memory Card is stopped.
- Never insert the SD Memory Card facing the wrong way. If the SD Memory Card is inserted forcibly, it may become unusable.


- To format the SD Memory Card (e.g., to delete all of the data), use the SD Formatter for SD/SDHC/SDXC provided by the SD Association.
 SD Association: https://www.sdcard.org/
- The SD Memory Card uses flash memory, and so its service life is limited. When the end of the SD Memory Card's service life approaches, the ability to write data is lost, and data is sometimes not retained after writing. The service life depends on the size of the data that is written and on the ambient temperature. For the unlikely event that data is lost, it is recommended to periodically back up data.

Installing the SD Memory Card

1 Insert the SD Memory Card into the slot on the back of the NA Unit with the label facing upward when viewed from the back of the NA Unit.




2 Push the SD Memory Card securely into the compartment.



Removing the SD Memory Card

- **1** Execute the EjectSDMemory action.
- 2 Use the _HMI_CanEjectSDCard system-defined variable to confirm that the power supply to the SD Memory Card is stopped, and then remove the SD Memory Card.



The SD Memory Card will be ejected from the compartment.

3 Pull out the SD Memory Card.

USB Memory Devices 2-3

This section describes how to use a USB Memory Device to transfer the project or save log data.

2-3-1 **Models and Specifications**

USB Memory Devices that comply with the USB 2.0 standard are supported, but use one of the USB Memory Devices specified by OMRON. (Refer to 1-3-3 Other Optional Products on page 1-7.) OMRON is not responsible for the operation, performance, or write life of any other USB Memory Device.

2-3-2 **Applications**

You can use the USB Memory Device for the following applications.

- Transferring the project data created on the Sysmac Studio to the HMI
- · Updating the HMI system program

2-3-3 Installing and Removing

This section describes methods to install and remove an USB Memory.

Refer to the NA-series Programmable Terminal Software User's Manual (Cat. No. V118) for information on subroutines.



Precautions for Correct Use

You can connect only one USB memory device at the same time.


Before Using a USB Memory Device

Observe the following precautions while the USB Memory Device is being accessed.

- Use a USB memory device for temporary purposes such as data transfer.
- Before you remove the USB Memory Device, execute EjectUSBDevice in a subroutine.
- Before you turn OFF the power supply to the HMI, execute EjectUSBDevice in a subroutine.
- · Never insert the USB Memory Device facing the wrong way. If the USB Memory Device is inserted forcibly, it may become unusable.
- To format a USB Memory Device (e.g., to delete all of the data), use a Windows formatting utility and format to FAT32.
- · The USB Memory Devices use flash memory, and so their service life is limited. When the end of the USB Memory Device's service life approaches, the ability to write data is lost, and data is sometimes not retained after writing. The service life depends on the size of the data that is written and on the ambient temperature. For the unlikely event that data is lost, it is recommended to periodically back up data.

Installing the USB Memory Device


1 Insert the USB Memory Devices into the USB host port on the back of the NA Unit.



2 Push the USB Memory Device all of the way in.

Removing the USB Memory Device

1 Execute EjectUSBDevice in a subroutine and then remove the USB Memory Device.



Support Software


This Sysmac Studio is used to create, debug, and maintain applications for NA-series Programmable Terminals.

2-4-1 **Connection Methods**

With an NA-series Programmable Terminal, you can connect the Sysmac Studio online in the following ways.

Connecting with USB


Use a commercially available USB cable for a USB connection.



You do not need to specify the connected device on the Sysmac Studio.

Connecting with Ethernet

You can use a direct connection or connect through an Ethernet switch by connecting to Ethernet port 2 on the NA Unit.



- · Connect the Sysmac Studio to Ethernet port 2.
- The IP address and connection device do not need to be specified at the Sysmac Studio. Select the
 Direct Connection with Sysmac Studio Check Box under HMI Settings TCP/IP Settings and then
 connect to Ethernet port 2.
- You can make the connection either with or without a switching hub.
- The Ethernet port on the NA Unit supports Auto-MDI, so you can use either a cross cable or a straight cable if you connect directly to the computer.

Refer to the *NA-series Programmable Terminal Device Connection User's Manual* (Cat. No. V119) for information on recommended Ethernet switches and connection details.



Installation and Wiring

This section describes how to install and wire an NA Unit.

Proce 3-1-1 3-1-2	Power ON Operation	3-2
Fail-s : 3-2-1		
Instal l 3-3-1	_	
Wiring 3-4-1 3-4-2 3-4-3	Power Supply Wiring	. 3-15 . 3-18
3-5-1 3-5-2 3-5-3 3-5-4 3-5-5	Temperature Humidity Vibration and Shock Atmosphere Electrical Environment	. 3-19 . 3-20 . 3-21 . 3-21 . 3-22
	3-1-1 3-1-2 Fail-s 3-2-1 Instal 3-3-1 Wiring 3-4-1 3-4-2 3-4-3 Contr 3-5-1 3-5-2 3-5-3 3-5-4	3-1-2 Power OFF Operation Fail-safe Measures 3-2-1 Power ON Sequence Installing NA Units 3-3-1 Installation in a Control Panel Wiring Methods 3-4-1 Power Supply Wiring 3-4-2 Wiring the Ethernet Port 3-4-3 Wiring the Serial Port Control Panel Installation 3-5-1 Temperature 3-5-2 Humidity 3-5-3 Vibration and Shock 3-5-4 Atmosphere 3-5-5 Electrical Environment

Processing at Power ON and Power

MARNING

Do not attempt to disassemble, repair, or modify the NA Unit. It may cause NA Unit to lose its safety function.



Do not attempt to take the NA Unit apart and do not touch the product inside while the power is being supplied. Otherwise it may result in electric shock.

3-1-1 **Power ON Operation**



Precautions for Safe Use

Confirm the safety of the system before turning ON or OFF the power supply, or pressing the reset switch.

Operation until Operation Ready Status

The NA Unit will enter operation-ready status after the following time elapses once power supply starts.

NA Unit Startup Time at Power ON

It takes approximately 30 seconds for the NA Unit to start up. The startup time is affected by the contents of the project and the presence or absence of an SD Memory Card.

3-1-2 **Power OFF Operation**

WARNING

NA Unit operation may not be dependable for momentary power interruptions. Implement countermeasures for momentary power interruptions at the power supply.



Precautions for Power Interruptions

Observe the following precautions when power is interrupted.

Item	Description		
SD Memory Card access in prog-	Any write data may be lost.		
ress			
Transferring the project or other	The operation is interrupted. As a result, an error will occur the next time that		
data in process	the power is turned ON. Transfer the data again.		

3-2 Fail-safe Measures

M WARNING

Provide safety measures in external circuits to ensure safety in the system if an abnormality occurs due to malfunction of the NA Unit or due to other external factors affecting operation. Not doing so may result in serious accidents due to incorrect operation.



The circuits associated with safety measures, such as emergency stop circuits, interlock circuits, and limit circuits, must be provided in external control circuits.

External safety measures must be provided to ensure the safe operation of the system from when the power supply is turned ON until execution of the project starts.

Unintended operation may occur when an error occurs in memory or other data. As a countermeasure for such problems, external safety measures must be provided to ensure safe operation of the system.

Provide measures in the communications system and in the user program to ensure safety in the overall system even if errors or malfunctions occur.

You must implement fail-safe measures to provide sufficient protection in the event that abnormal signals or problems occur as the result of broken signal lines or momentary power interruptions. Not doing so may result in serious accidents due to incorrect operation.

3-2-1 Power ON Sequence

We recommend the following sequence for turning ON the power supplies.

- (1) Ethernet switches and other network devices
- (2) Connected devices
- (3) NA Unit

If you turn ON the power supply to the connected device after you turn ON the power supply to the NA Unit, an error may occur depending on system settings.



Precautions for Safe Use

It takes up to approximately 30 seconds for execution of the HMI project to start after the power is turned ON. External communications are also not performed during this period. Implement fail-safe measures so that connected devices do not operate incorrectly, including measures to check the execution of the HMI project.

Installing NA Units

This section describes how to install an NA Unit.



Precautions for Correct Use

- · Follow the instructions in this manual to correctly perform installation.
- Do not install or store the NA Unit in any of the following locations:
 - · Locations subject to severe changes in temperature
 - · Locations subject to temperatures or humidity outside the range specified in the specifica-
 - Locations subject to condensation as the result of high humidity
 - · Locations subject to corrosive or flammable gases
 - · Locations subject to strong shock or vibration
 - · Locations outdoors subject to direct wind and rain
 - · Locations subject to strong ultraviolet light
 - · Locations subject to dust
 - · Locations subject to direct sunlight
 - · Locations subject to splashing oil or chemicals
- Take appropriate and sufficient countermeasures when installing systems in the following locations:
 - · Locations subject to static electricity or other forms of noise
 - · Locations subject to strong electric field or magnetic field
 - · Locations close to power supply lines
 - · Locations subject to possible exposure to radioactivity
- Mounting Panel
 - The following table shows the mounting panel thickness and the necessity of using a High-pressure Waterproof Attachment (PWA) to conform to standards.

	UL Type	e 1, IP65	UL Type 4X*1	
Model	Panel thick- ness	PWA	Panel thick- ness	PWA
NA5-15W□□□□-V1	1.6 to 6.0 mm	Not necessary	1.6 to 4.5 mm	Necessary*2
NA5-12W□□□□-V1				
NA5-9W□□□□-V1				
NA5-7W□□□□-V1				
NA5-15W□□□□-V1-P			1.6 to 6.0 mm	Not necessary*3
NA5-12W□□□□-V1-P				,
NA5-9W□□□□-V1-P			1.6 to 4.5 mm	Necessary*2
NA5-7W□□□□-V1-P				

^{*1.} Do not use the NA Unit outdoors.

 Tighten the Mounting Brackets evenly to a torque of between 0.5 and 0.6 N·m to maintain water and dust resistance. If the tightening torque exceeds the specified range or the tightening is not even, deformation of the front panel may occur. Make sure the panel is not dirty or warped, that the front surface is smooth, and that the panel is strong enough to hold the NA Unit.

^{*2.} Be sure to use a PWA. If you do not use a PWA, there is a risk of water entry, which may cause severe equipment damage.

^{*3.} Do not use a PWA. If you use a PWA, there is a risk of water entry, which may cause severe equipment damage.


3-3-1 Installation in a Control Panel


The NA Unit is installed by embedding it in a control panel. Panel Mounting Brackets and a Phillips screwdriver are required to mount the NA Unit.

Installation in a Control Panel

The mounting method differs depending on the model and applicable standards. Mount the NA Unit after thoroughly reading the description below.







Panel Mounting Bracket

Phillips screwdriver

High-pressure Waterproof Attachment (PWA)



Precautions for Safe Use

- · Do not let metal particles enter the NA Unit when preparing the panel.
- Tighten the Mounting Brackets evenly to a torque of between 0.5 and 0.6 N·m to maintain water and dust resistance. If the tightening torque exceeds the specified value, or the tightening is not even, deformation of the front panel may occur. What is more, make sure the panel is not dirty or warped and that it is strong enough to hold the NA Unit.
- As the rubber packing will deteriorate, shrink, or harden depending on the operating environment, periodical inspection is necessary.
- When using the NA5-□□W□□□□-V1, to help prevent electrical shock, ground to 100 Ω or less by using dedicated ground wires (with cross-section area of 2 mm² or larger) and tighten the terminal screw on the protective ground terminal to a torque of 1.0 to 1.2 N·m.



Precautions for Correct Use

- Completely shield the gap at openings in the control panel or operation panel with a gasket.
- Refer to *Grounding Methods and Precautions* on page 3-25 and wire the functional ground terminal () of the NA-series PT as required.




Additional Information

The NA Units comply with shipbuilding standards. Refer to *Conformance to Shipbuilding Standards* on page 23 for information on applicable shipbuilding standards.

General mounting method (UL Type 1, IP65)

The general mounting method is common across all models and is as described below. It can also conform to UL Type 1 standards or IP65 standards.

Open a hole in which to embed the NA Unit with the following dimensions and insert the NA Unit from the front side of the panel.



Recommended panel thickness: 1.6 to 6.0 mm

Model	Dimensions	
NA5-15W□□□□-V1(-P)	392 ^{+1/-0} × 268 ^{+1/-0} mm (horizontal × vertical)	
NA5-12W□□□□-V1(-P)	310 ^{+1/-0} × 221 ^{+1/-0} mm (horizontal × vertical)	
NA5-9W□□□□-V1(-P)	261 ^{+1/-0} × 166 ^{+1/-0} mm (horizontal × vertical)	
NA5-7W□□□□-V1(-P)	197 ^{+ 0.5/-0} × 141 ^{+0.5/-0} mm (horizontal × vertical)	

The dimensions of the NA Unit are the dimensions of the front panel of the NA Unit. Decide the position of the hole while ensuring that there is no interference with other devices.

Model	Dimensions of the NA Unit	
NA5-15W□□□□-V1	420 × 291 mm	
NA5-12W□□□□-V1	340 × 244 mm	
NA5-9W□□□□-V1	290 × 190 mm	
NA5-7W□□□□-V1	236 × 165 mm	
NA5-15W□□□□-V1-P	414 × 287 mm	
NA5-12W□□□□-V1-P	333 × 240 mm	
NA5-9W□□□□-V1-P	283 × 185 mm	
NA5-7W□□□□-V1-P	220 × 160 mm	

Fully loosen the screws of the mounting brackets as shown in the following figure.




Attach the Panel Mounting Brackets from the back of the panel as shown in the following figure. The number of mounting brackets is as described below, and the required number of Panel Mounting Brackets are included with the NA Unit. Refer to Bracket Mounting Locations for Different Models on page 3-7 for details on the bracket mounting locations.

Model	Number of Panel Mounting Brackets	
NA5-15W□□□□-V1	8 locations	
NA5-12W□□□□-V1	6 locations	
NA5-9W□□□□-V1	4 locations	
NA5-7W□□□□-V1	4 locations	
NA5-15W□□□□-V1-P	10 locations	
NA5-12W□□□□-V1-P	8 locations	

Model	Number of Panel Mounting Brackets	
NA5-9W□□□□-V1-P	8 locations	
NA5-7W□□□□-V1-P	4 locations	

Catch the brackets in the mounting holes in the NA Unit, pull forward lightly, and then use a Phillips screwdriver to tighten the screws and secure the NA Unit to the panel, which will be held between the mounting brackets and the NA Unit.




Bracket Mounting Locations for Different Models

When you mount an NA Unit, secure it with the mounting brackets as shown in the following figures.

For the NA5- $\square\square$ W $\square\square\square$ -V1, the locations where the NA Unit must be secured with mounting brackets are as follows.


• NA5-15W□□□□-V1

Secure the NA Unit with mounting brackets in the eight locations shown below.




• NA5-12W□□□□-V1

Secure the NA Unit with mounting brackets in the six locations shown below.




• NA5-9W□□□□-V1

Secure the NA Unit with mounting brackets in the four locations shown below.



• NA5-7W□□□□-V1

Secure the NA Unit with mounting brackets in the four locations shown below.




For the NA5-\(\subseteq \text{W} \subseteq \subseteq \text{V1-P}, the locations where the NA Unit must be secured with mounting brackets are the marked locations below.




• NA5-15W□□□□-V1-P

Secure the NA Unit with mounting brackets in the ten locations shown below.




• NA5-12W□□□□-V1-P

Secure the NA Unit with mounting brackets in the eight locations shown below.




• NA5-9W□□□□-V1-P

Secure the NA Unit with mounting brackets in the eight locations shown below.



• NA5-7W□□□□-V1-P

Secure the NA Unit with mounting brackets in the four locations shown below.




Conforming to UL Type 4X standards by using a PWA

By using a PWA, all models can conform to UL Type 4X standards. The mounting method is as described below.

To conform to UL Type 4X standards, always use NA5-\(\subseteq \text{W} \subseteq \subseteq \text{V1/NA5-9W} \subseteq \subseteq \text{V1-P/} NA5-7W \underset there is a risk of water entry, which may cause severe equipment damage.

Open a hole in which to embed the NA Unit with the following dimensions and insert the NA Unit from the front side of the panel.




Recommended panel thickness: 1.6 to 4.5 mm

Model	Dimensions of the hole for embedding
NA5-15W□□□□-V1	392 ^{+1/-0} × 268 ^{+1/-0} mm (horizontal × vertical)
NA5-12W□□□□-V1	310 ^{+1/-0} × 221 ^{+1/-0} mm (horizontal × vertical)
NA5-9W□□□□-V1(-P)	261 ^{+1/-0} × 166 ^{+1/-0} mm (horizontal × vertical)
NA5-7W□□□□-V1(-P)	197 ^{+ 0.5/-0} × 141 ^{+0.5/-0} mm (horizontal × vertical)

The dimensions of the NA Unit are the dimensions of the PWA. Decide the position of the hole while ensuring that there is no interference with other devices.

Model	Dimensions of the NA Unit	
NA5-15W□□□□-V1	$430\times306~\text{mm}$	
NA5-12W□□□□-V1	348 × 259 mm	
NA5-9W□□□-V1(-P)	298 × 203 mm	
NA5-7W□□□□-V1(-P)	236 × 178 mm	

Slide the PWA over the NA Unit from the back until the flat side of the PWA is flat against the inside of the panel.



Model	PWA model number	
NA5-15W□□□□-V1	NA-15WATW01	
NA5-12W□□□□-V1	NA-12WATW01	
NA5-9W□□□□-V1(-P)	NA-9WATW01	
NA5-7W□□□□-V1(-P)	NA-7WATW01	

3 Fully loosen the screws of the mounting brackets as shown in the following figure.




4 Attach the Panel Mounting Brackets from the back of the panel as shown in the following figure.

The number of mounting brackets depends on the size of the NA Unit, as shown in the following table. Refer to *Bracket Mounting Locations for Different Models* on page 3-11 described later.

Model	Number of Panel Mounting Brackets
NA5-15W□□□□-V1	8 locations
NA5-12W□□□□-V1	6 locations
NA5-9W□□□□-V1	4 locations
NA5-7W□□□□-V1	4 locations
NA5-9W□□□□-V1-P	8 locations
NA5-7W□□□□-V1-P	4 locations

Catch the brackets in the mounting holes in the NA Unit, pull forward lightly, and then use a Phillips screwdriver to tighten the screws and secure the NA Unit to the panel, which will be held between the mounting brackets and the NA Unit.




Bracket Mounting Locations for Different Models

When you mount an NA Unit, secure it with the mounting brackets as shown in the following figures.

For the NA5- $\square\square$ W $\square\square\square$ -V1, the locations where the NA Unit must be secured with mounting brackets are as follows.


• NA5-15W□□□□-V1

Secure the NA Unit with mounting brackets in the eight locations shown below.




• NA5-12W□□□□-V1

Secure the NA Unit with mounting brackets in the six locations shown below.




• NA5-9W□□□□-V1

Secure the NA Unit with mounting brackets in the four locations shown below.



• NA5-7W□□□□-V1

Secure the NA Unit with mounting brackets in the four locations shown below.




For the NA5-\(\subseteq \text{W} \subseteq \subseteq \text{V1-P}, the locations where the NA Unit must be secured with mounting brackets are the marked locations below.




• NA5-9W□□□□-V1-P

Secure the NA Unit with mounting brackets in the eight locations shown below.



• NA5-7W□□□□-V1-P

Secure the NA Unit with mounting brackets in the four locations shown below.



Conforming to UL Type 4X standards without using a PWA

To make NA5-15W \underset \underset V1-P/NA5-12W \underset \underset V1-P conform to UL Type 4X, mount with additional mounting brackets without using a PWA. The installation procedures are as follows.

The number of mounting brackets is as shown in the following table. Refer to Bracket Mounting Locations for Different Models on page 3-14 for details on the bracket mounting locations.

Model	Number of Panel Mounting Brackets	
NA5-15W□□□□-V1-P	14 locations	
NA5-12W□□□□-V1-P	10 locations	


Bracket Mounting Locations for Different Models

When you mount an NA Unit, secure it with the mounting brackets as shown in the following figures. The locations where the NA Unit must be secured with mounting brackets are the marked locations below.




• NA5-15W□□□□-V1-P

Secure the NA Unit with mounting brackets in the fourteen locations shown below.



• NA5-12W□□□□-V1-P

Secure the NA Unit with mounting brackets in the ten locations shown below.



3-4 Wiring Methods

This section describes how to wire an NA Unit.

M WARNING

Make sure that the voltage and current that are input to the NA Unit are within the specified ranges. Inputting voltages or currents that are outside of the specified ranges may cause accidents or fire.



MARNING MARNING

Be sure that all terminal block screws and cable connector screws are tightened to the torque specified in the relevant manuals. The loose screws may result in fire or malfunction.



Do not touch any equipment when power is being supplied or immediately after the power supply is turned OFF. You may be burnt.

3-4-1 Power Supply Wiring

Connect a 24-VDC power supply to the power supply input terminals.



Precautions for Safe Use

- Use a DC power with a slight voltage fluctuation and that will provide a stable output even if the input is momentarily interrupted for 10 ms. Also use power supply Class 2 or an SELV power supply satisfying the conditions below:
 - · Has an overcurrent protection function
 - · Has double insulation or reinforced insulation
 - Rated Power Supply Voltage: 24 VDC (Allowable range 19.2 to 28.8 VDC)
- Do not perform a dielectric strength test.



Precautions for Correct Use

- Do not allow wire clippings, shavings, or other foreign material to enter the NA Unit. Otherwise, burning, failure, or malfunction may occur. Cover the NA Unit or take other suitable countermeasures, especially during wiring work.
- To use a power supply that does not contain a protection circuit, supply power to the NA Unit through a fuse or other protective element.
- Tighten the terminal screws for the unit and power supply cables to an adequate torque.

Power Supply Specifications

The specifications of a connectable power supply are given in the following table.

Item	Value
Rated supply voltage	24 VDC
Allowable voltage fluctuation range	19.2 to 28.8 VDC (24 VDC ±20%)
Power supply capacity	NA5-15W□□□□-V1(-P): 29 W min.
	NA5-12W□□□□-V1(-P): 25 W min.
	NA5-9W□□□□-V1(-P): 23 W min.
	NA5-7W□□□□-V1(-P): 19 W min.

Wiring Materials


Use the enclosed power supply connector to connect the power supply to the NA Unit.

· We recommend that you use a power supply cable with the following stranded wires. Wire the power supply giving sufficient consideration to the voltage drop and heat generation for the cable length in the installation environment.

Applicable Wires (Stranded Wires)


Size	Conductor cross-section
AWG12 to AWG22	0.35 to 3.31 mm ²

Power Supply Connector



Pin No.	Signal name	Name
1	+24 V	+24-V input
2	0 V	0 V
3	FG	Functional ground

Wiring




Wiring Procedure

Use the following procedure to connect the power supply.

1 Remove the sheath from the power supply wires.




2 Remove the power supply connector from the NA Unit and loosen the terminal block screws.




3 Insert the wires all the way to the back of the connector and then turn the screws clockwise to secure the wires.

Use a small flat-blade screwdriver and tighten the screws to between 0.5 and 0.6 N·m.





Attach the power supply connector to the NA Unit.







Precautions for Correct Use

Observe the following precautions to prevent broken wires.

- When you remove the sheath, be careful not to damage the conductor.
- · Connect the conductor without twisting the wires.
- Do not weld the conductors. If you do so, vibration may cause the wires to break.
- · Do not pull on the cables or bend the cables beyond their natural limit. Do not place heavy objects on top of the cables or other wiring lines. Doing so may break the cables.
- Before you insert a wire into a terminal hole, turn the screw that tightens the terminal counterclockwise until the terminal is no longer visible. Then, insert the wire so that it is held on the terminal and screw side of the case and turn the screw clockwise to tighten the terminal.



· Faulty contact will result if you turn the screw counterclockwise to secure the wire. If necessary, remove the wire, make sure it is inserted in the terminal hole, and then connect it again.



Clockwise Counterclockwise

3-4-2 Wiring the Ethernet Port

Refer to the NA-series Programmable Terminal Device Connection User's Manual (Cat. No. V119) for information on wiring the Ethernet ports.

3-4-3 Wiring the Serial Port

For wiring to the serial port, refer to NA-series Programmable Terminal Device Connection User's Manual (Cat. No. V119).

3-5 Control Panel Installation

To ensure system reliability and safety, the system must be designed and configured according to the installation environment (temperature, humidity, vibration, shock, corrosive gases, overcurrent, noise, etc.).

3-5-1 Temperature

Panels have been reduced in size due to space-saving and miniaturization in devices and systems, and the temperature inside the panel may be at least 10 to 15°C higher than outside the panel. Implement the following measures against overheating at the installation site and in the panel, and allow a sufficient margin for the temperature.


High Temperatures

Use the following cooling methods as required, taking into account the ambient temperature and the amount of heating inside the panel.


Natural Cooling

Natural cooling relies on natural ventilation through slits in the panel, rather than using cooling devices such as fans or coolers. When using this method, observe the following points.

- Do not install the NA Unit at the top of the panel, where hot air tends to stagnate.
- To provide ventilation space above and below the NA Unit, leave sufficient distance from other devices, wiring ducts, etc.
- Do not mount the NA Unit in the wrong direction (e.g., vertically or upside down). Doing so may cause abnormal heating in the NA Unit.
- Do not install the NA Unit above any heat-generating equipment, such as heaters, transformers, and devices with high resistance.
- Do not install the NA Unit in a location exposed to direct sunlight.




Forced Ventilation (with Fan at Top of Panel)




Forced Ventilation Method

• Forced Air Circulation (with Fan in Closed Panel)




Forced Circulation

• Room Cooling (Cooling the Entire Room Where the Control Panel Is Located)



3-5-2 **Humidity**

Rapid temperature changes can cause condensation to occur, resulting in malfunctioning due to short-circuiting. When there is a possibility of this occurring, take measures against condensation, such as leaving the NA Unit power ON at night or installing a heater in the control panel to keep it warmer.



Examples of Measures against Condensation

3-5-3 Vibration and Shock

The NA Unit is tested for conformity with the sine wave vibration test method (IEC 60068-2-6) and the shock test method (IEC 60068-2-27) of the Environmental Testing for Electrotechnical Products. It is designed so that malfunctioning will not occur within the specifications for vibration and shock. If, however, the NA Unit is to be used in a location in which it will be directly subjected to regular vibration or shock, then implement the following countermeasures:

- Separate the control panel from the source of the vibration or shock.
 Or, secure the NA Unit and the panel with rubber padding.
- · Make the building or the floor vibration resistant.
- To prevent shock when other devices in the panel such as electromagnetic contactors operate, secure either the source of the shock or the NA Unit with rubber padding.

3-5-4 Atmosphere

Using the NA Unit in any of the following locations can cause defective contact with connectors and corrosion of components. Implement countermeasures such as purging the air as required.

- In locations exposed to dust, dirt, salt, metal powder, soot, or organic solvents, use a panel with an airtight structure. Be careful of temperature increases inside the panel.
- In locations exposed to corrosive gas, purge the air inside the panel to clear the gas and then pressurize the inside of the panel to prevent gas from entering from outside.
- In locations where flammable gas is present, either use an explosion-protected construction or do not use the NA Unit.


3-5-5 **Electrical Environment**

When installing or wiring devices, make sure that there will be no danger to people and that noise will not interfere with electrical signals.


Installation Locations for NA Unit

Install the NA Unit as far away as possible from high-voltage (600 V or higher) and power devices to ensure safe operation and maintenance.

Example of Recommended Equipment Arrangement



Example of Poor Equipment Arrangement



Examples of Equipment Arrangement in Panel with High-voltage Devices

External Wiring

Wiring, and noise countermeasures in particular, must be based mostly on experience, and it is necessary to closely manage wiring based on information in the manuals.

Wiring Routes


Each of the following combinations includes different signal types, properties, or levels. They will cause the signal-to-noise ratio to drop due to factors such as electrical induction. As a general rule when wiring, either use separate cables or separate wiring routes for these items. Future maintenance operations and changes to the system will also be made easier by carefully organizing the wiring from the start.

- · Power lines and signal lines
- · Input signals and output signals
- Analog signals and digital signals
- High-level signals and low-level signals
- · Communications lines and power lines
- · DC signals and AC signals
- High-frequency devices (such as Inverters) and signal lines (communications)

Wiring Methods


Observe the following points when wiring power supply and signal cables.

- When routing signal cables with different characteristics through the same duct, always keep them separated.
- As much as possible, avoid routing multiple power supply lines through the same duct. If it cannot be avoided, then construct a partition between them in the duct and ground the partition.




Partitioning Methods for Signal and Power Supply Cables

· To avoid overheating the conduits when using conduits for wiring, do not place wires for a single circuit in separate conduits.



Parallel Wiring (Single Phase)

- Power cables and signal cables adversely affect each other. Do not wire them in parallel.
- Noise induction may occur if the NA Unit is installed in a panel that includes high-voltage devices. Wire and install them as far apart as possible.
- Either install the NA Unit a minimum of 200 mm away from high-voltage lines or power lines, or place the high-voltage lines or power lines in metal tubing and completely ground the metal tubing to 100 Ω or less.



Example: Separating NA Unit from Power Lines

3-5-6 Grounding

Grounding has the following two purposes.

· Protective Grounding

Protective grounding is done to ensure safety. It is intended to prevent electrical shock by holding the electrical potential at the grounding potential that is generated by factors such as leakage, induction, or failure.

· Functional Grounding

Functional grounding is done to protect device and system functions, including prevention of noise from external sources, or prevention of noise from devices or equipment that could have harmful effects on other devices or equipment.

The functional ground must in some cases be determined by experimentation. It is important to sufficiently check the particular circumstances before grounding.

Grounding Methods and Precautions

Wiring the Ground

The NA unit has a protective ground terminal () and a functional ground terminal ().

1. Protective Ground


For safety, be sure to use a ground of 100Ω or less for the protective ground of the NA unit. For the grounding wiring, refer to 3. *Grounding Wiring* on page 3-26. Note that protective grounding is not required for the NA5- $\square\square$ W \square \square -V1-P, and thus no wiring is necessary.

· Applicable Wire

Conductor cross-section	Crimp terminal
2.00 mm ² min.	For M4

· Protective ground terminal

Thread diameter	Screw Tightening Torque
M4	1.0 to 1.2 N·m



2. Functional ground


For the grounding wiring, refer to 3. Grounding Wiring on page 3-26.

· Applicable Wire

Size	Conductor cross-section
AWG #12 to 22	0.35 to 3.31 mm ²


· Screw Tightening Torque 0.5 to 0.6 N·m

· Power Supply Connector




Pin No.	Signal name	Name
1	+24 V	+24-V input
2	0 V	0 V
3	FG	Functional ground

3. Grounding Wiring



4. NA Unit internal grounding connection diagram



*1. Protective grounding is not required for the NA5-_\U_\U__\-V1-P, and thus no wiring is necessary.



System Program

This section describes the system program that is used by NA-series Programmable Terminals.

4-1	Syster	m Program and NA Unit Startup Status	. 4-2
4-2	Syster	m Recovery	. 4-3
4-3	Syster	m Menu Overview	. 4-6
	4-3-1	System Menu Configuration	
	4-3-2	Using the System Menu	4-9
4-4	Syster	n Menu Details	4-11
	4-4-1	Display Settings (Project System Menu)	4-11
	4-4-2	Language Settings (Project System Menu)	. 4-12
	4-4-3	External Device Settings (Project System Menu)	. 4-12
	4-4-4	User Accounts (Project System Menu)	. 4-13
	4-4-5	NJ/NX/NY Troubleshooter (Project System Menu)	. 4-14
	4-4-6	Alarm Viewer (Project System Menu)	. 4-26
	4-4-7	Project System Menu Settings (Project System Menu)	. 4-29
	4-4-8	Print Settings (Project System Menu)	. 4-29
	4-4-9	Buzzer Settings (Project System Menu)	. 4-30
	4-4-10	Operation Log Viewer	. 4-31
	4-4-11	Safety Monitor	. 4-36
	4-4-12	Date & Time Settings (Device System Menu)	. 4-48
	4-4-13	Language Settings (Device System Menu)	. 4-48
	4-4-14	Interface Settings (Device System Menu)	. 4-49
	4-4-15	Brightness Settings (Device System Menu)	. 4-54
	4-4-16	Transfer Operations (Device System Menu)	. 4-55
	4-4-17	Hardware Diagnostics (Device System Menu)	. 4-60
	4-4-18	Production Information (Device System Menu)	. 4-64

System Program and NA Unit Startup **Status**

The system program is required to start the NA Unit and execute the project in the NA Unit.

- The system program automatically starts when you turn ON the power supply to the NA Unit or when you press the reset switch while power is supplied. When the system program starts, one of the following states is entered.
 - a) If there is an executable project in the NA Unit, the project is automatically executed. Refer to 4-3-2 Using the System Menu on page 4-9 for the procedure to display the System Menu.
 - b) If there is not an executable project in the NA Unit, the System Menu is automatically displayed.
- If there is an error in the system program, the NA Unit will not operate normally. If you think there is a problem with the system program, system recovery may be necessary. Refer to 5-2-1 Confirming NA Unit Operation on page 5-5 and 4-2 System Recovery on page 4-3 for the method to see whether there is an error in the system program and the system recovery proce-



Precautions for Correct Use

When you perform system recovery or update the system program, the NA Unit will be returned to the default status and the project will be deleted.

· You may need to update the system program from time to time, e.g., when support for a new connected device is added to the NA Units. In this case, the system program is automatically downloaded from the Sysmac Studio.



Additional Information

The system program at the time of shipment from the factory is version 1.0.0.

4-2 System Recovery

You can implement system recovery if the NA Unit will not start normally or if you want to initialize the contents of the NA Unit to the default state.

When you implement system recovery, all of the user data is deleted from the NA Unit and the system program is overwritten with the newest version.

System Recovery Procedure

Use the following procedure for system recovery.




Prepare a formatted SD Memory Card or USB Memory Device.



Precautions for Correct Use

- An SD Memory Card that is formatted in a manner that the master boot record is not arranged in the first sector cannot be used for system recovery. To use the SD Memory Card for system recovery, first format the SD Memory Card in the SD Memory Card Formatter for SD/SDHC/SDXC distributed by the SD Association.
- Among the HMC-SD291 SD Memory Cards, the SD Memory Cards with the E mark at the
 position indicated by the arrow in the figure below cannot be used for system recovery.



2 Execute the following file in the Sysmac Studio installation media.

Sysmac_Studio_installation_media\Utility\
NA5V1 RecoverUpdate\NA RecoverUpdate □ □ □.exe

3 Specify the root folder on the media you prepared in step 1 as the extraction location.




Additional Information


- · Files stored on the media may be deleted.
- · When you use the media for other applications, format again with a third party format tool.




Turn OFF the power supply to the NA Unit.


Open the battery cover on the back of the NA Unit and set the DIP switch to the settings shown below. When you finish setting the DIP switch, close the battery cover.








8 Select the package that you want to install, and then tap the **Install** Button.




9 Tap the **Yes** Button.



10 When the following message is displayed, remove the media from the NA Unit and turn OFF the power supply to the NA Unit.


System Installer

Intallation completed.



Now remove the USB storage device or the SD card, turn off the device, revert the DIP switches to the original state and turn on the device.

11 Open the battery cover on the back of the NA Unit and set the DIP switch to the settings shown below. When you finish setting the DIP switch, close the battery cover.



This concludes system recovery.

System Menu Overview

You can use the System Menu to perform operations according to on-screen displays to perform various settings for the NA Unit.

Refer to 4-3-1 System Menu Configuration on page 4-6 for the configuration of the System Menu.

Refer to 4-3-2 Using the System Menu on page 4-9 for the procedures to use the System Menu.

4-3-1 **System Menu Configuration**

The initial display for the System Menu depends on whether there is a project in the NA Unit.

If there is a project, the Project System Menu is displayed initially. If there is no project, the Device System Menu is displayed initially and you cannot access the Project System Menu.


The following items and functions are displayed on the System Menu.

• Project System Menu (1/2)




Item	Description	Reference
Display Settings	Sets the screen saver and display brightness.	P. 4-11
Language Settings	Sets the user language and the system language.	P. 4-12
External Device Settings	Sets the communications settings for connected devices.	P. 4-12
User Accounts	Sets the user account settings.	P. 4-13
NJ/NX/NY Troubleshooter	Displays the NJ/NX/NY Troubleshooter.	P. 4-14
Alarm Viewer	Displays user alarms.	P. 4-26
Project System Menu Set-	Sets the starting method for the System Menu.	P. 4-29
tings		
Device System Menu	Calibrates the touch panel.	P. 4-60

• Project System Menu (2/2)



Item	Description	Reference
Print Settings	ettings Sets up printing/capturing of the NA screens.	
Buzzer Settings	Sets buzzer sounds.	P. 4-30
Operation Log Viewer	ion Log Viewer Displays the Operation Log Viewer. P. 4-3	
Safety Monitor	Displays the Safety Monitor.	P. 4-36

• Device System Menu



Item	Description	Reference
Date & Time Settings	Sets the date and time, as well as settings for synchronization with the time server.	P. 4-48
Language Settings	Makes settings for the system language.	P. 4-48
Interface Settings	Makes settings for the NA Unit interface.	P. 4-49
Brightness Settings	Sets the screen brightness.	P. 4-54
Transfer Operations	Transfers the project and data.	P. 4-55
Hardware Diagnostics	Calibrates the touch panel.	P. 4-60
Production Information	Gives the lot number of the NA Unit and other information.	P. 4-64

4-3-2 Using the System Menu

This section describes how to use the System Menu, including the display methods and how to select menu items.



Additional Information

The system settings that are made in the Sysmac Studio project data take priority over the settings that are made from the System Menu.


System Menu Display Methods

You can display the System Menu with any of the following methods. Refer to the *NA-series Program-mable Terminal Software User's Manual* (Cat. No. V118) for information on actions and subroutines.

- Double-tapping one of the four corners of the touch panel
- Executing the ShowSystemMenu action
- Executing the ShowSystemMenu function in a subroutine

Double-tapping one of the four corners of the touch panel

Double-tapping one of the four corners of the touch panel on the NA Unit.



When you tap one of the four corners of the touch panel, tap one where no object is displayed. If you tap a corner where an object is displayed, the function of the object is executed. You can also choose the active locations from the four corners.

Executing the ShowSystemMenu Action

When you create the application, you can create a button on a page and assign the ShowSystem-Menu action to that button. Then when you tap the button, the System Menu is displayed.


Executing the ShowSystemMenu Function in a Subroutine

When you create the application, you can create a button on a page and assign that button to a sub-routine that executes the ShowSystemMenu function. Then when you tap the button, the System Menu is displayed.

Selecting Menu Items

Tap a menu item or icon on the System Menu to display the corresponding functionality.

Example: Tap the Hardware Diagnostics Icon on the Device System Menu to display the Hardware Diagnostics Screen.



Leaving the System Menu to Enter Operating Status

Tap the Exit Button on the Project System Menu to return to Run Status. Any changes to settings are applied when you return to Run Status. To enable some settings, you may have to reset the NA Unit.

Common System Menu Operations

This section describes the functions that are common to the entire System Menu.



LCD Display

This button exits the System Menu and places the NA Unit in Run Status or displays the Project System Menu.



This button changes to a page at the next higher level.




This button applies local changes to settings.

4-4 System Menu Details

This section describes the functions that are provided by the System Menu.

4-4-1 Display Settings (Project System Menu)


You can use the display settings to set the following items.



No.	Item	Description
(a)	Screen Saver Enabled	Select this check box to use the screen saver.
(b)	Туре	Sets the type of screen saver.
(c)	Timeout	Sets the time until the screen saver is started in minutes.
(d)	Brightness	Sets the screen brightness.

4-4-2 **Language Settings (Project System Menu)**


You can use the language settings to set the following items.



No.	Item	Description
(a)	User Language	Sets the user language.
(b)	System Language	Displays the system language that is associated with the user lan-
		guage.
(c)	Keep this setting on as a startup	If you select this check box, the language that is set as the system
	language	language is used as the startup language.
(d)	USB Keyboard Layout	Sets the layout of a USB keyboard.

External Device Settings (Project System Menu) 4-4-3

You can use the external device settings to set the following items.



No.	Item	Description
(a)	Connected Device List	Displays a list of the connected devices that are registered in the
		project.
(b)	Connected Device Communica-	Displays the communications settings of the connected device that
	tions Settings	is selected in the list. Refer to the NA-series Programmable Termi-
		nal Device Connection User's Manual (Cat. No. V119) for details.


4-4-4 User Accounts (Project System Menu)

You can use the user account settings to set the following items.



Precautions for Safe Use

When you change a password, do not reset the NA Unit or turn OFF the power supply before
writing the new password is completed. A failure to store the password may cause the project
to fail to function.



No.	Item	Description
(a)	Name	Sets the name.
(b)	Role	Sets the rights.
(c)	Password	Sets the password.
(d)	Comment	Sets a comment.
(e)	Save	Saves any changes.
(f)	Cancel	Discards any changes.
(g)	/	Edits the selected user account.
(h)	Ē	Deletes the selected user account.
(i)	+	Adds a user account.
(j)	User account table	A list of the user accounts that are currently registered is displayed.

4-4-5 NJ/NX/NY Troubleshooter (Project System Menu)

The NJ/NX/NY Troubleshooter can be used to access descriptions and countermeasures for errors and events that occur in the Controller and built-in devices. These functions can be used only when you are connected to an NJ/NX/NY-series Controller.



Additional Information

When using the NJ/NX/NY Troubleshooter, set the CPU Unit Secure communication version to 1. The NJ/NX/NY Troubleshooter does not support Secure communication version 2. Refer to NJ/NX-series CPU Unit Software User's Manual (Cat. No. W501) regarding Secure communication versions.

Errors and Events That Can Be Monitored

User-defined Errors and User-defined Events

Errors and events can be defined by the user with the Sysmac Studio. Detailed information on troubleshooting also can be set. Refer to Section 1 Overview in the NJ/NX-series Troubleshooting Manual (Cat. No. W503) and Section 1 Overview of Errors in the NY-series Troubleshooting Manual (Cat. No. W564-E1) for details.

Controller Errors and Controller Events

These errors and events are generated by an NJ/NX/NY-series Controller. These errors and events cannot be edited by the user. Refer to Section 1 Overview in the NJ/NX-series Troubleshooting Manual (Cat. No. W503) and Section 1 Overview of Errors in the NY-series Troubleshooting Manual (Cat. No. W564-E1) for details.

When Connected to an NX-series CPU Unit

			Troubleshoo	ter functions	
System configuration element		Displaying errors	Clearing errors	Displaying error logs	Clearing error logs
CPU Unit			Appli	cable	
NX Units ^{*1}		Applicable	Applicable*4 *5	Applicable	Applicable*3
EtherCAT Slaves (Sys	EtherCAT Slaves (Sysmac devices)		icable	Applicable ^{*2}	Applicable*2 *3
EtherCAT Slave Ter- minals			icable	Applicable ^{*2}	Applicable*2 *3
	NX Units	Partially appli- cable ^{*6}	Applicable*4 *5	Applicable ^{*2}	Applicable*2 *3
X Bus Unit ^{*7}		Applicable	Applicable*8	Applicable	Applicable*3

^{*1.} Supported in runtime version 1.07 or higher.

^{*2.} Supported in runtime version 1.03 or higher.

^{*3.} Event logs for individual units cannot be cleared.

^{*4.} Errors that occur on a specific NX Unit cannot be cleared separately.

^{*5.} It might be necessary to reset errors in Safety Control Units with a safety program. Refer to the NX-series Safety Control Unit User's Manual (Cat. No. Z930) for details on resetting errors in Safety Control Units.

^{*6.} Events are not displayed for some NX Units. If an error occurs in an NX Unit that does not display events, an NX Unit Minor Fault event will occur in the EtherCAT Coupler Unit and the unit number of the NX Unit in which the error occurred will be given in the attached information.

- *7. Supported in runtime version 1.17 or higher.
- *8. Errors that occur on a specific X Bus Unit cannot be cleared separately.

When Connected to an NJ-series CPU Unit

			Troubleshoo	ter functions	
System configura	ation element	Displaying	Clearing	Displaying	Clearing error
		errors	errors	error logs	logs
CPU Rack	CPU Unit	Applio		cable	
	CJ-series Units	Appli	cable	Partially a	pplicable ^{*1}
EtherCAT Slaves (Sys	mac devices)	Appli	cable	Applicable ^{*2}	Applicable*2 *3
EtherCAT Slave Ter- minals	EtherCAT Coupler Units	Applicable		Applicable ^{*2}	Applicable*2 *3
	NX Units	Partially appli- cable ^{*4}	Applicable*5 *6	Applicable ^{*2}	Applicable*2 *3

^{*1.} You cannot display or delete events in the error history (upper four digits of event code are 0000 hex) in a CJ-series Special Unit mounted on an NJ-series CPU Unit.

- *2. Supported in runtime version 1.03 or higher.
- *3. Event logs for individual units cannot be cleared.
- *4. Events are not displayed for some NX Units. If an error occurs in an NX Unit that does not display events, an NX Unit Minor Fault event will occur in the EtherCAT Coupler Unit and the unit number of the NX Unit in which the error occurred will be given in the attached information.
- *5. Errors that occur on a specific NX Unit cannot be cleared separately.
- *6. It might be necessary to reset errors in Safety Control Units with a safety program. Refer to the *NX-series Safety Control Unit User's Manual* (Cat. No. Z930) for details on resetting errors in Safety Control Units.

When Connected to an NY-series CPU Unit

			Troubleshooter functions		
System configuration element		Displaying errors	Clearing errors	Displaying error logs	Clearing error logs
CPU Unit			Appli	cable	
EtherCAT Slaves (Sys	EtherCAT Slaves (Sysmac devices)		cable	Applicable ^{*1}	Applicable*1 *2
EtherCAT Slave Ter- minals EtherCAT Cou- pler Units		Appli	cable	Applicable ^{*1}	Applicable*1 *2
	NX Units	Partially appli- cable ^{*3}	Applicable*4 *5	Applicable*1	Applicable*1 *2

^{*1.} Supported in runtime version 1.06 or higher.

^{*2.} Event logs for individual units cannot be cleared.

^{*3.} Events are not displayed for some NX Units. If an error occurs in an NX Unit that does not display events, an NX Unit Minor Fault event will occur in the EtherCAT Coupler Unit and the unit number of the NX Unit in which the error occurred will be given in the attached information.

^{*4.} Errors that occur on a specific NX Unit cannot be cleared separately.

^{*5.} It might be necessary to reset errors in Safety Control Units with a safety program. Refer to the *NX-series Safety Control Unit User's Manual* (Cat. No. Z930) for details on resetting errors in Safety Control Units.

When Connected to an NX-series Communication Control Unit

	Troubleshooter functions			
System configuration element	Displaying errors	Clearing errors	Displaying error logs	Clearing error logs
Communication Control Unit		Appli	cable	-
NX Units	Partially appli- cable *1	Applicable*2*3	Applicable	Applicable*4

^{*1.} Events are not displayed for some NX Units.

^{*2.} Errors that occur on a specific NX Unit cannot be cleared separately.

^{*3.} It might be necessary to reset errors in Safety Control Units with a safety program. Refer to the NX-series Safety Control Unit/Communication Control Unit User's Manual (Cat. No. Z395) for details on resetting errors in Safety Control Units.

^{*4.} Event logs for individual units cannot be cleared.

Starting and Quitting the NJ/NX/NY Troubleshooter

There are four ways to start the NJ/NX/NY Troubleshooter.


- Select NJ/NX/NY Troubleshooter from the System Menu.
- Execute the ShowTroubleshooter action.
- Execute the ShowTroubleshooter function.
- Set the Troubleshooter operation settings to specify monitoring user-defined or Controller errors.
 (The NJ/NX/NY Troubleshooter will be displayed automatically when a user-defined error or Controller error occurs.)

Starting from the System Menu

1 Display the System Menu and select NJ/NX/NY Troubleshooter.



2 The NJ/NX/NY Troubleshooter will be started.




Starting from a User Screen


The required settings must be made from the Sysmac Studio.

The following example shows how to execute the Troubleshooter by using an object event. In this example, settings are performed to execute the Troubleshooter when a Button object is clicked.


1 Place a Button object on the screen and display *Events and Actions*.




Select Click as the event.



Select ShowTroubleshooter as the action.



- Specify the name of the Controller to be connected in ControllerName.
- Specify the name of the page to be displayed while the Troubleshooter is running in *StartPage*.






Additional Information

If you use runtime version 1.02 or if you do not specify a name for *ControllerName*, a Controller status list is displayed on the screen when the Troubleshooter is activated.

Starting the Troubleshooter for User-defined Errors or Controller Errors

The required settings are made from the Sysmac Studio.


- 1 Double-click **Troubleshooter** under **Configurations and Setup** in the Multiview Explorer. The Troubleshooter Settings Tab Page will be displayed in the Edit Pane.
- **2** Select the Launch on System Event or Launch on User Event Check Box.



- **3** Generate the type of error that was set in step 2 in the Controller.
- **4** The NJ/NX/NY Troubleshooter will be started.

Quitting the NJ/NX/NY Troubleshooter


Click the Exit Button on the screen that was displayed when the NJ/NX/NY Troubleshooter started.



The display will return to the user screen that was displayed before the NJ/NX/NY Troubleshooter started.

NJ/NX/NY-series Controller Status Screen


The status of the host to which the NA is currently connected is displayed.



No.	Item	Description
1	Exit Button	Quits the Troubleshooter.
2	Title Bar	Displays the current date of the NA.
3	Tabs	Switch between displaying active events and the event log.
4	Status List	Displays the status of the currently connected host.
5	Status Bar	Displays information on the Controller that is currently selected.
6	Show Controller Events	Displays the Controller Event List Screen of the selected host.
7	Show User Events	Displays the User-defined Event Lists Screen.

Controller Event List Screen

This screen displays a list of the Controller errors for the selected host.



No.	Item	Description
1	Exit Button	Quits the Troubleshooter.
2	Title Bar	Displays the current date of the NA.
3	Tabs	Switch between displaying active events and the event log.
4	Controller Events	Displays current Controller events.
5	User Events	Displays current user-defined events.
6	Change (source of the error)	Selects the source of the errors to display and restricts the items to
	Button	display.
7	Back Button	Returns the display to the NJ/NX/NY-series Controller Status
		Screen.
8	Screen Shot Button	Captures an image of the displayed screen and stores it in USB
		memory or an SD Memory Card in PNG format.
9	Show Detail Button	Displays the detailed screen of the current event.
10	Error Reset Button	Clears the events that are displayed on the screen.
11	Status Bar	Displays information on the Controller that is currently selected.




Additional Information

Although user-defined events are also displayed with similar descriptions on the screen, no source is displayed because user events are not displayed according to the Functional Module. When the **Reset** Button is pressed, all of the errors, including anything hidden on the screen, will be cleared.

Controller Event Log Screen

This screen displays a list of the Controller events for the selected host.



No.	Item	Description
1	Exit Button	Quits the Troubleshooter.
2	Title Bar	Displays the current date of the NA.
3	Tabs	Switch between displaying active events and the event log.
4	Controller Events	Displays current Controller events.
5	User Events	Displays current user-defined events.
6	Display Item Selection	Selects the Event Log Selection Screen to display.
7	Back Button	Returns the display to the NJ/NX/NY-series Controller Status
		Screen.
8	Screen Shot Button	Captures an image of the displayed screen and stores it in USB
		memory or an SD Memory Card in PNG format.
9	Save to File Button	Stores the Controller event log of the selected Controller in USB
		memory or an SD Memory Card in CSV format.
10	Show Detail Button	Displays the detailed screen of the current event log.
11	Log Clear Button	Removes all the Controller Event Log of the selected Controller.
12	Status Bar	Displays information on the Controller that is currently selected.




Precautions for Correct Use

When the Log Clear Button is pressed, all of the event logs, including anything hidden on the screen, will be cleared.

This operation cannot be undone.

Event Source Selection Screen


On this screen, the Functional Modules that are the sources of the errors are selected.



No.	Item	Description
1	Functional Module List	Displays a list of the Functional Modules in the Controller.
2	Sub Functional Module List	Displays a list of the Sub Functional Modules in the Controller.
3	OK Button	Confirms the Functional Module to display.
4	Cancel Button	Cancels the item selection.

Details Screen

This screen displays detailed information on errors or events.




No.	Item	Description
1	Title Bar	Displays the current date of the NA.
2	Back Button	Closes the Details Screen.
3	Details Button	Displays errors and events in detail.
4	Screen Shot Button	Captures an image of the displayed screen and stores it in USB memory or an SD Memory Card in PNG format.
5	Status Bar	Displays information on the Controller that is currently selected.

Operation Settings of the NJ/NX/NY Troubleshooter

The operation settings of the NJ/NX Troubleshooter are set from the Sysmac Studio. Double-click **Troubleshooter** under **Configurations and Setup** in the Multiview Explorer. The Troubleshooter Settings Tab Page will be displayed in the Edit Pane.

Setting the Display Languages for Errors and Event Logs


The display languages are set in the Language Mapping Area.



No.	Item	Description
1	Selected Controller	Selects the Controller for which to set the languages.
2	HMI Project Language	Displays the project language that is set in the HMI.
3	User Event Language	Sets the language to use to display user-defined events. Set the cor-
		responding languages for the NA project and the Controller project.

Restricting Operation of the Troubleshooter

You can use passwords to restrict the operation of the Troubleshooter for each function.



No.	Item	Description
1	Access to Event Logs	Select the level to restrict operations to switch to event log screens.
2	Ability to Reset Errors	Select the level to restrict operations to reset an errors.
3	Ability to Clear Event Logs	Select the level to restrict operations to clear logs.
4	Ability to Save to CSV File	Select the level to restrict operations to save the data to CSV files.
5	Ability to Print Screens	Select the level to restrict operations to capture screens.
6	Restriction Level	Set the levels in the Security Setting Area for the operations to restrict.

4-4-6 Alarm Viewer (Project System Menu)


The following two functions are provided to display alarms.

Item Description	
Active HMI User Alarms	Displays current user alarms.
Historical HMI User Alarms	Displays the user alarm log.

From the Alarm Viewer Screen, you can tap any of the icons for functions to display the individual function screens.




· Active HMI User Alarms This screen displays a table of the current user alarms.




No.	Item	Description	
(a)	Active HMI User Alarm List	Displays a table of the current user alarms.	
(b)	Show Details	Displays detailed information on the selected user alarm.	

Alarm Details Screen
 This screen displays detailed information on a selected user alarm.



No.	Item	Description
(a)	Alarm Code	Displays the alarm code of the user alarm that occurred.
(b)	Additional Information	Displays the additional information of the user alarm that occurred.
(c)	Details	Displays the details on the user alarm that occurred.
(d)	Logged-in User	Displays the name of the user that is currently logged in.
(e)	Status	Displays the status of the user alarm that occurred.
(f)	Priority	Displays the priority of the user alarm that occurred.
(g)	Group	Displays the group of the user alarm that occurred.
(h)	Message	Displays the message for the user alarm that occurred.
(i)	Name	Displays the name of the user alarm that occurred.
(j)	Date and Time	Displays the time and date that the user alarm occurred.


Historical HMI User Alarms Screen
 This screen displays a log of the user alarms.



No.	Item	Description
(a)	Historical HMI User Alarm	Displays a log of the user alarms.

4-4-7 Project System Menu Settings (Project System Menu)


You can use the System Menu settings to set the following items.



No.	Item	Description	
(a)	Double-tap Interval	Sets the double-tap interval for the operation to start the System	
		Menu.	
(b)	Detectable Corner	Sets the double-tap detection positions for the operation to start the	
		System Menu.	

4-4-8 Print Settings (Project System Menu)


You can use the print settings to set the following items.



No.	Item	Description	
(a)	Color Mode	Select from among the following options for colors and/or reverse display of printing or capturing screens:	
		• Color	
		Grayscale	
		Reverse Grayscale	
(b)	Print With Title	Select this check box to insert a screen title during printing/capturing of the screen.	

Buzzer Settings (Project System Menu) 4-4-9

You can use the buzzer settings to set the following items.



No.	Item	Description
(a)	Touch Input Notification	Select this check box to sound the buzzer when an object is
		touched.
(b)	Alarm Notification	Select this check box to sound the buzzer when an alarm occurs.
(c)	Sound Type	Select the buzzer type from among the following options:
		Continuous
		Intermittent Short Pulse
		Intermittent Long Pulse
(d)	Minimum User Alarm Priority	Select the user fault level that sounds the buzzer from among the
		following options:
		User Fault Level 1
		User Fault Level 2
		User Fault Level 3
		User Fault Level 4
		User Fault Level 5
		User Fault Level 6
		User Fault Level 7
		User Fault Level 8
		User Information

4-4-10 Operation Log Viewer

In the Operation Log Viewer, you can check the logs recorded when operations specified on Sysmac Studio are executed on the NA unit.

Starting and Exiting Operation Log Viewer

There are three ways to start the Operation Log Viewer as shown below.


- Select Operation Log Viewer from the System Menu.
- · Execute the ShowOperationLogViewer action.
- Execute the ShowOperationLogViewer function.

Starting from the System Menu

1 Display the System Menu and select Operation Log Viewer.



2 Operation Log Viewer starts up.




Starting from a User Screen


The required settings are made from the Sysmac Studio.

The following example shows how to execute the Operation Log Viewer by using an object event. In this example, settings are performed to execute Operation Log Viewer when a Button object is tapped.


1 Place a Button object on the screen and display Events and Actions.



Select Click as the event.




3 Select ShowOperationLogViewer as the action.



• Exiting Operation Log Viewer


1 Tap Back on the screen that was displayed when the Operation Log Viewer started.



2 The display will return to the screen that was displayed before the Operation Log Viewer started.

Operation Log Viewer


Displays the operation logs.



No.	Item		Description
1	Search	Searches the speci	ified date and time and then displays the results
		in the log list.	
2	Log List	Displays a list of the	e logs that have been recorded.
		Date and Time:	Displays the local time at which the log was recorded.
		Operation:	Displays the contents of an operation.
		Operation Info1:	Displays the object name as well as other information.
		Page:	Displays the page name.
3	Change Page	Changes the page of the Log List. The left end is the newest page	
		while the right end	is the oldest.
4	Back	Closes the Operation Log Viewer.	
5	Details	Displays detailed information on the log selected in the Log List.	

Detail Information

Displays detailed information on the log.



No.	Item		Description
1	Log detail information	Displays detailed	information on the log.
		Date and Time:	Displays the local time at which the log was recorded.
		User:	Displays the user who executed the operation.
		Category:	Displays the category of the operation executed.
		Operation:	Displays the operation that has been executed.
		Details:	Displays detailed information.
2	Back	Closes the details	displayed.

Safety Monitor 4-4-11

Safety Monitor provides a function to identify inputs that cause abnormal states when the external output from the safety program of the safety control unit is in an abnormal state.

Display Item

Safety Monitor can display the items below.

I/O Matrix Monitor

Displays the value of the variables used in the safety program.

There are two applicable variable types, variables registered to Output among the following variables and variables registered to Input related to those variables.

- · Exposed variables
- · Device variables

Safety I/O Monitor

Displays the status of the safety I/O unit.

The safety I/O unit on which the variables registered to Input or Output in Exposed Variables are assigned to the I/O port are targeted.

System configuration

All NA5 Series Programmable Terminals support the Safety Monitor. To use the Safety Monitor, an SD memory card needs to be inserted into the NA unit.

The equipment that can be monitored is as follows.

CPU Unit

- · NJ-series CPU Unit
- · NX-series CPU Unit

Communication Control Unit

• NX-CSG320

Safety Controller Unit

- NX-SL5□□□
- NX-SL3□□□

Safety I/O Unit

- NX-SIH400
- NX-SID800
- NX-SOH200
- NX-SOD400

Connection path

	Directly connected to the CPU unit	Via an EtherCAT coupler unit
NJ-series CPU Unit	Not supported	Supported
NX-series CPU Unit	Supported*1	Supported
NX-CSG320	Supported	Not supported

^{*1.} Only NX102-□□□□ and NX502-□□□□ supports it.



Additional Information

When the Safety Monitor is used, the target device needs to exist in the same project in the Sysmac Studio.

Starting and exiting Safety Monitor

There are three ways to start the Safety Monitor as shown below.


- Select Safety Monitor from the System Menu.
- · Execute the StartSafetyMonitor action.
- Execute the StartSafetyMonitor function.

Starting from the System Menu

Display the System Menu and select Safety Monitor.



This starts the Safety Monitor.




Starting from a User Screen

The required settings are made from the Sysmac Studio.


The following example shows how to use an object event to execute the Safety Monitor.

In this example, settings are made to execute the Safety Monitor when a Button object is pressed.


1 Place a Button object on the screen and display Events and Actions.



2 Select Click as the event.




3 Select *StartSafetyMonitor* as the action.



Exiting Safety Monitor


Tap on the screen that was displayed when the Safety Monitor started.



The display will return to the screen that was displayed before the Safety Monitor started.

I/O Matrix Monitor


Displays a list of values of variables. In the initial state, only outputs are displayed. Selecting an output displays its related inputs.



No.	Item	Description	
1	Applicable equipment	Displays the safety CPU unit currently being monitored.	
2	Output from Safety CPU	Displays a list of outputs and shows values.	
3	Safety I/O monitor	Displays information on the safety I/O unit to which the selected variable is assigned. Displays the safety output unit monitor or safety input unit monitor according to the safety I/O unit assigned	
4	Variable Information	Displays detailed information on the selected variable.	
5	Search	Searches for a variable.	
6	PDF display	Displays files set in PDF Display Settings.	
7	Menu	Accesses various functions.	
8	×	Exits the Safety Monitor.	
9	Input to Safety CPU	Displays a list of inputs related to the selected output and shows the value.	

Safety output unit monitor


Displays the status of the safety output unit.



No.	Item	Description	
1	Applicable equipment	Displays the CPU unit currently being monitored.	
2	Unit information	Displays information on the currently displayed safety output unit.	
3	Terminal section monitor	Displays the output state of the terminal.	
		Green: ON	
		Gray: OFF	
		Red: Error	
		Orange: IOG terminal being used	
		Black: Unused	
4	Variable Information	Displays the name of the variables assigned to the terminal as well	
		as any comments.	
5	Change display items	Changes the items to display when there are four or more display	
		items.	
6	External equipment setting	Displays information on the equipment connected to the terminal.	
	information	Displays the name of the equipment, terminal numbers connected,	
		as well as corresponding icons.	
7	×	Closes the safety output unit monitor.	

Safety input unit monitor


Displays the status of the safety input unit.



No.	Item	Description
1	Applicable equipment	Displays the CPU unit currently being monitored.
2	External equipment setting	Displays information on the equipment connected to the terminal.
	information	Displays the name of the equipment, terminal numbers connected,
		as well as corresponding icons.
3	Change display items	Changes the items to display when there are four or more display
		items.
4	Variable Information	Displays the name of the variables assigned to the terminal as well
		as any comments.
5	Terminal section monitor	Displays the input status of the terminal.
		Green: ON
		Gray: OFF
		Red: Error
		Orange: Test output terminal being used
		Black: Unused
6	Unit Information	Displays information on the displayed safety input unit.
7	×	Closes the safety input unit monitor.

Variable Information


Displays detailed information on the variable.



No.	Item	Description
1	Variable Information	Displays detailed information on the variable.
2	Close	Closes Variable Information.

Search Variable

Searches for a variable.



No.	Item	Description
1	Variable Name	Sets the name of the variable to search.
2	Туре	Selects the type of variables to search.
3	Search	Performs the search.
4	Close	Closes the search.

Search operation specifications

- For the name of variables, only items that exactly match are searched.
- When Output from Safety CPU is set in Type, search is performed in order of the items displayed in Output from Safety CPU from the top.
- · When Input to Safety CPU is set in Type, inputs related to Input to Safety CPU are searched in order of the displayed outputs from the top. Inputs related to a single output are searched in order of the display from the top.

PDF Display

Displays the files set in PDF Display Settings on the Document Viewer in Windowed mode. The Document Viewer closes when the Safety Monitor is exited.


Menu

The following three functions can be executed from the menu.

- · Device Selection
- PDF Display Settings
- · Variables Display Filter Settings

Device Selection


Specify the device to be monitored.



No.	Item	Description
1	Device List	Displays a list of the devices that can be selected.
2	Change	Sets the selected device as the target of monitoring.
3	Cancel	Closes Device Selection.

PDF Display Settings

Specify the files to be displayed in PDF Display.



No.	Item	Description
1	Media Settings	Specifies the location where files are saved. For FTP Server
		settings, inquire to the server administrator.
2	Folder Name	Displays the name of the folders displayed in File List.
3	File List	Displays a list of folders and files included in the folder.
4	Update	Updates the folder name and file list to the latest state.
5	Open	Opens the selected file as a configuration file and copies the
		specified file to the SD memory card installed on the NA unit.
6	Cancel	Closes PDF Display Settings.

· Specifications of configuration files

Specifications of configuration files are shown below.

File Name: [Any file name that can be recognized by Windows].ini


File format: UNICODE TEXT Character code: UTF-16(LE) Delimiter: Tab (0x0900)

Elements of each column are shown below. Rows including the initial row are handled as data and up to 16 rows are loaded.

Column Number	Item	Description
1	PDF File Name	Specifies the name of the PDF file to be displayed. Extensions cannot be omitted.
		If this column is omitted, it causes an error.
2	Target Controller Name	Specifies the name of the controller for which the specified PDF file is displayed.
		If this column is omitted, it causes an error.
3	Safety Signature	Specifies the safety signature for the safety controller connected to the controller specified in Target Controller Name.
		When a value is set in this column, the set value and the safety signature for the safety controller to be displayed must match in order to execute PDF Display. When this column is omitted, PDF Display is executed unconditionally.

Display Filter Settings


Specify the variables not to be displayed on the Safety Monitor.



No.	Item	Description
1	Output from Safety CPU	Changes the variables displayed in Variables List to outputs.
2	Variables List	Displays a list of applicable variables as well as comments. Deselected variables are not displayed on the Safety Monitor.
3	OK	This button applies the settings.
4	Cancel	Discards the settings.
5	Input to Safety CPU	Changes the variables displayed in Variables List to inputs.

4-4-12 Date & Time Settings (Device System Menu)


You can use the date & time settings to set the following items.



No.	Item	Description
(a)	Time Zone	Sets the time zone.
(b)	Automatically adjust clock for	Select this check box to automatically compensate for daylight sav-
	DST	ing time.
(c)	Interval	Sets the interval for synchronizing with the NTP server.
(d)	NTP Server	Sets the IP address of the NTP server.
(e)	Synchronize with an Internet time	Select this check box to synchronize the time with a time server.
	server	
(f)	Current Local Time	Sets the current time.

4-4-13 Language Settings (Device System Menu)

You can use the language settings to set the following items.




No.	Item	Description
(a)	System Menu Language	Sets the system language. The language settings made from the
		Project System Menu take priority.

4-4-14 Interface Settings (Device System Menu)

You can use the interface settings to set communications for the NA Unit.


From the Interface Settings Screen, you can tap any of the icons for settings to display the individual setting screens.



No.	Item	Description
(a)	Ethernet	Sets the IP address of the NA Unit and other settings.
(b)	Serial	Makes settings for the serial port.
(c)	FTP	Makes settings for the FTP server.
(d)	VNC	Makes settings for VNC.
(e)	FINS	Makes settings for FINS.

Ethernet


This screen is used to set the Ethernet port IP address and other settings for Ethernet.



No.	Item	Description
(a)	Ethernet Port 1 Settings	Sets the IP address and other settings for Ethernet port 1.
(b)	Ethernet Port 2 Settings	Sets the IP address and other settings for Ethernet port 2. This setting is ignored if you select the <i>Ethernet Direct Connection</i> Check Box.
(c)	Ping Test	Executes a ping test for the specified address.

FTP

This screen is used to make settings for the FTP server.




No.	Item	Description
(a)	Enable FTP server	Select this check box to use the FTP server.
(b)	Change Account Setting	Select this check box to change the account.
(c)	Login Name	Sets the login name.
(d)	Password	Sets the password.

VNC


This screen is used to make settings for VNC.

• VNC Settings (1/2)



No.	Item	Description
(a)	Enable VNC Server	Select this check box to use the VNC.
(b)	Port No.	Sets the port number.
(c)	Mode	Sets the mode.
(d)	Change Password	Select this check box to change the password.
(e)	Password	Sets the password.


• VNC Settings (2/2)



No.	Item	Description
(a)	Enable registered client login	Select this check box to set login restrictions.
(b)	List of clients	Lists the clients registered at present.
(c)	/	Edits the selected client.
(d)	Ī	Deletes the selected client.
(e)	+	Adds a new client.
(f)	IP Address	Sets the IP address of a client.
(g)	MAC Address	Sets the MAC address of a client.
(h)	Comment	Sets a comment for a client.

FINS


This screen is used to make settings for FINS.



No.	Item	Description
(a)	Ethernet Port 1 Settings	Sets the FINS network address for Ethernet port 1.
		The node address is automatically created based on the IP address.
(b)	Ethernet Port 2 Settings	Sets the FINS network address for Ethernet port 2.
		The node address is automatically created based on the IP address.
(c)	FINS/UDP Port No.	Displays the FINS/UDP port number.

Serial Port Settings


This screen is used to make settings for the serial port.



No.	Item	Description
(a)	Purpose	Displays the application of the serial port.
(b)	Communication speed	Displays the communications speed of the serial port.
(c)	Data bits	Displays the data bits for when communicating with the serial port.
(d)	Stop bits	Displays the stop bits for when communicating with the serial port.
(e)	Parity	Displays the parity for when communicating with the serial port.

4-4-15 Brightness Settings (Device System Menu)

You can use the brightness settings to set the following items.




No.	Item	Description
(a)	Brightness	Sets the screen brightness.

4-4-16 Transfer Operations (Device System Menu)

This screen is used to transfer the project and other data.


You can tap any of the icons for settings to display the individual setting screens.



No.	Item	Description
(a)	Transfer User Program to HMI	Downloads the project.
(b)	Transfer User Program from HMI	Uploads the project.
(c)	Transfer Data to HMI	Downloads various types of data.
(d)	Transfer Data from HMI	Uploads various types of data.

Transfer User Program to HMI


This screen is used to download the project from an SD Memory Card or USB Memory Device.



No.	Item	Description
(a)	Source Media	Sets the media that contains the project to download.
(b)	Path	Displays the path of the folder displayed at (c).
(c)	Folder Contents	Displays the files and folders in the currently open folder.
(d)	Compare with HMI	Compares between the selected project and the HMI.
(e)	Transfer to HMI	Downloads the selected project to the HMI.

Transfer User Program from HMI

This screen is used to upload the project to an SD Memory Card or USB Memory Device.



No.	Item	Description
(a)	Destination Media	Sets the media to which to upload the project.
(b)	Path	Displays the path of the folder displayed at (c).
(c)	Current Folder	Displays the files and folders in the currently open folder.
(d)	Destination File	Sets the file name.
(e)	Transfer from HMI	Uploads the selected project from the HMI to the destination media.




Precautions for Correct Use

Projects that are downloaded with Sysmac Studio version 1.10 and projects that are downloaded when the *Transfer source code to the NA device* Check Box is not selected cannot be read by the Sysmac Studio.

You can use projects like these (i.e., projects that do not contain the source code) to create duplicates of the NA Unit with the same project or as backups to restore the NA Unit without using a computer if the NA Unit fails.

Transfer Data to HMI


This screen is used to download text, videos, or other data from an SD Memory Card or USB Memory Device.



No.	Item	Description
(a)	Data Type	Sets the file type. Only files with the specified file type are displayed
		at (c).
(b)	Transfer to HMI	Downloads the data.
(c)	Current Folder	Displays the files and folders in the currently open folder.
(d)	Path	Displays the path of the folder displayed at (c).
(e)	Media	Sets the media that contains the data to download.

Transfer Data from HMI

This screen is used to upload recipes, videos, or other data to an SD Memory Card or USB Memory Device.




No.	Item	Description	
(a)	Media	Sets the media to which to upload the data.	
(b)	Path	Displays the path of the folder displayed at (c).	
(c)	Destination Folder	Displays the files and folders in the currently open destination folder.	
(d)	File Name	Sets the name of the file at the destination.	
(e)	Transfer from HMI	Uploads the data.	
(f)	Target Files	Displays a list of the files that you can upload.	
(g)	Data Type	Sets the file type. Only files with the specified file type are displayed	
		at (c) and (f).	

Hardware Diagnostics (Device System Menu) 4-4-17

This screen is used to check the operation of the touch panel and to calibrate it.


You can tap any of the icons to access a function.



No.	Item	Description
(a)	Function Keys	Checks the operation of the function keys.
(b)	Production Information	Displays product information.
(c)	LCD Display	Displays a color bar to use to check the LCD.
(d)	Touch Panel Calibration	Calibrates the touch panel.
(e)	Touch Panel Input	Checks touch panel inputs.


Function Keys

This screen is used to check the operation of the function keys.



Production Information


This screen displays product information.



LCD Display


A color bar is displayed. Use this to check the LCD.

Tap the screen to move to the next display.



Touch Panel Calibration


This screen is used to calibrate the touch panel. Tap the plus signs that are displayed. To cancel, double-tap any position.



Touch Panel Input


The locations that are touched are displayed as dots. Use this to check the operation of the touch panel.

To end, double-tap any position.



4-4-18 Production Information (Device System Menu)

This screen displays product information.





Troubleshooting

This section describes troubleshooting methods for errors that may occur in the NA-series Programmable Terminal.


5-1	Operat	tion after an Error	5-2
	5-1-1	Checking NA Unit Status	5-2
	5-1-2	Fatal Errors in the NA Unit	5-3
	5-1-3	Nonfatal Errors in the NA Unit	5-4
5-2	Troubleshooting 5-		5-5
	5-2-1	Confirming NA Unit Operation	5-5
	5-2-2	Correcting Fatal Errors in the NA Unit	5-6
	5-2-3	Troubleshooting Non-fatal Errors	5-6
	5-2-4	Causes and Correction When You Cannot Go Online from the Sysmac Studio	. 5-7
	5-2-5	Troubleshooting NA Unit Errors	5-12

Operation after an Error

This section describes the error status of the NA-series Programmable Terminal and the operation that occurs after an error is detected. Refer to 5-2 Troubleshooting on page 5-5 for details on corrections for specific errors.

5-1-1 **Checking NA Unit Status**

You can check the operating status of an NA Unit with the RUN indicator on the right side of the front panel.



RUN indicator		Status	
Status	Color	- Status	
Not lit.		Power is not correctly supplied to the NA Unit.	
Lit.	Green	The NA Unit is operating normally.	
Lit.	Red	A fatal error ^{*1} occurred in the NA Unit.	
		Refer to 5-1-2 Fatal Errors in the NA Unit on page 5-3 for details.	
Flashing.	Red	A nonfatal error*1 occurred in the NA Unit.	
		Refer to 5-1-3 Nonfatal Errors in the NA Unit on page 5-4 for details.	

^{*1.} An error is any status in which normal operation is not performed. Errors include hardware problems, system program crashes, and user data errors.

5-1-2 Fatal Errors in the NA Unit

Fatal Errors in the NA Unit

Some errors are fatal and prevent the NA Unit from operating. This section describes these fatal errors, which cause the operation of the NA Unit to stop.

- If any of the following errors occur, the Sysmac Studio cannot go online with the NA Unit and communications connections with connected devices are not possible.
 - · Power Supply Error

Power is not supplied, the voltage is outside of the allowable range, or the power supply section is faulty.

- · Hardware Error
 - A hardware error is any hardware problem except those in the power supply.
- System Program Error
 The system program is corrupted and normal operation is not possible.
- If any of the following errors occur, the Sysmac Studio can go online with the NA Unit, but communications connections with connected devices are not possible.
 - Runtime Error

The middleware that executes the project is not operating normally.

· Project Error

There is a fatal error in the project, so normal operation is not possible.

5-1-3 Nonfatal Errors in the NA Unit

Nonfatal Errors in the NA Unit

If there are no problems in the hardware or system program, the NA Unit will operate even if one of these errors occurs. This section describes nonfatal errors.


- If any of the following errors occur, the Sysmac Studio can go online with the NA Unit, but communications connections with connected devices are not possible.
 - · Tag Verification Error
 - The tags registered in the NA Unit do not agree with the tags registered in the connected device.
 - Connected Device Communications Error Normal communications are not possible with a connected device.
- If any of the following errors occur, the Sysmac Studio can go online with the NA Unit and communications connections with connected devices are possible.
 - · Low Battery Voltage The voltage of the Battery has decreased.
 - SD Memory Card or USB Memory Device Error There is an error in the SD Memory Card or USB Memory Device inserted in the NA Unit.

5-2 Troubleshooting

This section provides basic error identification, troubleshooting flowcharts, and error corrections. Use them when an error occurs in the NA Unit.

5-2-1 Confirming NA Unit Operation

When an error occurs in the NA Unit, use the following flowchart to determine whether the error is a fatal error or a non-fatal error.



Correcting Fatal Errors in the NA Unit 5-2-2

Power Supply Error

Check the following items:

- Is the NA Unit correctly connected to the external DC power supply?
- Is the voltage supplied from the external DC power supply within the allowable range?

Hardware Error

Turn OFF the power supply, disconnect all devices connected to the NA Unit, and then turn the power supply back ON. If the NA Unit operates normally, the cause of the error is in a disconnected

System Program Error

Execute system recovery.

Runtime Error

Download the project again. If you cannot download the program, execute system recovery.

Project Error

Download the project again.

If you confirmed that there are no problems with the above items and the NA Unit still does not operate normally, inquire at the contact given on the back of this manual.

5-2-3 **Troubleshooting Non-fatal Errors**

Tag Verification Error

Match the tags registered in the NA Unit with the tags registered in the connected device.

Connected Device Communications Error

- · Check the HMI Settings and connected device settings to see if they allow normal communica-
- If a router or other network devices are installed, check the settings of the router or other network devices to see if they allow normal communications.
- If a connected device uses data links, check to see if the processing capacity of the connected device and the network band are sufficient to handle them.
- If a connected device is set to Secure communication, use Runtime Ver.1.16 or later.
- · If a connected device has Packet Filter set, check the settings to see if they allow communication with the HMI.

Low Battery Voltage

Replace the Battery.

Minor Project Error

Download the project again.

SD Memory Card or USB Memory Device Error

Replace the SD Memory Card or USB Memory Device with a normal one.

5-2-4 Causes and Correction When You Cannot Go Online from the Sysmac Studio


The following table lists the possible causes when you cannot go online with the NA Unit from the Sysmac Studio.

Cause	Description	Correction
Incorrect settings or faulty communications path	There is a mistake in the settings that the Sysmac Studio uses to go online with the NA Unit. Or, the communications path is faulty.	Refer to <i>Troubleshooting Incorrect Settings</i> and Faulty Communications Path on page 5-8.
Fatal Errors in the NA Unit	A fatal error occurred in the NA Unit.	Refer to 5-2-1 Confirming NA Unit Operation on page 5-5.
High load on the NA Unit	The load on the NA Unit is too high and time cannot be obtained to connect with the Sysmac Studio.	Execute system recovery, reduce the project load, and then download the project again.


Troubleshooting Incorrect Settings and Faulty Communications Path

This section provides troubleshooting methods for incorrect settings, fault communications paths, and high NA Unit loads.


Direct Connection with USB Port




Ethernet – Direct Connection



Ethernet – Hub Connection





Troubleshooting NA Unit Errors 5-2-5

This section describes how to troubleshoot errors in the NA Unit.

NA Unit Startup

NA Unit symptom	Cause	Correction
The indicator does not	Power is not supplied.	Confirm the connection location and correctly supply
light.		power.
	The supplied voltage is	Check the supplied voltage and supply the correct volt-
	outside the allowable	age.
	range.	
	The power supply fuse	The NA Unit needs to be repaired. Inquire at the con-
	has burnt out.	tact given on the back of this manual.
	There is an error in the	The NA Unit may be faulty. Inquire at the contact given
	power supply section.	on the back of this manual.
	The brightness of the	Increase the screen brightness setting in the project
	screen has decreased.	and download the project again.
The indicators light red	The system program is	Execute system recovery. If the problem recurs after
and nothing is displayed	corrupted. (This is a fatal	you execute system recovery, inquire at the contact
on the screen.	error.)	given on the back of this manual.
	There is a problem with	Disconnect all devices except for the power supply and
	the connected device.	restart the NA Unit. If the NA Unit starts normally, con-
		nect one device at a time and restart the NA Unit each
		time to see which device is causing the problem.
The indicators light red	The runtime middleware is	Execute system recovery. If the problem recurs after
and an initialization mes-	corrupted.	you execute system recovery, inquire at the contact
sage is displayed on the		given on the back of this manual.
screen.		
The indicators light red	Initializing runtime middle-	Download the project again and update the runtime
and an initialization failed	ware failed.	middleware. If the problem recurs after the download,
message is displayed on		execute system recovery.
the screen.	T	D 1 10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
The indicators light red	The project is corrupted.	Download the project again. If the problem recurs after
and an error dialog box		the download, execute system recovery.
with a blue title bar is dis-		
played.	Chartery failed	Restart the NA Unit.
The indicators light red and normal operation is	Startup failed.	Restart the NA Unit.
performed.		
The indicators flash red	The tage registered in the	Motob the tage in the NA I Init with the tage registered.
and <i>E_COM_002: Tag</i>	The tags registered in the NA Unit do not agree with	Match the tags in the NA Unit with the tags registered in the connected device.
comparison error with xxx	the tags in the connected	
error message is dis-	device.	Match the unit version of the connected device and
played.	GOVICE.	the set unit version.
piayou.		

Errors during NA Unit Operation

• Errors Determined from NA Unit Symptoms

The indicators light red and operation stops. The indicators flash red and the SD Memory Card or USB Memory Device cannot be accessed. Memory Device. The screen is too dark. The touch panel does not respond. The touch panel is broken. The display is dark. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The indicators flash red and operation stops. The indicators flash red and operation stops. The re is not enough memory. Change the project to reduce memory usage. Replace the SD Memory Card or USB Memory Device in the NA Unit with a normal one. Replace the SD Memory Card or USB Memory Device in the NA Unit with a normal one. This is not an error. Touch the screen or press a function key. The Backlight has failed. The Backlight has failed. The touch panel does not respond. The touch panel is broken. The touch panel is broken. The screen is too dark. Separate the brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. Separate the number of objects on the screens for which refreshing is slow. There is a heavy processing load on the consciplination of the connected device.
The indicators flash red and the SD Memory Card or USB Memory Device cannot be accessed. Nothing is displayed on the screen. The Backlight has failed. The screen is too dark. The touch panel does not respond. The touch panel is broken. The display is dark. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The indicators flash red and the SD Memory Card or USB Memory Device in the NA Unit with a normal one. Replace the SD Memory Card or USB Memory Device in the NA Unit with a normal one. Replace the SD Memory Card or USB Memory Device in the NA Unit with a normal one. Replace the SD Memory Card or USB Memory Device in the NA Unit with a normal one. This is not an error. Touch the screen or press a function key. The Backlight has failed. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. Reset the NA Unit and then implement noise countermeasures in the wiring. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. * Increase the brightness of the screen in the brightness setting on the System Menu. * Increase the brightness of the screen in the brightness setting on the System Menu. * Increase the brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Communications are not stable due to external noise. There are too many objects. There are too many objects. There is a heavy process- Reduce the SD Memory Device. This is not an error. Touch the screen or press a function key. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. * Increase the brightness setting in the project and download the project again. The Backlight needs to be replaced. * Increase the brightness setting in the project and download the project again. * Increase the brightness setting in
and the SD Memory Card or USB Memory Device cannot be accessed. Nothing is displayed on the screen. The Backlight has failed. The screen is too dark. The touch panel does not respond. The touch panel is broken. The touch panel is broken. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The manual memory Device. SD Memory Card or USB Memory Device. In the NA Unit with a normal one. In the NA Unit with a normal one. In the NA Unit with a normal one. This is not an error. Touch the screen or press a function key. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. Reset the NA Unit and then implement noise countermeasures in the wiring. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Communications are not stable due to external noise. There are too many objects. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
Card or USB Memory Device cannot be accessed. Nothing is displayed on the screen. The screen saver was activated. The Backlight has failed. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The touch panel does not respond. The touch panel is broken. The display is dark. The screen is too dark. The screen is too dark. The touch panel is broken. The touch panel is broken. The backlight has failed. The touch panel is broken. The touch panel is broken. The backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The screen is too many objects. The screen saver was activated. The screen is too dark. The Backlight needs to be replaced. Inquire at the contact given on the System Menu. Increase the Na Unit and then implement noise countermeasures in the wiring. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. Increase the screen brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. Separate the communications cables from power lines and perform other noise countermeasures. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
Device cannot be accessed. Nothing is displayed on the screen. The screen saver was activated. The Backlight has failed. The screen is too dark. The touch panel does not respond. The touch panel is broken. The backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The screen is aver was activated. The screen saver was activated. The screen is too dark. The Backlight has failed. The Backlight is faulty or has reached the end of its life. The Backlight is faulty or has reached the end of its life. There are too many objects. There is a heavy process- This is not an error. Touch the screen or press a function key. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The screen is too dark. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. Separate the number of objects on the screens for which refreshing is slow. There are too many objects. There are too many objects. There are too many objects. There are too many object the connected device.
Accessed. Nothing is displayed on the screen. The Backlight has failed. The Backlight has failed. The screen is too dark. The screen is too dark. The touch panel does not respond. The touch panel is broken. The touch panel is broken. The backlight has failed. The screen is too dark. The touch panel is broken. The backlight has failed. The screen is too dark. The backlight has failed. The screen is too dark. The screen is too dark. The touch panel does not respond. The touch panel is broken. The touch panel is broken. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The screen is a heavy process- There is a heavy process- The screen is too dark. This is not an error. Touch the screen or press a function key. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. Separate the number of objects on the screens for which refreshing is slow. There is a heavy process- There are too many objects. There is a heavy process- There are too many object is an error. Touch the screen or press a function key. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures.
Nothing is displayed on the screen. The screen saver was activated. The Backlight has failed. The screen is too dark. The touch panel does not respond. The touch panel is broken. The touch panel is broken. The display is dark. The screen is too dark. The screen is too dark. The screen is too dark. The backlight needs to be replaced. Inquire at the contact given on the back of this manual. Reset the NA Unit and then implement noise countermeasures in the wiring. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. There are too many objects. There is a heavy process- This is not an error. Touch the screen or press a function key. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures. There are too many objects. There are too pany objects. Reduce the cycle time of the connected device.
the screen. activated. The Backlight has failed. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The screen is too dark. Increase the screen brightness setting in the project and download the project again. External noise caused a malfunction.
The Backlight has failed. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The screen is too dark. Increase the screen brightness setting in the project and download the project again. Reset the NA Unit and then implement noise countermeasures in the wiring. The touch panel is broken. The touch panel is broken. The display is dark. The screen is too dark. The screen is too dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. There are too many objects. There is a heavy process- The Backlight has failed. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. There are too many objects. Reduce the cycle time of the connected device.
tact given on the back of this manual. The screen is too dark. The touch panel does not respond. External noise caused a malfunction. The touch panel is broken. The touch panel is broken. The display is dark. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. There are too many objects. There are too many objects. The touch panel is too dark. The screen is too dark. The screen is too dark. The screen is too dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. There is a heavy process- There is a heavy process- The screen is too dark. Increase the NA Unit and then implement noise countermeasures. Reset the NA Unit and then implement noise countermeasures in the wiring. The Such Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the NA Unit and then implement noise countermeasures in the wiring. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the System Menu. Increase the brightness of the screen in the brightness setting in the project and download the project again. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. There is a heavy process-
The screen is too dark. The touch panel does not respond. External noise caused a malfunction. The touch panel is broken. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The screen is too dark. The screen is too dark. The screen is too dark. The packlight is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the end of its life. The pack light is faulty or has reached the project again. The pack light is faulty or has reached the project and download the project again. The pack light is faulty or has reached the project and download the project a
The touch panel does not respond. External noise caused a malfunction. The touch panel is broken. The display is dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The touch panel is broken. The touch panel is broken. External noise caused a malfunction. The touch panel is broken. The touch panel is broken. The touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
The touch panel does not respond. External noise caused a malfunction. The touch panel is broken. The touch panel is broken. The display is dark. The acreen is too dark. Numbers or characters are refreshed too slowly. The touch panel is broken. External noise caused a malfunction. The touch panel is broken. The touch panel is broken. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Separate the communications cables from power lines and perform other noise countermeasures. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. There is a heavy process- Reduce the cycle time of the connected device.
not respond. malfunction.
The touch panel is broken. Use the Touch Panel Input Icon on the System Menu to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. The display is dark. The screen is too dark. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The Backlight is faulty or has reached the end of its life. Decrease the communications cables from power lines and perform other noise countermeasures. Separate the communications cables from power lines and perform other noise countermeasures. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
to test the touch panel. If an error is found, inquire at the contact given on the back of this manual. The display is dark. The screen is too dark. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. Separate the communications cables from power lines and perform other noise countermeasures. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
the contact given on the back of this manual. The display is dark. The screen is too dark. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
The display is dark. The screen is too dark. Increase the brightness of the screen in the brightness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
ness setting on the System Menu. Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- Reduce the screen brightness setting in the project and download the project again. The Backlight needs to be replaced. Inquire at the contact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. Reduce the cycle time of the connected device.
Increase the screen brightness setting in the project and download the project again. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- There are too slowly process- There are too brightness setting in the project and download the project again. The Backlight needs to be replaced. Inquire at the contact tact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. Reduce the cycle time of the connected device.
And download the project again. The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- The Backlight needs to be replaced. Inquire at the contact tact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. Reduce the cycle time of the connected device.
The Backlight is faulty or has reached the end of its life. Numbers or characters are refreshed too slowly. The Backlight is faulty or has reached the end of its life. Communications are not stable due to external noise. There are too many objects. There is a heavy process- Reduce the events to be replaced. Inquire at the contact tact given on the back of this manual. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. Reduce the cycle time of the connected device.
has reached the end of its life. Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- Reduce the cycle time of this manual. Separate the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. Reduce the cycle time of the connected device.
Numbers or characters are refreshed too slowly. Communications are not stable due to external noise. There are too many objects. There is a heavy process- Reduce the communications cables from power lines and perform other noise countermeasures. Decrease the number of objects on the screens for which refreshing is slow. Reduce the cycle time of the connected device.
are refreshed too slowly. stable due to external noise. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
are refreshed too slowly. stable due to external and perform other noise countermeasures. There are too many objects. There is a heavy process- Reduce the cycle time of the connected device.
There are too many objects. Decrease the number of objects on the screens for which refreshing is slow. There is a heavy process- Reduce the cycle time of the connected device.
objects. which refreshing is slow. There is a heavy process- Reduce the cycle time of the connected device.
There is a heavy process- Reduce the cycle time of the connected device.
ing load on the con-
nected device that is
resulting in extended
cycle times.
The message communi- cations interval is too Shorten the refreshing interval of the variable that is allocated to the object.
cations interval is too allocated to the object.
Gauges are refreshed Too many objects overlap If multiple images are stacked behind the gauges, put
too slowly. the gauges. them together in a single image.
Lay out the gauges so that they do not overlap with
other objects.
Some of the objects on The IsVisible Check Box Select the IsVisible Check Box in the object properties
the screen are not dis- is not selected in the on the Sysmac Studio.
played. object settings. If you change the <i>IsVisible</i> property, e.g., from a sub-
routine, set it to True.
The trend graph dis- The communications Increase the ON/OFF interval for the communications
play does not match address that is set as the address used as the event.
the actual log timing. event for the log timing is
turning ON and OFF at a
high speed.

NA Unit symptom	Cause	Correction
Numeric values cannot	The upper/lower limit	Check the Minimum Value and Maximum Value proper-
be input.	check for numeric inputs	ties of the object on the Sysmac Studio and correct
	is operating.	them as required.
When an object is	A communications error	Check the connection between the NA Unit and con-
touched, nothing is	occurred.	nected device.
input or executed.	The IsEnabled Check Box	Select the IsEnabled Check Box in the object proper-
	is not selected in the	ties on the Sysmac Studio.
	object settings.	If you change the <i>IsEnabled</i> property, e.g., from a sub-
		routine, set it to True.
	Security is set.	Log in at a level where the operation is allowed.
Operation is not possi-	The NA Unit is in Input	Use the EnableInputOperation function or EnableInput-
ble for all objects.	Prohibited Mode.	Operation action to enable the inputs that are currently
		prohibited.
		Log in at a level where input is allowed.
The NA Unit will not	The currently logged in	Go to the System Menu and log in as a level that has
change to the System	user does not have per-	permission to display the System Menu.
Menu.	mission.	

• Errors Determined with Messages

Output message	Cause	Correction
E_COM_100, E_COM_101, E_COM_102, or E_COM_103: Failed to read the data (XXX). E_COM_200, E_COM_201, E_COM_203: Failed to write the data (XXX). E_COM_001: Failed to connect to XXX - XXX (XXX).	Normal communications are not possible with a connected device XXX. The connected device XXX could not respond to and communicate with the NA Unit within the timeout period due to a high load or the like. The project information on the connected device XXX has been updated. A connection with the HMI is not allowed in the Packet Filter function on the connected device XXX. The connected device XXX is set to Secure communication.	 Confirm that power is turned ON to the connected devices and network devices. Confirm that the NA Unit, connected devices, and network devices are connected correctly. Check the communications settings between the NA Unit and connected device. Confirm that the tag settings for the NA Unit and for the connected device are correct, and verify the tags again. Extends the timeout period of the connected device with referring to the reference manual for the device. Allow communication with the NA Unit in the Packet Filter function of the connected device. Use Runtime Ver.1.16 or later which supports secure communication. Transfer the project again to the connected device and NA Unit. If the problem is not resolved even after transfer, replace the connected device.

Output message	Cause	Correction
E_COM_002: Tag comparison error with xxx.	The tag specified for the project and the tag for the connected device XXX do not match.	 Confirm that the tag settings for the NA Unit and for the connected device are correct, and verify the tags again. If you connect an NA-series Programmable Terminal with an NJ/NX/NY-series Controller, match the set unit version with the unit version of the CPU Unit. When connected with CS/CJ/CP via FINS Ethernet or Host Link, correct the format of the assignment destination of the device variable to the correct format. Check whether or not the address of the assignment destination is an address that can be accessed by a connected device.
E_SYS_002: XXX XXX is low on available free space E_SYS_003: XXX XXX is very low on available free space	There is not sufficient space available on the SD Memory Card or in the USB Memory Device.	Replace the SD Memory Card or USB Memory Device with one with sufficient available space.
E_SYS_004: Storage media XXX not found. Check if the storage media is inserted.	The specified SD Memory Card or USB Memory Device is not inserted in the NA Unit.	Insert an SD Memory Card or USB Memory Device into the NA Unit.
E_SYS_010: The asynchronous call has been rejected because the request queue is full.	The number of asynchronous subroutines to be executed simultaneously exceeded the upper limit (105).	 Decrease the number of the asynchronous subroutines to be executed simultaneously. Specify the timing for the asynchronously executed subroutines.
E_SYS_015: The battery voltage is low.	The battery voltage has lowered less than the specified value during operation.	Replace the battery following the procedure given in 6-2 Replacing the Battery on page 6-5
E_SYS_019: XXX must be behind XXX.	The filtering conditions for the Alarm Viewer were mistakenly specified.	Check the set values of the EndTime and StartTime parameters and the filtering conditions in the FilterBy-DateTime function.
E_LOG_001: Backup to MRAM has failed for XXX	The M-RAM cannot be written normally.	Restart the NA Unit. If the same message is displayed after the restart, execute system recovery. If the same message is displayed even after system recovery, the
E_LOG_002: Failed to recover data from MRAM for XXX. All the data within MRAM have been cleared.	The XXX data on the M-RAM is in an illegal state.	NA Unit must be repaired. Inquire at the contact given on the back of this manual.
E_LOG_003: Failed to backup Alarms to MRAM.	The M-RAM cannot be written normally.	
E_LOG_004: Failed to recover Alarms from MRAM. All the data within MRAM have been cleared.	The alarm data on the M-RAM is in an illegal state.	
E_LOG_005: Failed to write XXX records to file: XXX E_LOG_007: Failed to create log file for XXX	Logging the data failed.	 Insert an SD Memory Card or USB Memory Device into the NA Unit. Replace the SD Memory Card or USB Memory Device with one with sufficient available space. If the same message is displayed even if you perform
		the above corrections, try replacing the SD Memory Card or USB Memory Device.

E_LOG_006: Logging failed. Illialization for data logging failed. Restart the NA Unit. If the same message is displayed after the restart, execute system recovery, the NA Unit must be repaired. Inquire at the contact given on the back of this manual. E_MED_001: The format of the video file has an unsupported format or is in an illegal state. E_MED_003: Failed to play the video (0xXXXXXXXX). E_MED_005: Failed to stop the video (0xXXXXXXXXX). E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player Check if the video file exists and its formal is supported. E_RCP_001: Failed to initialise the media player Check if the video flee exists and its formal the support exists. E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player XXX. E_MED_007: Failed to initialise the media player XXX. E_MED_007: Failed to initialise the media player Check if the video file exists and its formal is supported. E_RCP_001: Failed to make the video file exists and its formal to supported. E_RCP_001: Failed to initialise the media player XXX. E_SYS_999: Runtime Exception Caught XXX. E_SEC_001: Invalid for User XXX or password. E_SEC_002: Detected The user determined to use permission that is invalid for User XXX under the current HMI settlings. E_SEC_003: Login blocked for 10 minutes. Incorrect passwords were blocked for 10 minutes. Incorrect passwords were blocked for 10 minutes. Incorrect passwords were occurred while evaluating expression for an object. An invalid expression is on object. If you use an array variable for expressions.	Output message	Cause	Correction
E_MED_001: The format of the video file has an unsupported format or is unant of the video file kax xx used in XxX is not supported. E_MED_003: Failed to play the video (0xXXXXXXXXX). E_MED_006: Failed to pause the video (0xXXXXXXXXXX). E_MED_006: Failed to stop the video (0xXXXXXXXXXX). E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_SCE_002: Detected permission that is invalid for User XXX under the user does not have permission that is invalid for User XXX under the user does not have permission that is invalid for User XXX under the user does not have permission that is invalid for User XXX under the user does not have permission that is invalid for User XXX under the user does not have permission that is invalid expression for action XXX of object. E_PAG_007: Error occurred while evaluating expression for action XXX of object. An invalid expression is set for the expression is object. An invalid expression is an object. An invalid expression is on object. If you use an array variable for expressions. If you use an array variable for expressions.	E_LOG_006: Logging	Initialization for data log-	Restart the NA Unit. If the same message is displayed
E_MED_001: The format of the video file with the video file with the video file with the video file bas an unsupported format or is supported. E_MED_003: Failed to play the video (0xXXXXXXXXX) E_MED_005: Failed to play the video (0xXXXXXXXXX) E_MED_005: Failed to play the video (0xXXXXXXXXX) E_MED_007: Failed to initialise the media player XXX. A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Walt for 10 minutes and then try to log in again. Log in as a user that has permission set for the object. Log in as a user that has permission set for the object. Log in as a user that has permission set for the object. Incorrect passwords were blocked for 10 minutes. Log in as a user that has permission set for the object. An invalid expression is unsiston. Incorrect passwords were consecutively entered on an object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.	for XXX has been	ging failed.	after the restart, execute system recovery. If the same
E_MED_001: The format of the video file has an unsupported format or is supported. E_MED_003: Failed to play the video (0xXXXXXXXXX). E_MED_004: Failed to pause the video (0xXXXXXXXXX). E_MED_005: Failed to stop the video (0xXXXXXXXXX). E_MED_006: Unexpected error in media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_SYS_999: Runtime Exception Caught XXX. E_SYS_999: Runtime Exception Caught XXX. E_SEC_001: Invalid User XXX under the current HMI settings. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error oaction XXX of object XXX on page XXX. E_PAG_010: Error oaction XXX of object An invalid expression is at for the expression for an object. An invalid expression is expression for an object. An invalid expression is at for the expression for an object. * Please check the syntax to set for expressions.	stopped		
E_MED_001: The format of the video file with the video file with the video file with the video file with the video flow with the video flow video (0xXXXXXXXXX). E_MED_003: Failled to play the video (0xXXXXXXXXX). E_MED_006: Failled to play the video (0xXXXXXXXXX). E_MED_007: Failled to play the video (0xXXXXXXXXXX). E_MED_007: Failled to play the video (0xXXXXXXXXXX). E_MED_007: Failled to play the video flow with the video flow with video flow flow with video flow with video flow with video flow flow with video flow flow flow flow			
mat of the video file XXX used in XXX is not supported. E_MED_003: Failed to play the video (0xXXXXXXXX). E_MED_004: Failed to pause the video (0xXXXXXXXX). E_MED_005: Failed to pause the video (0xXXXXXXXX). E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX. E_SYS_999: Runtime Exception Caught XXX. E_SYS_999: Runtime Exception Caught XXX. E_SYS_099: Runtime Exception Caught XXX. E_SYS_000: Detected permission that is invalid to the correct template when you save the recipe. I to go in as a user that has permission set for the object. I to go in as a user that has permission set for the object. I to go in as a user that has permission set for the object. I to go in as a user that has permission set for the object with the caught AxX.			on the back of this manual.
XXX used in XXX is not supported. E_MED_003: Failed to play the video (0xXXXXXXX). E_MED_004: Failed to pause the video (0xXXXXXXX). E_MED_005: Failed to stop the video (0xXXXXXXXX). E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXXX E_SYS_999: Runtime Exception Caught XXXX E_SEC_001: Invalid User XXX vi password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_SEC_003: Login blocked for 10 minutes. E_SEC_007: Error consecutively entered 5 times. E_PAG_007: Error consecutively entered 5 times. E_PAG_007: Error consecutively entered 5 times. An invalid expression is set for the expression for an object. **Please check the syntax to set for expressions.** **If you use an array variable for expression, set the number of elements.**	E_MED_001: The for-		Convert the file to a supported format and download
supported. E_MED_003: Failed to play the video (0xXXXXXXXX). E_MED_004: Failed to pause the video (0xXXXXXXXX). E_MED_005: Failed to stop the video (0xXXXXXXXX). E_MED_006: Unexpected error in media player.XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_001: Invalid User XXX under the current HMI settings. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_001: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for an object of man object. A n invalid expression is set for the expression for an object. **Please check the syntax to set for expressions.** If you use an array variable for expression, set the number of elements.		1	the data again.
E_MED_003: Failed to play the video ((0xXXXXXXXX)). E_MED_004: Failed to pause the video ((0xXXXXXXXX)). E_MED_005: Failed to stop the video ((0xXXXXXXXX)). E_MED_006: Unexpected error in media player. XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX or password. User XXX or password. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. Incorrect passwords were consecutively entered 5 times. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object XXX on page XXX. A n invalid expression is set for the expression for an object. **Please check the syntax to set for expressions.** **Please check the syntax to set for expressions.** **If you use an array variable for expression, summer of elements.**		in an illegal state.	
play the video (0xXXXXXXXX). E_MED_004: Failed to pause the video (0xXXXXXXXX). E_MED_005: Failed to stop the video (0xXXXXXXXX). E_MED_006: Unex- pected error in media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYC_001: Invalid User XXX or password. E_SEC_001: Invalid User XXX under the current HMI settings. The user attempted to use an object for which the user does not have per- mission. E_SEC_003: Cogin blocked for 10 minutes. E_PAG_001: Error occurred while evaluat- ing expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspend- ing action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspend- ing action XXX of object XXX of object An invalid expression is set for the expression for an object. **Please check the syntax to set for expressions, set the number of elements.			
E_MED_004: Failed to pause the video (0xXXXXXXX).			
E_MED_004: Failed to pause the video (0xXXXXXXXX). E_MED_005: Failed to stop the video (0xXXXXXXXXX). E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX. E_SYS_999: Runtime User XXX or password. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX or password. E_SEC_003: Login User XXX under the current HMI settings. E_SEC_003: Login Incorrect passwords were consecutively entered 5 times. E_PAG_001: Error occurred while evaluating expression for action XXX of object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression, set the number of elements.			
pause the video ((0xXXXXXXX) E_MED_005: Failed to stop the video ((0xXXXXXXXX) E_MED_006: Unex- pected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_010: Error coccurred while evaluat- ing expression for action XXX of object An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. Please check the syntax to set for expressions.	<u> </u>		
(0xXXXXXXX). E_MED_005: Failed to stop the video ((0xXXXXXXXX). E_MED_006: Unexpected error in media player. Check if the video file exists and its format is supported. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_SEC_001: Invalid User XXX. or password. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the user does not have permission. E_SEC_003: Login blocked for 10 minutes. E_PAG_001: Error consecutively entered 5 times. E_PAG_007: Error occurred while evaluating expression for action XXX of object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression is set for the expression for an object. * Please check the syntax to set for expressions. * Please check the syntax to set for expressions. * Please check the syntax to set for expressions. * Please check the syntax to set for expressions. * Please check the syntax to set for expressions.			
E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csy file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_010: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression for an object. Please check the syntax to set for expressions.	•		
stop the video ((0xXXXXXXX)). E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player, Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. B_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error coccurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error coccurred while suspending action XXX of object XXX on page XXX. An invalid expression is set for the expression for an object. **Please check the syntax to set for expressions.** **Please check the syntax to set for expr	<u> </u>		
(0xXXXXXXXX). E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csy file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_001: Invalid User XXX or password. The user attempted to use an object for which the user does not have permission that is invalid for User XXX under the current HMI settings. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while evaluating expression for an object. An invalid expression is set for the expression for an object. Please check the syntax to set for expressions.			
E_MED_006: Unexpected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error coccurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error coccurred while evaluating expression for an object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. Please check the syntax to set for expressions.			
pected error in media player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX E_SYS_099: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. Is a consecutive to be used to be used to be used permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error coccurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error coccurred while suspending action XXX of object An invalid expression for an object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. An invalid expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions.	<u> </u>		
player XXX. E_MED_007: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SYS_999: Runtime Exception Caught XXX performed. E_REC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Log in as a registered user. Log in as a user that has permission set for the object. Wait for 10 minutes and then try to log in again. Wait for 10 minutes and then try to log in again. Please check the syntax to set for expressions. Please check the syntax to set for expressions. **Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.			
E_RCP_001: Failed to initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX or page XXX. E_PAG_010: Error occurred while suspending action XXX of object A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template valents is select the valents in save the number of select the NA Unit. Select the correct template when you save the recipe. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the correct template valents is select the NA Unit. Select the Carl valents is valents in valents is select the NA Unit.	•		
initialise the media player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csy file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_001: Invalid User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object XXX of object A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe.	<u> </u>		
player. Check if the video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX performed. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression for action XXX of object An invalid expression is set for the expression is set for the expression for an object. **Please check the syntax to set for expressions.** **If you use an array variable for expression, set the number of elements.**			
video file exists and its format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX. E_PAG_010: Error occurred while suspending action XXX of object. A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe.			
Format is supported. E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX performed. E_SEC_010: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX. E_PAG_010: Error occurred while suspending action XXX of object. A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe. Select the correct template vhen you save the recipe.	• •		
E_RCP_001: Failed to import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX or page XXX. E_PAG_010: Error occurred while suspending action XXX of object A recipe is set incorrectly. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe. Select the correct template when you save the recipe.			
import Recipe csv file XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX or page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression for an object. An invalid expression is set for the expression for an object. Please check the syntax to set for expressions. F Please check the syntax to set for expressions. Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions. F Please check the syntax to set for expressions.			
XXX. Ingredients do not match template XXX. E_SYS_999: Runtime Exception Caught XXX performed. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression for action XXX of object An invalid expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions.		A recipe is set incorrectly.	Select the correct template when you save the recipe.
match template XXX. E_SYS_999: Runtime Exception Caught XXX performed. E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object XXX of object An invalid expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions.	•		
E_SYS_999: Runtime Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object xXX of object xXXX of object xXXX of object ing action XXXX of object action XXXX of object ing action XXX of object ing action XXXX	•		
Exception Caught XXX E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXXX of object action action XXXX of object action action XXXX of object action		Illegal processing was	Doctort the NA Linit
E_SEC_001: Invalid User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression is set for the expression for an object. An invalid expression is set for the expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions.			Restart the NA Offit.
User XXX or password. E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression is set for the expression for an object. Log in as a user that has permission set for the object. Wait for 10 minutes and then try to log in again. Wait for 10 minutes and then try to log in again. Please check the syntax to set for expressions.		l '	Log in as a registered user
E_SEC_002: Detected permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object an object. The user attempted to use an object for which the user does not have permission. Log in as a user that has permission set for the object. Wait for 10 minutes and then try to log in again. Wait for 10 minutes and then try to log in again. Please check the syntax to set for expressions.		_	Log III as a registered user.
permission that is invalid for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression is occurred while suspending action XXX of object Set for the expression for an object. an object for which the user does not have permission. Wait for 10 minutes and then try to log in again. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.			Log in as a user that has permission set for the object
for User XXX under the current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object XXX of object XXX of object An invalid expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.			= = = = = = = = = = = = = = = = =
current HMI settings. E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression is occurred while suspending action XXX of object Set for the expression for an object. Mait for 10 minutes and then try to log in again. Wait for 10 minutes and then try to log in again. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.	•	_	
E_SEC_003: Login blocked for 10 minutes. E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object XXX of object An invalid expression is set for the expression is set for the expression is occurred while suspending action XXX of object An invalid expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions. Please check the syntax to set for expressions. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.	_		
blocked for 10 minutes. E_PAG_007: Error		Incorrect passwords were	Wait for 10 minutes and then try to log in again.
E_PAG_007: Error occurred while evaluating expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object an object. An invalid expression is set for the expression is set for the expression is set for the expression for an object. Please check the syntax to set for expressions. • Please check the syntax to set for expressions. • If you use an array variable for expression, set the number of elements.		•	, , ,
occurred while evaluating expression for an object. Set for the expression for an object. Set for the expression for an object. E_PAG_010: Error occurred while suspending action XXX of object set for the expression is set for the expression for an object. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements.		-	
ing expression for action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object an object. An invalid expression is set for the expression for an object. • Please check the syntax to set for expressions. • If you use an array variable for expression, set the number of elements.	E_PAG_007: Error	An invalid expression is	Please check the syntax to set for expressions.
action XXX of object XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object set for the expression for an object. An invalid expression is set for the expression for an object. • Please check the syntax to set for expressions. • If you use an array variable for expression, set the number of elements.	occurred while evaluat-	set for the expression for	
XXX on page XXX. E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression for an object. • Please check the syntax to set for expressions. • If you use an array variable for expression, set the number of elements.	ing expression for	an object.	
 E_PAG_010: Error occurred while suspending action XXX of object An invalid expression is set for the expression for an object. Please check the syntax to set for expressions. If you use an array variable for expression, set the number of elements. 	action XXX of object		
occurred while suspending action XXX of object set for the expression for an object. • If you use an array variable for expression, set the number of elements.	XXX on page XXX.		
ing action XXX of object an object. number of elements.		An invalid expression is	Please check the syntax to set for expressions.
ing action XXX of object an object. number of elements.	•	set for the expression for	If you use an array variable for expression, set the
	-	T	
XXX on page XXX.	XXX on page XXX.	,	

• Error Codes Correspondence Table

The displayed error codes depend on the runtime version. A correspondence table is given below:

Error codes prior to runtime version 1.03	Error codes for runtime version 1.03 or higher
ManE202	E_COM_100,
	E_COM_101,
	E_COM_102, or
	E_COM_103
ManE203	E_COM_200,
	E_COM_201,
	E_COM_202, or E_COM_203
ManE204	E COM 001
ManW301	E SYS 002
ManW302	E_SYS_003
ManE303	E_SYS_004
ManE304	E_LOG_001
ManE305	E_LOG_002
ManE306	E_LOG_003
ManE307	E_LOG_004
ManE308	E_LOG_005
ManE310	E_LOG_007
ManE309	E_LOG_006
ManE401	E_MED_001
ManE403	E_MED_003
ManE404	E_MED_004
ManE405	E_MED_005
ManE408	E_MED_006
ManE409	E_MED_007
ManE501	E_RCP_001
ManE901	E_SYS_999
ManE101	E_SEC_001
ManE103	E_SEC_002
ManE104	E_SEC_003



Maintenance

This section describes the required inspections and maintenance. It also describes the service life and replacement procedure for the Battery.

6-1	Periodic Maintenance and Inspection			
	6-1-1	Preparations for Problems	. 6-2	
	6-1-2	Periodic Inspection	. 6-2	
	6-1-3	Precautions When Replacing the NA Unit	. 6-4	
	6-1-4	Cleaning	. 6-4	
6-2	Replacing the Battery			
	6-2-1	Battery Replacement	. 6-5	
	6-2-2	Operation without a Battery	. 6-6	

Periodic Maintenance and Inspection 6-1

Periodic inspections are required in order to maintain the NA-series PT in the best operating condition.

6-1-1 **Preparations for Problems**

Observe the following precautions to enable smooth troubleshooting when problems occur.

Backing Up the Sysmac Studio Project

Always make a backup of the Sysmac Studio project and store it in a safe place. You will need it if you have to send in the NA Unit for repairs or if replace the NA Unit with another NA Unit.

Spare NA Units

We recommend that you keep spare NA Units on hand to enable faster system recovery when problems occur with an NA Unit, the backlight reaches the end of its life making the display hard to see, etc.

6-1-2 **Periodic Inspection**

Although the major components in NA Unit have an extremely long life time, they can deteriorate under improper environmental conditions. Periodic inspections are thus required.

Inspection is recommended at least once every six months to a year, but more frequent inspections will be necessary according to the ambient environment.

Take immediate steps to correct the situation if any of the conditions in the following table are outside of the criteria.

Periodic Inspection Points

No.	Item	Inspection	Criteria	Correction
1	Source power supply	Check for voltage fluctuations at the power supply terminals.	The voltage must be within the allowable voltage fluctuation range (19.2 to 28.8 V (24 V ±20%)).	Use a voltage tester to check the power supply at the terminals. Take necessary steps to bring voltage fluctuations within limits.
2	Ambient environ- ment	Make sure that the ambient temperature (e.g., the temperature inside the control panel) is suitable. Make sure that the ambient humidity (e.g., the humidity inside the control panel) is suitable. Check that the NA Unit is not in direct sunlight.	O to 50°C *1 The relative humidity must be 10% to 90% with no condensation.*1 Not in direct sunlight	Use a thermometer to check the temperature and ensure that the ambient temperature remains within the allowable range. Use a hygrometer to check the humidity and ensure that the ambient humidity remains within the allowable range. Be careful of the condensation caused by temperature changes. Protect the NA Unit if necessary.
		Check for accumulation of dirt, dust, salt, metal powder, etc.	No accumulation	Clean and protect the NA Unit if necessary.

No.	Item	Inspection	Criteria	Correction
2	Ambient environ- ment	Check for water, oil, or chemical sprays that may land on the NA Unit.	No spray	Clean and protect the NA Unit if necessary.
		Check for corrosive or flamma- ble gases in the area of the NA Unit.	No corrosive or flam- mable gases	Check by smell or use a sensor.
		Check for direct vibration or shock placed on the NA Unit.	Vibration resistance and shock resistance must be within specifi- cations.	Install cushioning or shock absorbing equipment if necessary.
		Check for noise sources near the NA Unit.	No noise source	Either separate the NA Unit away from noise source or protect the NA Unit.
3	Installa- tion and	Check the mounting brackets to see if they are loose.	No looseness	Tighten loose screws with a Phillips-head screwdriver.
	wiring	Check that cable connectors are fully inserted and locked.	No looseness	Fully insert and lock the connector
		Check for loose screws in external wiring.	No looseness	Tighten loose screws with a Phillips-head screwdriver.
		Check crimp connectors in external wiring.	Adequate spacing between connectors	Check visually and adjust if necessary.
		Check for damaged external wiring cables.	No visible damage	Check visually and replace cables if necessary.
4	User-ser viceable parts	Check the brightness of the backlight.	The backlight must be sufficiently bright. Backlight life (at room temperature and humidity): 50,000 hours	Contact your OMRON representative to request replacement.
		Check whether the CJ1W-BAT01 Battery Set has reached its service life or whether it is passed the expiration date.	Service life expectancy is 5 years.	Replace the Battery when its service life expectancy has passed even if a Battery error has not occurred.
5	Touch panel position input accuracy	Are the touched positions and the positions that respond off-set?	The positions must not be offset.	Calibrate the touch panel with the System Menu.

^{*1.} The ambient temperature and ambient humidity criteria depend on conditions. Refer to 1-4-1 General Specifications on page 1-9.

Tools Required for Inspections

Required Tools

- · Phillips-head screwdriver
- · Voltage tester or digital multi-meter
- · Industrial alcohol and clean cotton cloth

• Tools Required Occasionally

• Thermometer and hygrometer (humidity meter)

6-1-3 Precautions When Replacing the NA Unit

If you discover a fault in the NA Unit during inspections and must replace the NA Unit, observe the following precautions when you replace the NA Unit.

- Back up the NA Unit data. If OMRON performs repairs, the data may be deleted.
- Do not replace the NA Unit until the power is turned OFF.
- Check the new NA Unit to make sure that there are no errors.
- If you return a faulty NA Unit for repair, describe the problem in as much detail as possible and enclose this description with the NA Unit.
- For poor contact, take a clean cotton cloth, soak the cloth in industrial alcohol, and carefully wipe the contacts clean. Be sure to remove any lint prior to remounting the NA Unit.



Precautions for Correct Use

If you replaced the NA Unit, transfer the project and the variables with a Retain attribute (i.e., variables retained during power interruptions) that are required at startup before you start operation. Unexpected accidents may occur depending on the relation between the project and the status of variables retained during power interruptions.

6-1-4 Cleaning

Clean the NA Unit periodically in order to keep it in the best operating condition.

Cleaning Method

If the touch panel becomes dirty, the displays will be hard to see. Periodically clean the touch panel as follows:

- Wipe the NA Unit daily with a dry, soft cloth. If the touch panel is very dirty and you try to clean it with a dry cloth, you may scratch the front sheet. Use a damp cloth first to remove the dirt.
- When a spot cannot be removed with a dry cloth, dampen the cloth with a neutral cleanser (an approximately 2% solution), wring out the cloth, and wipe the NA Unit.
- A smudge may remain on the NA Unit from gum, vinyl, or tape that was left on for a long time. Remove any smudges when cleaning.



Precautions for Safe Use

Do not use volatile solvents such as benzene and thinners or chemical cloths.

6-2 Replacing the Battery

The Battery in the NA Unit requires maintenance. (The Battery is for the NA Unit's internal clock.) This section describes how to replace the Battery.

6-2-1 Battery Replacement

Purpose of the Battery

It is used to maintain the clock information in the NA Unit while the power supply is OFF. The clock will stop if there is no Battery or the Battery has been discharged completely.



Precautions for Correct Use

The Battery will loose its charge faster at high ambient temperatures.

Low Battery Indicators

When the Battery voltage drops below a certain level, the _HMI_IsBatteryLow (Low Battery Voltage) system-defined variable changes to True. E_SYS_015 error may occur in an periodic inspection because it happens when the battery voltage has dropped to less than the specified value. This error does not happen when the battery voltage is less than the specified value before startup. To check a drop in the battery voltage, install the system to monitor the system variable "_HMI_Is BatteryLow".

If the indicator flashes, see if the _HMI_IsBatteryLow system-defined variable is True. If it is True, first check the Battery connection in the NA Unit. If the Battery in the NA Unit is properly connected, replace the Battery with a new one as soon as possible.

Even if _HMI_IsBatteryLow changes to True, clock information can be retained by ensuring that the power supply to the NA Unit is not turned OFF.

Replacement Procedure


Use the following procedure to replace the Battery when the previous Battery has become completely discharged. Refer to 2-1-1 Components and Functions on page 2-2 for the details on replacing Battery.



Precautions for Safe Use

- Do not touch the packaging part of the circuit board with your bare hands. Discharge any static electricity from your body before handling the board.
- Do not use any battery if strong impact is applied to it (e.g. by dropping on the floor) because such a battery may cause a leakage.
- Apply power for at least five minutes before changing the battery. Mount a new battery within
 five minutes after turning OFF the power supply. If power is not supplied for at least five minutes, the clock data may be lost. Check the clock data after changing the battery.
- Do not dismantle a battery nor let it short-circuit.
- Do not apply an impact with the lithium battery, charge it, dispose it into a fire, or heat it.
 Doing either of them may cause an ignition or a bursting.
- Turn ON the power after replacing the Battery for an NA Unit that has not been used for a long time. Leaving the NA Unit unused again without turning ON the power even once after the Battery is replaced may result in a shorter Battery life.

- The following is required by UL standards: The Battery inside this product is not user replaceable. Replacement of the lithium battery needs to be done by a trained technician.
- Turn OFF the power supply to the NA Unit. If the NA Unit has not been ON, turn it ON for at least five minutes and then turn it OFF.
- Open the cover on the NA Unit, disconnect the Battery connector, remove the Battery, and replace it with a new Battery.





Precautions for Correct Use

Be sure to install a replacement Battery within two years of the production date shown on the Battery label.

Production Date



Manufactured in March 2014.



Additional Information

When you turn ON the power supply to the NA Unit after you replace the Battery, the _HMI_IsBatteryLow system-defined variable will automatically change to False.

6-2-2 **Operation without a Battery**

If a Battery is not connected or the Battery voltage is too low, the following operation occurs.

- The _HMI_IsBatteryLow system-defined variable will change to True.
- · Clock information will be incorrect.



Appendices

The appendices provide specifications and other information not provided in the body of this manual.


A-1	Dimen	sions	. A-2
	A-1-1	NA Units	. A-2
A-2	Availa	ble Products	A-10
	A-2-1	Optional Products	A-10

A-1 Dimensions


A-1-1 NA Units

NA5-15W□□□□-V1

NA Units




Cable Connection Dimensions




(Unit: mm)


NA5-12W□□□□-**V**1

NA Units




139.1







NA5-9W□□□□-V1

NA Units









NA5-7W□□□□-**V**1


NA Units






NA5-15W□□□□-V1-P

NA Units







139.1


69.1

NA5-12W□□□□-V1-P

NA Units










NA5-9W□□□□-V1-P

NA Units









NA5-7W \square \square \square -V1-P

NA Units





A-2 Available Products


A-2-1 Optional Products

Table of Optional Products

Name	Model	Remarks	
	NA-15WKBA04	Anti-reflection Sheets for NA5-15W□□□□(-V1)	
	NA-12WKBA04	Anti-reflection Sheets for NA5-12W□□□□(-V1)	
	NA-9WKBA04	Anti-reflection Sheets for NA5-9W□□□□(-V1)	
Anti-reflection Sheets	NA-7WKBA04	Anti-reflection Sheets for NA5-7W□□□□(-V1)	
Anti-renection Sheets	NA-15WKBA04-V2	Anti-reflection Sheets for NA5-15W□□□□-V1-P	
	NA-12WKBA04-V2	Anti-reflection Sheets for NA5-12W□□□□-V1-P	
	NA-9WKBA04-V2	Anti-reflection Sheets for NA5-9W□□□□-V1-P	
	NA-7WKBA04-V2	Anti-reflection Sheets for NA5-7W□□□□-V1-P	
	NA-15WATW01	High-pressure waterproofing frame for	
		NA5-15W□□□□(-V1)	
High-pressure	NA-12WATW01	High-pressure waterproofing frame for	
Waterproof Attach-		NA5-12W□□□□(-V1)	
ment (PWA)	NA-9WATW01	High-pressure waterproofing frame for	
		NA5-9W□□□□(-V1(-P))	
	NA-7WATW01	High-pressure waterproofing frame for	
		NA5-7W□□□□(-V1(-P))	
Battery	CJ1W-BAT01	Replacement Battery	
	HMC-SD292	SD Memory Card	
	HMC-SD492	SD Memory Card	
SD Memory Cards	HMC-SD1A2	SD Memory Card	
	FZ-MEM2G	USB Memory Device	
	FZ-MEM16G	USB Memory Device	

NA WKBA04 Anti-reflection Sheets

Attach a Sheet to the screen to protect against diffused reflections and dirt. The entire Sheet is colorless and transparent. Five Sheets are provided in one set.




Material	Attachment method
Polyester film	Double-sided tape

Model	Specification	Dimensions (Unit: mm)	
Wodel	Specification	Х	Υ
NA-15WKBA04	Anti-reflective protective sheets for NA5-15W□□□□(-V1)	415	286
NA-12WKBA04	Anti-reflective protective sheets for NA5-12W□□□□(-V1)	335	239
NA-9WKBA04	Anti-reflective protective sheets for NA5-9W□□□□(-V1)	285	185
NA-7WKBA04 Anti-reflective protective sheets for NA5-7W□□□□(-V1)		231	160

NA-UWKBA04-V2 Anti-reflection Sheets

Attach a Sheet to the screen to protect against diffused reflections and dirt. The entire Sheet is color-less and transparent. Five Sheets are provided in one set.





Material	Attachment method
Polyester film	Double-sided tape

Model	Specification	Dimensions (Unit: mm)	
Wiodei	Specification	Х	Υ
NA-15WKBA04-V2	Anti-reflective protective sheets for NA5-15W□□□□-V1-P	409	282
NA-12WKBA04-V2	Anti-reflective protective sheets for NA5-12W□□□□-V1-P	328	235
NA-9WKBA04-V2	Anti-reflective protective sheets for NA5-9W□□□□-V1-P	278	180
NA-7WKBA04-V2	Anti-reflective protective sheets for NA5-7W□□□□-V1-P	215	155

NA- WATW01 High-pressure Waterproof Attachment

The High-pressure Waterproof Attachment (PWA) is required to conform to UL Type 4X standards. The mounting panel thickness must be between 1.6 and 4.5 mm. To conform to UL Type 4X standards, always use the NA5-\(\subseteq\text{UM}\)\(\subseteq\subseteq\text{V1/NA5-7W}\)\(\subseteq\subseteq\subseteq\text{V1-P/NA5-9W}\)\(\subseteq\subseteq\subseteq\text{V1-P with a High-pressure Waterproof Attachment (PWA). If you do not use a PWA, there is a risk of water entry, which may cause severe equipment damage.






Material	Attachment method	
Stainless steel (AISI 304)	Mounting brackets	

Model	Specification	Dimensions (Unit: mm)		
Wodei		Х	Υ	Z
NA-15WATW01*1	High-pressure Waterproof Attachment for NA5-15W□□□□(-V1)	430	306	19
NA-12WATW01*1	High-pressure Waterproof Attachment for NA5-12W□□□□(-V1)	348	259	19
NA-9WATW01 High-pressure Waterproof Attachment for NA5-9W \(\subseteq \text{U}(-V1(-P)) \)		298	203	19
NA-7WATW01	High-pressure Waterproof Attachment for NA5-7W□□□□(-V1(-P))	234	178	19

^{*1.} When making NA5-15W \underset \u



Index

A	O .	
ABS1-23	Operation Log Viewer	4-31
Anti-reflection Sheets		
available products1-6, A-10	P	
В	performance specifications	1-12
	periodic inspection	
Battery 1-8	power supply connector	2-5
battery replacement	power supply specifications	3-16
BV1-23	R	
C	IX.	
	reset switch	2-6
cleaning6-4	RINA	
control panel3-5	RUN indicator	2-2, 5-2
CR1-23	6	
D	S	
	Safety Monitor	1-36
data capacity1-13	SD Memory Card slot	
dimensions	SD Memory Cards	
DNV1-23	Serial Port	
	Serial port	
E	shipbuilding standards	
	support software	
errors	system configurations System Menu	
Ethernet ports	system program	
external interfaces	system recovery	
F	,	
	. Т	
Function keys2-2		
	troubleshooting	5-5
G	U	
general specifications1-9		
grounding	USB host ports	1-13
grounding 0 20	USB Memory Devices	
1	USB slave port	
	147	
ID information label2-9	W	
installing NA Units	wining a marable and a	2.45
K	wiring methods	3-15
KR1-23		
L		
LR1-23		
N		
NA-series Programmable Terminals1-2		
NK		

OMRON Corporation Industrial Automation Company

Kyoto, JAPAN Contact : www.ia.omron.com

Regional Headquarters

OMRON EUROPE B.V.

Wegalaan 67-69, 2132 JD Hoofddorp The Netherlands Tel: (31) 2356-81-300 Fax: (31) 2356-81-388

OMRON ASIA PACIFIC PTE. LTD.

438B Alexandra Road, #08-01/02 Alexandra Technopark, Singapore 119968 Tel: (65) 6835-3011 Fax: (65) 6835-3011 OMRON ELECTRONICS LLC

2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900 Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD.

Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Tel: (86) 21-6023-0333 Fax: (86) 21-5037-2388 Authorized Distributor:

©OMRON Corporation 2020-2026 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

Cat. No. V125-E1-07 0126